



Sep 10, 2024

DIRKSEN

8601 W FOSTER AVE, Chicago IL 60656.

Dear **DIRKSEN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

DIRKSEN

8601 W FOSTER AVE, Chicago IL 60656.

Estimadas familias de **DIRKSEN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51007	51007-1-N-124-F03		Flush180	24-AUG-21	1.260	ug/L
51007	51007-1-N-124-F03		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-124-F03		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-F04		Flush180	24-AUG-21	10.000	ug/L
51007	51007-1-S-121-F04		Flush180	24-AUG-21	1.280	ug/L
51007	51007-1-S-121-F04		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-F04		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-F05		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-F05		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-F05		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-F05		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-F06		Flush180	24-AUG-21	2.750	ug/L
51007	51007-1-N-120-F06		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-F06		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-F06		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-126-F01		Flush180	24-AUG-21	1.170	ug/L
51007	51007-1-N-126-F01		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-126-F01		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-123-F02		Flush180	24-AUG-21	1.440	ug/L
51007	51007-1-S-123-F02		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-123-F02		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-123-F02		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-124-F03		Flush180	24-AUG-21	3.830	ug/L
51007	51007-1-N-126-F01		Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-F04		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-121-F04		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-121-F04		Flush180	03-SEP-21	4.020	ug/L
51007	51007-1-S-121-F04		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-120-F06		Flush180	03-SEP-21	1.110	ug/L
51007	51007-1-N-120-F06		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-120-F06		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-120-F06		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-F02		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-F02		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-F02		Flush180	03-SEP-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51007	51007-1-S-123-F02		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-F03		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-F03		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-F03		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-F03		Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-121-F04		Initial	24-AUG-21	7.750	ug/L
51007	51007-1-N-122-F05		Initial	24-AUG-21	2.980	ug/L
51007	51007-1-N-120-F06		Initial	24-AUG-21	19.000	ug/L
51007	51007-1-N-126-F01		Initial	24-AUG-21	2.790	ug/L
51007	51007-1-S-123-F02		Initial	24-AUG-21	19.800	ug/L
51007	51007-1-N-124-F03		Initial	24-AUG-21	68.000	ug/L
51007	51007-1-S-121-F04		Initial	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-F02		Initial	03-SEP-21	1.000	ug/L
51007	51007-1-N-120-F06		Initial	03-SEP-21	1.970	ug/L
51007	51007-1-N-124-F03		Initial	03-SEP-21	1.000	ug/L
51007	51007-1-HAL-F02	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F02	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F02	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F02	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F02	1ST FLOOR HALL	Initial	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F01	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F01	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F01	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F01	1ST FLOOR HALL	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F01	1ST FLOOR HALL	Initial	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F01	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F01	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F01	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F01	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F02	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F02	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F02	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F02	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F03	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F03	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F03	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F03	2ND FLOOR	Flush180	19-NOV-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51007	51007-2-HAL-F01	2ND FLOOR	Initial	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F02	2ND FLOOR	Initial	19-NOV-20	1.000	ug/L
51007	51007-2-HAL-F03	2ND FLOOR	Initial	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F01	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F01	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F01	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F02	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F02	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F02	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F02	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F01	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F01	3RD FLOOR	Initial	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F02	3RD FLOOR	Initial	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F03	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F03	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F03	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F03	3RD FLOOR	Flush180	19-NOV-20	1.000	ug/L
51007	51007-3-HAL-F03	3RD FLOOR	Initial	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F03	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F03	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F03	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F03	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F02	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F02	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F02	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F02	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F01	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F01	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F01	IN CAFE	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F01	IN CAFE	Initial	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F02	IN CAFE	Initial	19-NOV-20	1.000	ug/L
51007	51007-1-CAF-F01	IN CAFE	Initial	19-NOV-20	1.000	ug/L
51007	51007-1-HAL-F10	Left Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F10	Left Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F10	Left Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F10	Left Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F10	Left Fountain Next to Security Door 3	Initial	23-NOV-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F10	Door 3				
51007	51007-1-S-121-S07	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-S07	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-S07	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-S07	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S09	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S09	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S09	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S09	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S11	Left Sink	Flush180	24-AUG-21	1.050	ug/L
51007	51007-1-N-120-S11	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S11	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S11	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S13	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S13	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S13	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S13	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-126-S01	Left Sink	Flush180	24-AUG-21	1.550	ug/L
51007	51007-1-N-126-S01	Left Sink	Flush180	24-AUG-21	1.640	ug/L
51007	51007-1-N-126-S01	Left Sink	Flush180	24-AUG-21	2.310	ug/L
51007	51007-1-N-126-S01	Left Sink	Flush180	24-AUG-21	3.390	ug/L
51007	51007-1-S-123-S03	Left Sink	Flush180	24-AUG-21	1.700	ug/L
51007	51007-1-S-123-S03	Left Sink	Flush180	24-AUG-21	1.030	ug/L
51007	51007-1-S-123-S03	Left Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-123-S03	Left Sink	Flush180	24-AUG-21	1.070	ug/L
51007	51007-1-N-124-S05	Left Sink	Flush180	24-AUG-21	2.740	ug/L
51007	51007-1-N-124-S05	Left Sink	Flush180	24-AUG-21	3.060	ug/L
51007	51007-1-N-124-S05	Left Sink	Flush180	24-AUG-21	2.950	ug/L
51007	51007-1-N-124-S05	Left Sink	Flush180	24-AUG-21	1.350	ug/L
51007	51007-1-S-121-S07	Left Sink	Initial	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S09	Left Sink	Initial	24-AUG-21	1.300	ug/L
51007	51007-1-N-120-S11	Left Sink	Initial	24-AUG-21	4.490	ug/L
51007	51007-1-N-118-S13	Left Sink	Initial	24-AUG-21	1.000	ug/L
51007	51007-1-N-126-S01	Left Sink	Initial	24-AUG-21	1.000	ug/L
51007	51007-1-N-124-S05	Left Sink	Initial	24-AUG-21	2.720	ug/L
51007	51007-1-S-123-S03	Left Sink	Initial	24-AUG-21	1.770	ug/L
51007	51007-1-HAL-F12	Main- Across from Room 105 North, Fountain 1	Flush180	07-JUN-16	1.160	ppb
51007	51007-1-HAL-	Main- Across from Room 105	Flush180	07-JUN-16	0.444	ppb

Water Quality Assessment Everett McKinley Dirksen Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12	North, Fountain 1				
51007	51007-1-HAL-F12	Main- Across from Room 105 North, Fountain 1	Flush180	07-JUN-16	0.379	ppb
51007	51007-1-HAL-F12	Main- Across from Room 105 North, Fountain 1	Flush180	07-JUN-16	0.668	ppb
51007	51007-1-HAL-F12	Main- Across from Room 105 North, Fountain 1	Initial	07-JUN-16	0.963	ppb
51007	51007-1-HAL-F13	Main- Across from Room 105 South, Fountain 2	Flush180	07-JUN-16	0.526	ppb
51007	51007-1-HAL-F13	Main- Across from Room 105 South, Fountain 2	Flush180	07-JUN-16	0.535	ppb
51007	51007-1-HAL-F13	Main- Across from Room 105 South, Fountain 2	Flush180	07-JUN-16	0.489	ppb
51007	51007-1-HAL-F13	Main- Across from Room 105 South, Fountain 2	Flush180	07-JUN-16	0.459	ppb
51007	51007-1-HAL-F13	Main- Across from Room 105 South, Fountain 2	Initial	07-JUN-16	0.394	ppb
51007	51007-1-HAL-F05	Main- Across from Room 111 North, Fountain 1	Flush180	07-JUN-16	0.601	ppb
51007	51007-1-HAL-F05	Main- Across from Room 111 North, Fountain 1	Flush180	07-JUN-16	0.424	ppb
51007	51007-1-HAL-F05	Main- Across from Room 111 North, Fountain 1	Flush180	07-JUN-16	0.438	ppb
51007	51007-1-HAL-F05	Main- Across from Room 111 North, Fountain 1	Flush180	07-JUN-16	0.487	ppb
51007	51007-1-HAL-F05	Main- Across from Room 111 North, Fountain 1	Initial	07-JUN-16	1.010	ppb
51007	51007-1-HAL-F06	Main- Across from Room 111 South, Fountain 2	Flush180	07-JUN-16	0.460	ppb
51007	51007-1-HAL-F06	Main- Across from Room 111 South, Fountain 2	Flush180	07-JUN-16	0.471	ppb
51007	51007-1-HAL-F06	Main- Across from Room 111 South, Fountain 2	Flush180	07-JUN-16	0.472	ppb
51007	51007-1-HAL-F06	Main- Across from Room 111 South, Fountain 2	Flush180	07-JUN-16	0.471	ppb
51007	51007-1-HAL-F06	Main- Across from Room 111 South, Fountain 2	Initial	07-JUN-16	0.384	ppb
51007	51007-1-102-S10	Main- Inside Room 102, Sink	Flush180	07-JUN-16	0.799	ppb
51007	51007-1-102-S10	Main- Inside Room 102, Sink	Flush180	07-JUN-16	0.912	ppb
51007	51007-1-102-S10	Main- Inside Room 102, Sink	Flush180	07-JUN-16	0.968	ppb
51007	51007-1-102-S10	Main- Inside Room 102, Sink	Flush180	07-JUN-16	0.720	ppb
51007	51007-1-102-S10	Main- Inside Room 102, Sink	Initial	07-JUN-16	2.230	ppb
51007	51007-1-104-S11	Main- Inside Room 104, Sink	Flush180	07-JUN-16	1.220	ppb
51007	51007-1-104-S11	Main- Inside Room 104, Sink	Flush180	07-JUN-16	0.583	ppb
51007	51007-1-104-S11	Main- Inside Room 104, Sink	Flush180	07-JUN-16	0.828	ppb
51007	51007-1-104-S11	Main- Inside Room 104, Sink	Flush180	07-JUN-16	1.410	ppb
51007	51007-1-104-S11	Main- Inside Room 104, Sink	Initial	07-JUN-16	0.605	ppb
51007	51007-1-119-S07	Main- Inside Room 119, Sink	Flush180	07-JUN-16	0.353	ppb
51007	51007-1-119-S07	Main- Inside Room 119, Sink	Flush180	07-JUN-16	0.352	ppb
51007	51007-1-119-S07	Main- Inside Room 119, Sink	Flush180	07-JUN-16	0.356	ppb
51007	51007-1-119-S07	Main- Inside Room 119, Sink	Flush180	07-JUN-16	0.329	ppb
51007	51007-1-119-S07	Main- Inside Room 119, Sink	Initial	07-JUN-16	0.134	ppb
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	07-JUN-16	0.496	ppb
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	19-NOV-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	07-JUN-16	0.484	ppb
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	07-JUN-16	1.160	ppb
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Flush180	07-JUN-16	0.249	ppb
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Initial	19-NOV-20	2.090	ug/L
51007	51007-1-KIT-KS01	Main- Kitchen East, Sink 1	Initial	07-JUN-16	4.160	ppb
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	07-JUN-16	0.635	ppb
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	07-JUN-16	0.397	ppb
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	07-JUN-16	0.690	ppb
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Flush180	07-JUN-16	2.210	ppb
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Initial	19-NOV-20	1.000	ug/L
51007	51007-1-KIT-KS02	Main- Kitchen West, Sink 2	Initial	07-JUN-16	0.833	ppb
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	18-AUG-20	10.500	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-JUN-16	0.496	ppb
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-JUN-16	0.330	ppb
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-JUN-16	0.301	ppb
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Flush180	07-JUN-16	0.325	ppb
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Initial	18-AUG-20	4.600	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Initial	07-OCT-20	2.920	ug/L
51007	51007-1-HAL-F08	Main- Next to Room 119 East, Fountain 1	Initial	07-JUN-16	0.317	ppb
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-JUN-16	0.294	ppb
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-JUN-16	0.290	ppb
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-JUN-16	0.298	ppb
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Flush180	07-JUN-16	0.295	ppb
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Initial	07-JUN-16	0.227	ppb

Water Quality Assessment Everett McKinley Dirksen Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51007	51007-1-HAL-F09	Main- Next to Room 119 West, Fountain 2	Initial	07-OCT-20	1.000	ug/L
51007	51007-1-HAL-F03	Main- Outside Gym East, Fountain 1	Flush180	07-JUN-16	0.463	ppb
51007	51007-1-HAL-F03	Main- Outside Gym East, Fountain 1	Flush180	07-JUN-16	0.352	ppb
51007	51007-1-HAL-F03	Main- Outside Gym East, Fountain 1	Flush180	07-JUN-16	0.522	ppb
51007	51007-1-HAL-F03	Main- Outside Gym East, Fountain 1	Flush180	07-JUN-16	0.327	ppb
51007	51007-1-HAL-F03	Main- Outside Gym East, Fountain 1	Initial	07-JUN-16	0.526	ppb
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Flush180	18-AUG-20	4.980	ug/L
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Flush180	07-JUN-16	0.321	ppb
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Flush180	07-JUN-16	0.315	ppb
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Flush180	07-JUN-16	0.312	ppb
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Flush180	07-JUN-16	0.314	ppb
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Initial	18-AUG-20	3.030	ug/L
51007	51007-1-HAL-F04	Main- Outside Gym West, Fountain 2	Initial	07-JUN-16	0.479	ppb
51007	51007-1-HAL-F11	Right Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F11	Right Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F11	Right Fountain Next to Security Door 3	Flush180	23-NOV-21	1.000	ug/L
51007	51007-1-HAL-F11	Right Fountain Next to Security Door 3	Flush180	23-NOV-21	2.500	ug/L
51007	51007-1-HAL-F11	Right Fountain Next to Security Door 3	Initial	23-NOV-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	24-AUG-21	1.440	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S10	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S10	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S10	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-122-S10	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S12	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S12	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S12	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S12	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	24-AUG-21	2.530	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	24-AUG-21	1.080	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-126-S02	Right Sink	Flush180	24-AUG-21	3.420	ug/L
51007	51007-1-N-126-S02	Right Sink	Flush180	24-AUG-21	1.360	ug/L
51007	51007-1-N-126-S02	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-	Right Sink	Flush180	24-AUG-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	126-S02					
51007	51007-1-S-123-S04	Right Sink	Flush180	24-AUG-21	1.150	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	24-AUG-21	1.030	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	24-AUG-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Flush180	03-SEP-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	08-SEP-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	08-SEP-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	08-SEP-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Flush180	08-SEP-21	1.000	ug/L
51007	51007-1-S-121-S08	Right Sink	Initial	24-AUG-21	17.300	ug/L
51007	51007-1-N-122-S10	Right Sink	Initial	24-AUG-21	1.000	ug/L
51007	51007-1-N-120-S12	Right Sink	Initial	24-AUG-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Initial	24-AUG-21	5.140	ug/L
51007	51007-1-N-126-S02	Right Sink	Initial	24-AUG-21	1.700	ug/L
51007	51007-1-S-123-S04	Right Sink	Initial	24-AUG-21	5.290	ug/L
51007	51007-1-N-124-S06	Right Sink	Initial	24-AUG-21	6.410	ug/L
51007	51007-1-S-121-S08	Right Sink	Initial	03-SEP-21	1.000	ug/L
51007	51007-1-S-123-S04	Right Sink	Initial	03-SEP-21	1.000	ug/L
51007	51007-1-N-124-S06	Right Sink	Initial	03-SEP-21	1.000	ug/L
51007	51007-1-N-118-S14	Right Sink	Initial	08-SEP-21	1.000	ug/L
53000	53000-1-HAL-F02	Modular 2- NeModular 2- Next to Toilet South, Foun	Flush180	07-JUN-16	1.000	ppb
53000	53000-1-HAL-	Modular 2- NeModular 2- Next to	Flush180	07-JUN-16	1.000	ppb

**Water Quality Assessment
Everett McKinley Dirksen Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Toilet South, Foun				
53000	53000-1-HAL-F02	Modular 2- NeModular 2- Next to Toilet South, Foun	Flush180	07-JUN-16	1.000	ppb
53000	53000-1-HAL-F02	Modular 2- NeModular 2- Next to Toilet South, Foun	Flush180	07-JUN-16	1.000	ppb
53000	53000-1-HAL-F02	Modular 2- NeModular 2- Next to Toilet South, Foun	Initial	07-JUN-16	1.000	ppb
53000	53000-1-HAL-F01	Modular 2- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53000	53000-1-HAL-F01	Modular 2- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53000	53000-1-HAL-F01	Modular 2- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53000	53000-1-HAL-F01	Modular 2- Next to Toilet North, Founatin 1	Initial	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F01	Modular 1- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F01	Modular 1- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F01	Modular 1- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F01	Modular 1- Next to Toilet North, Founatin 1	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F01	Modular 1- Next to Toilet North, Founatin 1	Initial	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F02	Modular 1- Next to Toilet South, Founatin 2	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F02	Modular 1- Next to Toilet South, Founatin 2	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F02	Modular 1- Next to Toilet South, Founatin 2	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F02	Modular 1- Next to Toilet South, Founatin 2	Flush180	07-JUN-16	1.000	ppb
53788	53788-1-HAL-F02	Modular 1- Next to Toilet South, Founatin 2	Initial	07-JUN-16	1.000	ppb