



**Sep 10, 2024**

**DOOLITTLE**

**535 E 35TH ST, Chicago IL 60616.**

Dear **DOOLITTLE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**DOOLITTLE**

**535 E 35TH ST, Chicago IL 60616.**

Estimadas familias de **DOOLITTLE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51398	51398-B-W-KIT-KS02		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS02		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS02		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS02		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS03		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS03		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS03		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS03		Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS02		Initial	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS03		Initial	12-FEB-20	1.010	ug/L
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	17-JUN-16	1.290	ppb
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	17-JUN-16	1.340	ppb
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	17-JUN-16	1.200	ppb
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	17-JUN-16	1.130	ppb
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Initial	17-JUN-16	1.240	ppb
51398	51398-ANX-2-N-HAL-WC02	Annex- 2nd Floor At Stairwell, Watercooler 1	Initial	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	17-JUN-16	1.090	ppb
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	17-JUN-16	1.030	ppb
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	17-JUN-16	1.170	ppb
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	17-JUN-16	0.918	ppb
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Initial	17-JUN-16	1.280	ppb
51398	51398-ANX-2-N-HAL-WC03	Annex- 2nd Floor At Stairwell, Watercooler 2	Initial	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	17-JUN-16	2.720	ppb
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	17-JUN-16	3.010	ppb
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	17-JUN-16	3.030	ppb
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	17-JUN-16	2.460	ppb
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	12-FEB-20	2.930	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	12-FEB-20	1.270	ug/L
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Initial	17-JUN-16	0.616	ppb
51398	51398-ANX-2-W-HAL-WC01	Annex- 2nd Floor Common B2, Watercooler	Initial	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	17-JUN-16	0.316	ppb
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	17-JUN-16	0.189	ppb
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	17-JUN-16	0.234	ppb
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	17-JUN-16	0.222	ppb
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Initial	17-JUN-16	1.610	ppb
51398	51398-ANX-1-N-KIT-KS01	Annex- Kitchen Sink	Initial	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.252	ppb
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.125	ppb
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.234	ppb
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.214	ppb
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.198	ppb
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.141	ppb
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.128	ppb
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	0.132	ppb
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Initial	17-JUN-16	0.160	ppb
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Initial	17-JUN-16	0.159	ppb
51398	51398-ANX-1-W-HAL-WC03	Annex- Outside East Boys and Girls Toilets, Waterc	Initial	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-E-HAL-WC02	Annex- Outside East Boys and Girls Toilets, Waterc	Initial	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	1.680	ppb
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	1.980	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	1.520	ppb
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	17-JUN-16	1.930	ppb
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Flush180	12-FEB-20	1.000	ug/L
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Initial	17-JUN-16	1.270	ppb
51398	51398-ANX-1-W-HAL-WC04	Annex- Outside West Boys and Girls Toilets, Waterc	Initial	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	17-JUN-16	0.355	ppb
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	17-JUN-16	0.349	ppb
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	17-JUN-16	0.307	ppb
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	17-JUN-16	0.305	ppb
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Flush180	12-FEB-20	1.000	ug/L
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Initial	17-JUN-16	0.205	ppb
51398	51398-B-W-KIT-KS01	Main- Kitchen Sink	Initial	12-FEB-20	1.000	ug/L
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	17-JUN-16	1.920	ppb
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	17-JUN-16	1.140	ppb
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	17-JUN-16	1.190	ppb
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	17-JUN-16	1.420	ppb
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	12-FEB-20	1.010	ug/L
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	12-FEB-20	1.030	ug/L
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Flush180	12-FEB-20	1.010	ug/L
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Initial	17-JUN-16	1.150	ppb
51398	51398-1-S-HAL-WC01	Main- Outside Room 104 East, Watercooler 1	Initial	12-FEB-20	1.050	ug/L
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	17-JUN-16	1.720	ppb
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	17-JUN-16	1.140	ppb
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	17-JUN-16	0.821	ppb
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	17-JUN-16	1.410	ppb
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-S-HAL-WC02	Main- Outside Room 104 West, Watercooler 2	Initial	17-JUN-16	0.574	ppb
51398	51398-1-S-	Main- Outside Room 104 West,	Initial	12-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-WC02	Watercooler 2				
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	17-JUN-16	2.490	ppb
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	17-JUN-16	2.260	ppb
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	17-JUN-16	2.330	ppb
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Flush180	17-JUN-16	1.090	ppb
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Initial	17-JUN-16	0.163	ppb
51398	51398-1-N-HAL-WC03	Main- Outside Room 115, Watercooler 1	Initial	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	17-JUN-16	1.590	ppb
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	17-JUN-16	3.560	ppb
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	17-JUN-16	3.260	ppb
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Flush180	17-JUN-16	4.060	ppb
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Initial	12-FEB-20	1.000	ug/L
51398	51398-1-N-HAL-WC04	Main- Outside Room 115, Watercooler 2	Initial	17-JUN-16	1.000	ppb
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	17-JUN-16	1.930	ppb
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	17-JUN-16	1.940	ppb
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	17-JUN-16	1.880	ppb
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Flush180	17-JUN-16	1.880	ppb
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Initial	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC01	Main- Outside Room 204, Watercooler 1	Initial	17-JUN-16	2.010	ppb
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	17-JUN-16	0.927	ppb
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	17-JUN-16	0.998	ppb
51398	51398-2-S-	Main- Outside Room 204,	Flush180	17-JUN-16	1.030	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-WC02	Watercooler 2				
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Flush180	17-JUN-16	0.811	ppb
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Initial	12-FEB-20	1.000	ug/L
51398	51398-2-S-HAL-WC02	Main- Outside Room 204, Watercooler 2	Initial	17-JUN-16	0.663	ppb
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	17-JUN-16	0.125	ppb
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	17-JUN-16	0.155	ppb
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	17-JUN-16	0.186	ppb
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Flush180	17-JUN-16	0.220	ppb
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Initial	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC03	Main- Outside Room 215, Watercooler 1	Initial	17-JUN-16	1.000	ppb
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	17-JUN-16	0.151	ppb
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	17-JUN-16	0.128	ppb
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	17-JUN-16	1.000	ppb
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Flush180	17-JUN-16	0.166	ppb
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Initial	12-FEB-20	1.000	ug/L
51398	51398-2-N-HAL-WC04	Main- Outside Room 215, Watercooler 2	Initial	17-JUN-16	1.000	ppb
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	17-JUN-16	1.760	ppb
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	17-JUN-16	1.450	ppb
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	06-OCT-20	1.000	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	20-AUG-20	8.610	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	06-OCT-20	1.210	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	06-OCT-20	1.220	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	06-OCT-20	1.340	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	17-JUN-16	1.220	ppb
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Flush180	17-JUN-16	1.640	ppb
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Initial	17-JUN-16	1.270	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Initial	06-OCT-20	1.000	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Initial	12-FEB-20	1.000	ug/L
51398	51398-3-S-HAL-WC01	Main- Outside Room 304, Watercooler 1	Initial	20-AUG-20	7.860	ug/L
51398	51398-3-HAL-WC02	Main- Outside Room 304, Watercooler 2	Flush180	17-JUN-16	1.260	ppb
51398	51398-3-HAL-WC02	Main- Outside Room 304, Watercooler 2	Flush180	17-JUN-16	1.120	ppb
51398	51398-3-HAL-WC02	Main- Outside Room 304, Watercooler 2	Flush180	17-JUN-16	1.350	ppb
51398	51398-3-HAL-WC02	Main- Outside Room 304, Watercooler 2	Flush180	17-JUN-16	1.530	ppb
51398	51398-3-HAL-WC02	Main- Outside Room 304, Watercooler 2	Initial	17-JUN-16	1.050	ppb
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	17-JUN-16	0.483	ppb
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	17-JUN-16	0.593	ppb
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	17-JUN-16	0.535	ppb
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	17-JUN-16	0.510	ppb
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Flush180	12-FEB-20	1.000	ug/L
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Initial	17-JUN-16	0.552	ppb
51398	51398-3-N-HAL-WC03	Main- Outside Room 317, Watercooler 1	Initial	12-FEB-20	1.000	ug/L
51398	51398-3-HAL-WC04	Main- Outside Room 317, Watercooler 2	Flush180	17-JUN-16	0.826	ppb
51398	51398-3-HAL-WC04	Main- Outside Room 317, Watercooler 2	Flush180	17-JUN-16	0.949	ppb
51398	51398-3-HAL-WC04	Main- Outside Room 317, Watercooler 2	Flush180	17-JUN-16	0.888	ppb
51398	51398-3-HAL-WC04	Main- Outside Room 317, Watercooler 2	Flush180	17-JUN-16	0.952	ppb
51398	51398-3-HAL-WC04	Main- Outside Room 317, Watercooler 2	Initial	17-JUN-16	0.805	ppb
51398	51398-B-HAL-WC02	Main- Outside Room B19, Watercooler 1	Flush180	17-JUN-16	0.342	ppb
51398	51398-B-HAL-WC02	Main- Outside Room B19, Watercooler 1	Flush180	17-JUN-16	0.402	ppb
51398	51398-B-HAL-WC02	Main- Outside Room B19, Watercooler 1	Flush180	17-JUN-16	0.446	ppb
51398	51398-B-HAL-WC02	Main- Outside Room B19, Watercooler 1	Flush180	17-JUN-16	0.464	ppb
51398	51398-B-HAL-WC02	Main- Outside Room B19, Watercooler 1	Initial	17-JUN-16	0.262	ppb
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Flush180	17-JUN-16	0.432	ppb
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Flush180	17-JUN-16	0.508	ppb
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Flush180	17-JUN-16	0.508	ppb
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Flush180	17-JUN-16	0.462	ppb
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Flush180	20-AUG-20	1.000	ug/L
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Initial	17-JUN-16	0.505	ppb
51398	51398-B-HAL-WC03	Main- Outside Room B19, Watercooler 2	Initial	20-AUG-20	1.000	ug/L
51398	51398-B-HAL-WC04	Main- Outside Room B19, Watercooler 3	Flush180	17-JUN-16	0.637	ppb
51398	51398-B-HAL-WC04	Main- Outside Room B19, Watercooler 3	Flush180	17-JUN-16	0.623	ppb



**Water Quality Assessment**  
**James R Doolittle Jr Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51398	51398-B-HAL-WC04	Main- Outside Room B19, Watercooler 3	Flush180	17-JUN-16	0.676	ppb
51398	51398-B-HAL-WC04	Main- Outside Room B19, Watercooler 3	Flush180	17-JUN-16	0.712	ppb
51398	51398-B-HAL-WC04	Main- Outside Room B19, Watercooler 3	Initial	17-JUN-16	0.684	ppb