



Sep 10, 2024

**DOUGLASS HS**

**543 N WALLER AVE, Chicago IL 60644.**

Dear **DOUGLASS HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**DOUGLASS HS**

**543 N WALLER AVE, Chicago IL 60644.**

Estimadas familias de **DOUGLASS HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51104	51104-1-S-HAL-WC07		Flush180	28-AUG-19	9.650	ug/L
51104	51104-1-S-HAL-WC07		Flush180	28-AUG-19	8.900	ug/L
51104	51104-1-S-HAL-WC07		Flush180	28-AUG-19	6.740	ug/L
51104	51104-1-S-HAL-WC07		Flush180	28-AUG-19	8.000	ug/L
51104	51104-1-S-HAL-WC07		Flush180	30-JAN-20	1.000	ug/L
51104	51104-1-S-HAL-WC07		Flush180	30-JAN-20	1.000	ug/L
51104	51104-1-S-HAL-WC07		Flush180	30-JAN-20	1.000	ug/L
51104	51104-1-S-HAL-WC07		Flush180	30-JAN-20	1.000	ug/L
51104	51104-1-S-HAL-WC07		Initial	28-AUG-19	13.900	ug/L
51104	51104-1-S-HAL-WC07		Initial	30-JAN-20	1.000	ug/L
51104	51104-1-HAL-F05	Left Fountain by boys' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F05	Left Fountain by boys' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F05	Left Fountain by boys' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F05	Left Fountain by boys' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F05	Left Fountain by boys' restroom, across from room EE3	Initial	22-DEC-22	3.230	ug/L
51104	51104-2-N-HAL-WC07	Main- Across From Room 120A, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC07	Main- Across From Room 120A, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC07	Main- Across From Room 120A, Left Water Cooler	Flush180	13-OCT-16	2.100	ppb
51104	51104-2-N-HAL-WC07	Main- Across From Room 120A, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC07	Main- Across From Room 120A, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	13-OCT-16	3.200	ppb
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	13-OCT-16	2.600	ppb
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	13-OCT-16	3.100	ppb
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	13-OCT-16	2.900	ppb
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	28-AUG-19	4.310	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	28-AUG-19	3.770	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	28-AUG-19	3.410	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	28-AUG-19	2.910	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	01-MAY-20	3.170	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	01-MAY-20	3.920	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	01-MAY-20	3.490	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Flush180	01-MAY-20	3.870	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Initial	13-OCT-16	2.200	ppb
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Initial	28-AUG-19	6.500	ug/L
51104	51104-2-N-HAL-WC08	Main- Across From Room 120A, Right Water Cooler	Initial	01-MAY-20	4.100	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51104	51104-2-LR-F09	Main- Girls Locker Room, Fountain	Flush180	13-OCT-16	15.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	24-MAR-17	1.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	24-MAR-17	1.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	24-MAR-17	1.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	24-MAR-17	1.000	ppb
51104	51104-2-LR-F09	Main- Girls Locker Room, Fountain	Flush180	13-OCT-16	24.000	ppb
51104	51104-2-LR-F09	Main- Girls Locker Room, Fountain	Flush180	13-OCT-16	13.000	ppb
51104	51104-2-LR-F09	Main- Girls Locker Room, Fountain	Flush180	13-OCT-16	48.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	9.100	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	7.600	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	11.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	7.600	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	7.600	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	9.100	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	11.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Flush180	08-DEC-16	7.600	ppb
51104	51104-2-LR-F09	Main- Girls Locker Room, Fountain	Initial	13-OCT-16	320.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Initial	08-DEC-16	28.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Initial	08-DEC-16	28.000	ppb
51104	51104-2-LOC-F09	Main- Girls Locker Room, Fountain	Initial	24-MAR-17	1.000	ppb
51104	51104-1-GYM-F01	Main- Gym, North Fountain- OUT OF ORDER	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-GYM-F01	Main- Gym, North Fountain- OUT OF ORDER	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-GYM-F01	Main- Gym, North Fountain- OUT OF ORDER	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-GYM-F01	Main- Gym, North Fountain- OUT OF ORDER	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-GYM-F01	Main- Gym, North Fountain- OUT OF ORDER	Initial	13-OCT-16	1.000	ppb
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	13-OCT-16	3.400	ppb
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	13-OCT-16	3.800	ppb
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	13-OCT-16	3.500	ppb
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	13-OCT-16	3.400	ppb
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	28-AUG-19	24.500	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	28-AUG-19	30.300	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	28-AUG-19	32.200	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	28-AUG-19	26.700	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	22-MAY-20	8.730	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	22-MAY-20	6.800	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	22-MAY-20	5.550	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	22-MAY-20	4.040	ug/L

## Water Quality Assessment Frederick A Douglass Academy High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	01-MAY-20	15.400	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	01-MAY-20	8.490	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	01-MAY-20	7.440	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Flush180	01-MAY-20	6.680	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Initial	13-OCT-16	6.500	ppb
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Initial	28-AUG-19	15.100	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Initial	22-MAY-20	24.000	ug/L
51104	51104-1-S-GYM-F02	Main- Gym, South Fountain	Initial	01-MAY-20	83.300	ug/L
51104	51104-1-N-KIT-KS02	Main- Kitchen, 3- Basin, Center Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS02	Main- Kitchen, 3- Basin, Center Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS02	Main- Kitchen, 3- Basin, Center Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS02	Main- Kitchen, 3- Basin, Center Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS02	Main- Kitchen, 3- Basin, Center Faucet	Initial	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS01	Main- Kitchen, 3- Basin, Left Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS01	Main- Kitchen, 3- Basin, Left Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS01	Main- Kitchen, 3- Basin, Left Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS01	Main- Kitchen, 3- Basin, Left Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS01	Main- Kitchen, 3- Basin, Left Faucet	Initial	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	13-OCT-16	2.400	ppb
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	13-OCT-16	3.700	ppb
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	13-OCT-16	2.600	ppb
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	28-AUG-19	1.310	ug/L
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Initial	13-OCT-16	1.000	ppb
51104	51104-1-N-KIT-KS03	Main- Kitchen, 3- Basin, Right Faucet	Initial	28-AUG-19	1.000	ug/L
51104	51104-1-S-KIT-KS04	Main- Kitchen, South Wall Sink	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-KIT-KS04	Main- Kitchen, South Wall Sink	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-KIT-KS04	Main- Kitchen, South Wall Sink	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-KIT-KS04	Main- Kitchen, South Wall Sink	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-KIT-KS04	Main- Kitchen, South Wall Sink	Initial	13-OCT-16	1.000	ppb
51104	51104-1-MOF-S20	Main- Main Office Toilets, Sink-NOT TESTED, HANDWASHING SINK	Flush180	13-OCT-16	2.000	ppb
51104	51104-1-MOF-S20	Main- Main Office Toilets, Sink-NOT TESTED, HANDWASHING SINK	Flush180	13-OCT-16	2.300	ppb
51104	51104-1-MOF-S20	Main- Main Office Toilets, Sink-NOT TESTED, HANDWASHING SINK	Flush180	13-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51104	51104-1-MOF-S20	Main- Main Office Toilets, Sink-NOT TESTED, HANDWASHING SINK	Flush180	13-OCT-16	3.000	ppb
51104	51104-1-MOF-S20	Main- Main Office Toilets, Sink-NOT TESTED, HANDWASHING SINK	Initial	13-OCT-16	2.900	ppb
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	28-AUG-19	1.020	ug/L
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	28-AUG-19	1.120	ug/L
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Flush180	28-AUG-19	1.150	ug/L
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC03	Main- Next to Room 1806, LEFT Water Cooler	Initial	28-AUG-19	1.000	ug/L
51104	51104-1-S-HAL-WC04	Main- Next to Room 1806, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC04	Main- Next to Room 1806, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC04	Main- Next to Room 1806, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC04	Main- Next to Room 1806, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC04	Main- Next to Room 1806, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	13-OCT-16	2.100	ppb
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Flush180	28-AUG-19	1.000	ug/L
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC08	Main- North of Room 104, Left Water Cooler	Initial	28-AUG-19	1.000	ug/L
51104	51104-1-HAL-WC19	Main- North of Room 104, Right Water Cooler	Flush180	13-OCT-16	4.400	ppb
51104	51104-1-HAL-WC19	Main- North of Room 104, Right Water Cooler	Flush180	13-OCT-16	3.900	ppb
51104	51104-1-HAL-WC19	Main- North of Room 104, Right Water Cooler	Flush180	13-OCT-16	4.500	ppb
51104	51104-1-HAL-WC19	Main- North of Room 104, Right Water Cooler	Flush180	13-OCT-16	3.900	ppb
51104	51104-1-HAL-WC19	Main- North of Room 104, Right Water Cooler	Initial	13-OCT-16	2.500	ppb
51104	51104-1-S-HAL-WC05	Main- North of Room 168, LEFT Water Cooler	Flush180	13-OCT-16	3.100	ppb
51104	51104-1-S-HAL-WC05	Main- North of Room 168, LEFT Water Cooler	Flush180	13-OCT-16	3.200	ppb
51104	51104-1-S-HAL-WC05	Main- North of Room 168, LEFT Water Cooler	Flush180	13-OCT-16	3.500	ppb
51104	51104-1-S-HAL-WC05	Main- North of Room 168, LEFT Water Cooler	Flush180	13-OCT-16	3.500	ppb

## Water Quality Assessment Frederick A Douglass Academy High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51104	51104-1-S-HAL-WC05	Main- North of Room 168, LEFT Water Cooler	Initial	13-OCT-16	2.800	ppb
51104	51104-1-S-HAL-WC06	Main- North of Room 168, RIGHT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC06	Main- North of Room 168, RIGHT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC06	Main- North of Room 168, RIGHT Water Cooler	Flush180	13-OCT-16	2.200	ppb
51104	51104-1-S-HAL-WC06	Main- North of Room 168, RIGHT Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-WC06	Main- North of Room 168, RIGHT Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	28-AUG-19	6.430	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	28-AUG-19	11.000	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	28-AUG-19	9.110	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	28-AUG-19	7.590	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Initial	28-AUG-19	13.600	ug/L
51104	51104-2-N-HAL-WC05	Main- Outside 327C, Left Water Cooler	Initial	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	13-OCT-16	2.200	ppb
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	13-OCT-16	2.100	ppb
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	13-OCT-16	2.100	ppb
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	13-OCT-16	2.000	ppb
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	28-AUG-19	4.410	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	28-AUG-19	3.630	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	28-AUG-19	2.830	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	28-AUG-19	3.270	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Flush180	30-JAN-20	1.000	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Initial	13-OCT-16	2.300	ppb
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Initial	28-AUG-19	5.850	ug/L
51104	51104-2-N-HAL-WC06	Main- Outside 327C, Right Water Cooler	Initial	30-JAN-20	1.000	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-S-	Main- Outside Office 204B, Left	Flush180	13-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-WC01	Water Cooler				
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	28-AUG-19	8.230	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	28-AUG-19	7.900	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	28-AUG-19	7.370	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	28-AUG-19	6.780	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	30-JAN-20	1.360	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	30-JAN-20	1.500	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	30-JAN-20	2.380	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Flush180	30-JAN-20	3.260	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Initial	28-AUG-19	12.000	ug/L
51104	51104-2-S-HAL-WC01	Main- Outside Office 204B, Left Water Cooler	Initial	30-JAN-20	1.310	ug/L
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	28-AUG-19	3.660	ug/L
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	28-AUG-19	3.360	ug/L
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	28-AUG-19	2.910	ug/L
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Flush180	28-AUG-19	2.500	ug/L
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC02	Main- Outside Office 204B, Right Water Cooler	Initial	28-AUG-19	4.380	ug/L
51104	51104-1-S-HAL-F01	Main- Outside Room 1607, Left Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F01	Main- Outside Room 1607, Left Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F01	Main- Outside Room 1607, Left Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F01	Main- Outside Room 1607, Left Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F01	Main- Outside Room 1607, Left Fountain	Initial	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F02	Main- Outside Room 1607, Right Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F02	Main- Outside Room 1607, Right Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F02	Main- Outside Room 1607, Right Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F02	Main- Outside Room 1607, Right Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-S-HAL-F02	Main- Outside Room 1607, Right Fountain	Initial	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC04	Main- Outside Room 420D, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC04	Main- Outside Room 420D, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC04	Main- Outside Room 420D, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-2-HAL-WC04	Main- Outside Room 420D, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb



## Water Quality Assessment Frederick A Douglass Academy High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC04	Water Cooler				
51104	51104-2-HAL-WC04	Main- Outside Room 420D, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-1-W-HAL-F03	Main- Outside Swimming Pool, North Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-W-HAL-F03	Main- Outside Swimming Pool, North Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-W-HAL-F03	Main- Outside Swimming Pool, North Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-W-HAL-F03	Main- Outside Swimming Pool, North Fountain	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-W-HAL-F03	Main- Outside Swimming Pool, North Fountain	Initial	13-OCT-16	1.000	ppb
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	13-OCT-16	4.300	ppb
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	13-OCT-16	3.500	ppb
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	13-OCT-16	3.300	ppb
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	13-OCT-16	3.000	ppb
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	28-AUG-19	2.720	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	28-AUG-19	2.290	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	28-AUG-19	2.420	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	28-AUG-19	2.000	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	01-MAY-20	2.310	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	01-MAY-20	2.220	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	01-MAY-20	2.240	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	01-MAY-20	1.990	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	30-JAN-20	2.550	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	30-JAN-20	2.670	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	30-JAN-20	2.390	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Flush180	30-JAN-20	2.090	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Initial	13-OCT-16	14.000	ppb
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Initial	28-AUG-19	6.980	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Initial	01-MAY-20	2.090	ug/L
51104	51104-1-W-HAL-F04	Main- Outside Swimming Pool, South Fountain	Initial	30-JAN-20	6.490	ug/L
51104	51104-1-N-HAL-WC01	Main- WEST of Room 183, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC01	Main- WEST of Room 183, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC01	Main- WEST of Room 183, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC01	Main- WEST of Room 183, Left Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC01	Main- WEST of Room 183, Left Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC02	Main- west of Room 183, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC02	Main- west of Room 183, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC02	Main- west of Room 183, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC02	Main- west of Room 183, Right Water Cooler	Flush180	13-OCT-16	1.000	ppb
51104	51104-1-N-HAL-WC02	Main- west of Room 183, Right Water Cooler	Initial	13-OCT-16	1.000	ppb
51104	51104-1-HAL-BF01	Right BF by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51104	51104-1-HAL-BF01	Right BF by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-BF01	Right BF by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-BF01	Right BF by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-BF01	Right BF by girls' restroom, across from room EE3	Initial	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F06	Right fountain by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F06	Right fountain by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F06	Right fountain by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F06	Right fountain by girls' restroom, across from room EE3	Flush180	22-DEC-22	1.000	ug/L
51104	51104-1-HAL-F06	Right fountain by girls' restroom, across from room EE3	Initial	22-DEC-22	1.000	ug/L