



**Sep 10, 2024**

**DURKIN PARK**

**8445 S KOLIN AVE, Chicago IL 60652.**

Dear **DURKIN PARK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**DURKIN PARK**

**8445 S KOLIN AVE, Chicago IL 60652.**

Estimadas familias de **DURKIN PARK**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	01-JUN-16	0.729	ppb
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	01-JUN-16	0.389	ppb
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	01-JUN-16	0.428	ppb
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	01-JUN-16	0.579	ppb
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	27-JAN-22	1.010	ug/L
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	27-JAN-22	1.070	ug/L
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Initial	01-JUN-16	1.210	ppb
51314	51314-1-HAL-F03	Main- 1st floor Outside Main Office, Fountain 1	Initial	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	01-JUN-16	0.265	ppb
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	01-JUN-16	0.317	ppb
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	01-JUN-16	0.419	ppb
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	01-JUN-16	0.869	ppb
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-OCT-20	1.160	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Initial	01-JUN-16	0.266	ppb
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Initial	27-OCT-20	1.000	ug/L
51314	51314-1-HAL-F04	Main- 1st floor Outside Main Office, Fountain 2	Initial	27-JAN-22	1.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	01-JUN-16	21.100	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	01-JUN-16	71.500	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	18-AUG-16	7.600	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	18-AUG-16	6.200	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	15-NOV-16	4.920	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	15-NOV-16	6.090	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	15-NOV-16	3.190	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	15-NOV-16	5.340	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	01-JUN-16	31.700	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	18-AUG-16	6.700	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	18-AUG-16	6.700	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	01-JUN-16	73.200	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	29-JUL-20	93.200	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-JAN-22	25.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-JAN-22	39.600	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-JAN-22	18.700	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-JAN-22	19.900	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Flush180	27-OCT-20	1.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Initial	01-JUN-16	42.400	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Initial	18-AUG-16	9.700	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Initial	15-NOV-16	3.040	ppb
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Initial	29-JUL-20	34.100	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Initial	27-OCT-20	1.000	ug/L
51314	51314-1-137-S01	Main-1st floor Inside Room 137, Sink	Initial	27-JAN-22	26.400	ug/L
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	01-JUN-16	4.570	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	01-JUN-16	2.830	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	01-JUN-16	0.578	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	01-JUN-16	0.837	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	18-AUG-16	6.300	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	18-AUG-16	4.000	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	18-AUG-16	6.800	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	18-AUG-16	5.700	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	27-JAN-22	1.110	ug/L
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Initial	01-JUN-16	1.990	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Initial	18-AUG-16	3.200	ppb
51314	51314-1-139-S02	Main-1st floor Inside Room 139, Sink	Initial	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F05	Main-1st floor by East Enterance, Fountain 1	Flush180	01-JUN-16	0.373	ppb
51314	51314-1-HAL-F05	Main-1st floor by East Enterance, Fountain 1	Flush180	01-JUN-16	0.271	ppb
51314	51314-1-HAL-F05	Main-1st floor by East Enterance, Fountain 1	Flush180	01-JUN-16	0.274	ppb
51314	51314-1-HAL-F05	Main-1st floor by East Enterance, Fountain 1	Flush180	01-JUN-16	1.000	ppb
51314	51314-1-HAL-F05	Main-1st floor by East Enterance, Fountain 1	Flush180	29-JUL-20	10.200	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Initial	01-JUN-16	0.257	ppb
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Initial	29-JUL-20	24.100	ug/L
51314	51314-1-HAL-F05	Main-1st floor by East Entrance, Fountain 1	Initial	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	01-JUN-16	0.464	ppb
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	01-JUN-16	0.270	ppb
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	01-JUN-16	0.936	ppb
51314	51314-1-HAL-F06-051314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	01-JUN-16	0.912	ppb
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Initial	01-JUN-16	0.889	ppb
51314	51314-1-HAL-F06	Main-1st floor by East Entrance, Fountain 2	Initial	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	01-JUN-16	0.358	ppb
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	01-JUN-16	0.216	ppb
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	01-JUN-16	1.020	ppb
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	01-JUN-16	0.212	ppb
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Initial	01-JUN-16	0.230	ppb
51314	51314-1-HAL-F07	Main-1st floor by East Entrance, Fountain 3	Initial	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-RBF02	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-RBF02	left retrofitted bottle filler	Flush180	27-JAN-22	1.060	ug/L
51314	51314-1-HAL-RBF02	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-RBF02	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
51314	51314-1-HAL-RBF02	left retrofitted bottle filler	Initial	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-F01	Modular- Outside Girls Bathroom, Fountain 1	Flush180	01-JUN-16	0.179	ppb
53790	53790-1-HAL-F01	Modular- Outside Girls Bathroom, Fountain 1	Flush180	01-JUN-16	0.510	ppb
53790	53790-1-HAL-F01	Modular- Outside Girls Bathroom, Fountain 1	Flush180	01-JUN-16	0.202	ppb
53790	53790-1-HAL-F01	Modular- Outside Girls Bathroom, Fountain 1	Flush180	01-JUN-16	0.163	ppb
53790	53790-1-HAL-F01	Modular- Outside Girls Bathroom, Fountain 1	Initial	01-JUN-16	0.210	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	01-JUN-16	0.178	ppb
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	01-JUN-16	0.190	ppb
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	01-JUN-16	0.207	ppb
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	01-JUN-16	0.157	ppb
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Initial	01-JUN-16	0.578	ppb
53790	53790-1-HAL-F02	Modular- Outside Girls Bathroom, Fountain 2	Initial	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-RBF03	outside girl's bathroom left	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-RBF03	outside girl's bathroom left	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-RBF03	outside girl's bathroom left	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-RBF03	outside girl's bathroom left	Flush180	27-JAN-22	1.000	ug/L
53790	53790-1-HAL-RBF03	outside girl's bathroom left	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	01-JUN-16	1.050	ppb
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Initial	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F01	Addition 1-1st floor by Cafeteria Fountain 1	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	29-JUL-20	1.000	ug/L
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Initial	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Initial	29-JUL-20	1.740	ug/L
54131	54131-1-HAL-F02	Addition 1-1st floor by Cafeteria Fountain 2	Initial	27-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Initial	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F03	Addition 1-1st floor by Cafeteria Fountain 3	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F04	Addition 1-1st floor by room 108, Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F04	Addition 1-1st floor by room 108, Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F04	Addition 1-1st floor by room 108, Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F04	Addition 1-1st floor by room 108, Fountain 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F04	Addition 1-1st floor by room 108, Fountain 1	Initial	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	29-JUL-20	1.000	ug/L
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Initial	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Initial	29-JUL-20	1.000	ug/L
54131	54131-1-HAL-F05	Addition 1-1st floor by room 108, Fountain 2	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Initial	01-JUN-16	1.000	ppb
54131	54131-1-HAL-F06	Addition 1-1st floor by room 108, Fountain 3	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-	Addition 1-Kitchen cleaning sink 2	Flush180	01-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS08					
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Initial	01-JUN-16	1.000	ppb
54131	54131-1-KIT-KS08	Addition 1-Kitchen cleaning sink 2	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	01-JUN-16	1.000	ppb
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	01-JUN-16	0.213	ppb
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	01-JUN-16	0.180	ppb
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Initial	01-JUN-16	0.143	ppb
54131	54131-1-KIT-KS07	Addition 1-Kitchen cooking sink 1	Initial	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-RBF01	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-RBF01	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-RBF01	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-RBF01	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
54131	54131-1-HAL-RBF01	left retrofitted bottle filler	Initial	27-JAN-22	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-S01	IN ANNEX	Initial	08-DEC-20	1.280	ug/L
57390	57390-1-1014-S01	IN ANNEX	Initial	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	01-JUN-16	1.000	ppb
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	01-JUN-16	1.000	ppb
57390	57390-1-HAL-	Addition 2-1st floor by room 130,	Flush180	01-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09	Fountain				
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	01-JUN-16	1.000	ppb
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Initial	01-JUN-16	1.000	ppb
57390	57390-1-HAL-F09	Addition 2-1st floor by room 130, Fountain	Initial	27-JAN-22	1.000	ug/L
57390	57390-1-1014-F01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-F01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-F01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-F01	IN ANNEX	Flush180	08-DEC-20	1.000	ug/L
57390	57390-1-1014-F01	IN ANNEX	Initial	08-DEC-20	1.690	ug/L
57390	57390-1-HAL-F10	by room 130 right	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F10	by room 130 right	Flush180	27-JAN-22	1.640	ug/L
57390	57390-1-HAL-F10	by room 130 right	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F10	by room 130 right	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-HAL-F10	by room 130 right	Initial	27-JAN-22	1.000	ug/L
57390	57390-1-1014-RBF04	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-RBF04	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-RBF04	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-RBF04	left retrofitted bottle filler	Flush180	27-JAN-22	1.000	ug/L
57390	57390-1-1014-RBF04	left retrofitted bottle filler	Initial	27-JAN-22	1.000	ug/L