



Sep 10, 2024

DYETT ARTS HS

555 E 51ST ST, Chicago IL 60615.

Dear **DYETT ARTS HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

DYETT ARTS HS

555 E 51ST ST, Chicago IL 60615.

Estimadas familias de **DYETT ARTS HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-2-W-HAL-F07		Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F07		Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F07		Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F07		Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F07		Initial	14-MAY-19	1.000	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	26-AUG-16	21.700	ppb
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	26-AUG-16	26.200	ppb
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	26-AUG-16	15.700	ppb
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	26-AUG-16	10.300	ppb
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	14-MAY-19	4.180	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	14-MAY-19	2.570	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	14-MAY-19	1.410	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	14-MAY-19	1.130	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	07-MAY-20	3.380	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	07-MAY-20	2.120	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	07-MAY-20	1.250	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Flush180	07-MAY-20	1.000	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Initial	26-AUG-16	19.500	ppb
51585	51585-1-S-BLR-F02	Boys Locker Room	Initial	14-MAY-19	19.700	ug/L
51585	51585-1-S-BLR-F02	Boys Locker Room	Initial	07-MAY-20	4.490	ug/L
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	26-AUG-16	2.620	ppb
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	26-AUG-16	2.230	ppb
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	26-AUG-16	6.130	ppb
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	26-AUG-16	3.740	ppb
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Initial	26-AUG-16	11.400	ppb
51585	51585-1-E-BLR-F01	Boys Locker Room Outside office	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	13-JUL-23	1.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	13-JUL-23	1.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	13-JUL-23	1.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	13-JUL-23	1.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	14-MAY-19	60.700	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	14-MAY-19	45.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	14-MAY-19	23.600	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	14-MAY-19	6.050	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	26-AUG-16	7.340	ppb
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	26-AUG-16	2.580	ppb
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	26-AUG-16	1.610	ppb
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	26-AUG-16	4.670	ppb
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	07-MAY-20	5.190	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	07-MAY-20	7.320	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	07-MAY-20	5.280	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	07-MAY-20	3.980	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	29-MAY-20	5.060	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	29-MAY-20	10.400	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	29-MAY-20	14.300	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Flush180	29-MAY-20	14.000	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Initial	13-JUL-23	1.080	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Initial	14-MAY-19	44.200	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Initial	26-AUG-16	5.340	ppb
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Initial	07-MAY-20	10.700	ug/L
51585	51585-1-W-PBLR-F01	Boys Locker Room for Pool	Initial	29-MAY-20	1.570	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	13-JUL-23	1.530	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	13-JUL-23	1.330	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	13-JUL-23	3.450	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	13-JUL-23	3.660	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	26-AUG-16	5.550	ppb
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	26-AUG-16	7.160	ppb
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	26-AUG-16	5.120	ppb
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	26-AUG-16	3.980	ppb
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	14-MAY-19	5.910	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	14-MAY-19	4.950	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	14-MAY-19	2.440	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	14-MAY-19	1.900	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	07-MAY-20	17.500	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	07-MAY-20	24.800	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	07-MAY-20	24.000	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	07-MAY-20	13.800	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	29-MAY-20	15.200	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	29-MAY-20	40.600	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	29-MAY-20	56.200	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Flush180	29-MAY-20	38.900	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Initial	13-JUL-23	1.320	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Initial	26-AUG-16	10.700	ppb
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Initial	14-MAY-19	7.520	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Initial	07-MAY-20	22.900	ug/L
51585	51585-1-S-GLR-F02	Girls Locker Room Lobby	Initial	29-MAY-20	2.000	ug/L
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	26-AUG-16	2.610	ppb
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	26-AUG-16	5.280	ppb
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	26-AUG-16	20.000	ppb
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	26-AUG-16	15.500	ppb
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	14-MAY-19	1.880	ug/L
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	14-MAY-19	1.650	ug/L
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	14-MAY-19	1.570	ug/L
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Flush180	14-MAY-19	1.400	ug/L
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Initial	26-AUG-16	28.800	ppb
51585	51585-1-W-GLR-F01	Girls Locker Room Outside Office	Initial	14-MAY-19	1.570	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	16-FEB-17	4.300	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	14-MAY-19	6.200	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	14-MAY-19	5.060	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	14-MAY-19	4.020	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	14-MAY-19	3.170	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	16-FEB-17	3.500	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	26-AUG-16	10.100	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	26-AUG-16	59.200	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	26-AUG-16	73.300	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	26-AUG-16	34.400	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	16-FEB-17	3.600	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	16-FEB-17	3.700	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	07-MAY-20	4.710	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	07-MAY-20	9.670	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	07-MAY-20	8.700	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	07-MAY-20	7.680	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	29-MAY-20	3.950	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	29-MAY-20	7.780	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	29-MAY-20	6.920	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Flush180	29-MAY-20	6.660	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	PGLR-F01					
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Initial	16-FEB-17	6.500	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Initial	14-MAY-19	7.080	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Initial	26-AUG-16	16.800	ppb
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Initial	07-MAY-20	3.060	ug/L
51585	51585-1-W-PGLR-F01	Girls Locker Room for Pool	Initial	29-MAY-20	3.750	ug/L
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	26-AUG-16	0.565	ppb
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	26-AUG-16	0.505	ppb
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	26-AUG-16	0.528	ppb
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	26-AUG-16	0.459	ppb
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Initial	26-AUG-16	1.260	ppb
51585	51585-1-N-KIT-KS03	Kitchen North Wall Near Coolers Left Sink	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	26-AUG-16	0.810	ppb
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	26-AUG-16	0.759	ppb
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	26-AUG-16	0.765	ppb
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	26-AUG-16	0.745	ppb
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Initial	26-AUG-16	1.320	ppb
51585	51585-1-N-KIT-KS02	Kitchen North Wall near Coolers Middle Sink	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	26-AUG-16	0.782	ppb
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	26-AUG-16	0.688	ppb
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	26-AUG-16	0.886	ppb
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	26-AUG-16	0.824	ppb
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Initial	26-AUG-16	1.650	ppb
51585	51585-1-N-KIT-KS01	Kitchen North Wall near Coolers/ Right Sink	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	26-AUG-16	1.170	ppb
51585	51585-1-S-	Kitchen South Wall	Flush180	26-AUG-16	0.820	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS07					
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	26-AUG-16	0.741	ppb
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	26-AUG-16	0.625	ppb
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Initial	26-AUG-16	1.760	ppb
51585	51585-1-S-KIT-KS07	Kitchen South Wall	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	26-AUG-16	1.810	ppb
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	26-AUG-16	0.901	ppb
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	26-AUG-16	0.725	ppb
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	26-AUG-16	0.819	ppb
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Initial	26-AUG-16	22.000	ppb
51585	51585-1-S-KIT-KS06	Kitchen South Wall Near Coolers Right Sink	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	26-AUG-16	8.090	ppb
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	26-AUG-16	3.620	ppb
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	26-AUG-16	2.070	ppb
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	26-AUG-16	2.590	ppb
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Initial	26-AUG-16	10.600	ppb
51585	51585-1-S-KIT-KS04	Kitchen South Wall near Coolers Left Sink	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	26-AUG-16	1.710	ppb
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	26-AUG-16	0.956	ppb
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	26-AUG-16	9.450	ppb
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	26-AUG-16	0.844	ppb
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Initial	26-AUG-16	4.660	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-1-S-KIT-KS05	Kitchen South Wall near Coolers Middle Sink	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-W-KIT-KS08	Kitchen, middle island , facing west	Flush180	14-MAY-19	1.920	ug/L
51585	51585-1-W-KIT-KS08	Kitchen, middle island , facing west	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-KIT-KS08	Kitchen, middle island , facing west	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-KIT-KS08	Kitchen, middle island , facing west	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-KIT-KS08	Kitchen, middle island , facing west	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	26-AUG-16	63.700	ppb
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	26-AUG-16	120.000	ppb
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	26-AUG-16	49.300	ppb
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	26-AUG-16	47.100	ppb
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Initial	26-AUG-16	1010.000	ppb
51585	51585-1-S-HAL-F09	Outside Boys Restroom Area F Left Fountain	Initial	14-MAY-19	1.020	ug/L
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	26-AUG-16	102.000	ppb
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	26-AUG-16	92.800	ppb
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	26-AUG-16	55.400	ppb
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	26-AUG-16	35.200	ppb
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Initial	26-AUG-16	39.500	ppb
51585	51585-1-S-HAL-F10	Outside Boys Restroom Area F Right Fountain	Initial	14-MAY-19	4.130	ug/L
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	26-AUG-16	2.600	ppb
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	26-AUG-16	3.040	ppb
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	26-AUG-16	2.490	ppb
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	26-AUG-16	2.040	ppb
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Initial	26-AUG-16	2.040	ppb
51585	51585-1-E-HAL-F03	Outside Engineer Office Left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	26-AUG-16	2.650	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	26-AUG-16	2.330	ppb
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	26-AUG-16	2.200	ppb
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	26-AUG-16	2.650	ppb
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Initial	26-AUG-16	1.800	ppb
51585	51585-1-E-HAL-F04	Outside Engineers Office Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	26-AUG-16	0.842	ppb
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	26-AUG-16	0.718	ppb
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	26-AUG-16	0.638	ppb
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	26-AUG-16	0.734	ppb
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Initial	26-AUG-16	1.380	ppb
51585	51585-2-E-HAL-F01	Outside Room 118 Left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	26-AUG-16	0.689	ppb
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	26-AUG-16	0.955	ppb
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	26-AUG-16	1.400	ppb
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Flush180	26-AUG-16	2.080	ppb
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F02	Outside Room 118 Right Fountain	Initial	26-AUG-16	2.230	ppb
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	26-AUG-16	0.853	ppb
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	26-AUG-16	1.200	ppb
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	26-AUG-16	1.560	ppb
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Flush180	26-AUG-16	2.340	ppb
51585	51585-2-E-	Outside Room 122 Left Fountain	Initial	14-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03					
51585	51585-2-E-HAL-F03	Outside Room 122 Left Fountain	Initial	26-AUG-16	1.770	ppb
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	26-AUG-16	0.895	ppb
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	26-AUG-16	0.894	ppb
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	26-AUG-16	1.650	ppb
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Flush180	26-AUG-16	0.834	ppb
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-E-HAL-F04	Outside Room 122 Right Fountain	Initial	26-AUG-16	0.915	ppb
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	26-AUG-16	0.682	ppb
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	26-AUG-16	1.810	ppb
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	26-AUG-16	0.578	ppb
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	26-AUG-16	1.140	ppb
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Initial	26-AUG-16	1.760	ppb
51585	51585-2-W-HAL-F08	Outside Room 146 Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	26-AUG-16	0.876	ppb
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	26-AUG-16	1.550	ppb
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	26-AUG-16	0.955	ppb
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Flush180	26-AUG-16	0.855	ppb
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F06	Outside Room 147 Right Fountain	Initial	26-AUG-16	1.290	ppb
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	26-AUG-16	1.450	ppb
51585	51585-2-W-	Outside Room 148 Left Fountain	Flush180	26-AUG-16	0.846	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F05					
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	26-AUG-16	0.893	ppb
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Flush180	26-AUG-16	1.010	ppb
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-2-W-HAL-F05	Outside Room 148 Left Fountain	Initial	26-AUG-16	1.640	ppb
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	26-AUG-16	1.620	ppb
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	26-AUG-16	1.610	ppb
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	26-AUG-16	1.110	ppb
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	26-AUG-16	1.400	ppb
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Initial	26-AUG-16	1.100	ppb
51585	51585-1-W-HAL-F05	Outside Room 43 Left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	26-AUG-16	1.740	ppb
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	26-AUG-16	0.963	ppb
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	26-AUG-16	0.747	ppb
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	26-AUG-16	1.520	ppb
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Initial	26-AUG-16	1.390	ppb
51585	51585-1-W-HAL-F06	Outside Room 43 Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	26-AUG-16	1.430	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	26-AUG-16	2.200	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	26-AUG-16	2.400	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	20-MAR-17	1.000	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	26-AUG-16	1.010	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Initial	26-AUG-16	1.710	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Initial	26-AUG-16	1.000	ppb
51585	51585-1-W-HAL-F08	Outside Room 47 left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	26-AUG-16	1.500	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	26-AUG-16	2.050	ppb
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	26-AUG-16	2.450	ppb
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	26-AUG-16	1.880	ppb
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Initial	26-AUG-16	1.160	ppb
51585	51585-1-E-HAL-F01	Outside Room 66 Left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	26-AUG-16	2.260	ppb
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	26-AUG-16	2.630	ppb
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	26-AUG-16	1.980	ppb
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	26-AUG-16	0.996	ppb
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Initial	26-AUG-16	1.260	ppb
51585	51585-1-E-HAL-F02	Outside Room 66 Right Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	26-AUG-16	2.720	ppb
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	26-AUG-16	1.330	ppb
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	26-AUG-16	2.430	ppb
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	26-AUG-16	2.650	ppb
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Flush180	14-MAY-19	3.050	ug/L
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Initial	26-AUG-16	1.990	ppb
51585	51585-1-W-HAL-F07	Outside Room Room 47 left Fountain	Initial	14-MAY-19	1.000	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	26-AUG-16	8.980	ppb
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	26-AUG-16	10.100	ppb
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	26-AUG-16	11.600	ppb
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	26-AUG-16	13.500	ppb
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	14-MAY-19	4.090	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	14-MAY-19	4.910	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	14-MAY-19	5.460	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	14-MAY-19	5.400	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	07-MAY-20	2.210	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	07-MAY-20	1.030	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	07-MAY-20	1.000	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Flush180	07-MAY-20	1.180	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Initial	26-AUG-16	23.500	ppb
51585	51585-1-N-HAL-F11	Outside girls restroom	Initial	14-MAY-19	3.310	ug/L
51585	51585-1-N-HAL-F11	Outside girls restroom	Initial	07-MAY-20	3.680	ug/L
51585	51585-1-S-HAL-F12	Outside room. 26 stage	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F12	Outside room. 26 stage	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F12	Outside room. 26 stage	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F12	Outside room. 26 stage	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-S-HAL-F12	Outside room. 26 stage	Initial	14-MAY-19	1.070	ug/L
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	26-AUG-16	0.429	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	26-AUG-16	0.543	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	16-FEB-17	0.690	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	16-FEB-17	0.210	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	16-FEB-17	0.310	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	16-FEB-17	0.230	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	26-AUG-16	2.250	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	26-AUG-16	1.050	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	14-MAY-19	3.480	ug/L
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	14-MAY-19	1.140	ug/L
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Flush180	14-MAY-19	1.000	ug/L
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Initial	16-FEB-17	2.500	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Initial	26-AUG-16	16.000	ppb
51585	51585-1-W-POOL-F02	Pool Fountain near Boys Locker Room	Initial	14-MAY-19	3.870	ug/L
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	26-AUG-16	46.600	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	16-FEB-17	5.000	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	16-FEB-17	4.900	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	26-AUG-16	13.800	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	26-AUG-16	116.000	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	26-AUG-16	71.200	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	16-FEB-17	5.100	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	16-FEB-17	4.200	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	14-MAY-19	1.170	ug/L
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	14-MAY-19	1.390	ug/L
51585	51585-1-E-	Pool Fountain near Girls Locker	Flush180	14-MAY-19	1.350	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	POOL-F01	Room				
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Flush180	14-MAY-19	1.360	ug/L
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Initial	26-AUG-16	32.800	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Initial	16-FEB-17	3.900	ppb
51585	51585-1-E-POOL-F01	Pool Fountain near Girls Locker Room	Initial	14-MAY-19	1.260	ug/L