



**Sep 10, 2024**

**EARLE**

**2040 W 62ND ST, Chicago IL 60636.**

Dear **EARLE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**EARLE**

**2040 W 62ND ST, Chicago IL 60636.**

Estimadas familias de **EARLE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	6.560	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	9.170	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	32.400	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	30-SEP-20	16.100	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	18-NOV-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	18-NOV-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	18-NOV-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	18-NOV-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	30-SEP-20	2.820	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	27-OCT-20	1.040	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Flush180	27-OCT-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Initial	30-SEP-20	1.000	ug/L
51320	51320-1-HAL-F02	HALL	Initial	30-SEP-20	9.490	ug/L
51320	51320-1-GYM-F01	HALL	Initial	30-SEP-20	5.610	ug/L
51320	51320-1-GYM-F01	HALL	Initial	18-NOV-20	1.000	ug/L
51320	51320-1-GYM-F01	HALL	Initial	27-OCT-20	15.600	ug/L
51320	51320-1-HAL-F02	HALL	Initial	27-OCT-20	1.670	ug/L
51320	51320-2-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Bottle Filler	Flush180	03-FEB-22	1.500	ug/L
51320	51320-2-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Bottle Filler	Flush180	03-FEB-22	1.070	ug/L
51320	51320-2-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Bottle Filler	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Bottle Filler	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Bottle Filler	Initial	03-FEB-22	1.320	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	30-SEP-20	7.770	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	30-SEP-20	11.700	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	30-SEP-20	9.310	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	30-SEP-20	7.670	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	18-NOV-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	18-NOV-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	18-NOV-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	18-NOV-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	27-OCT-20	1.290	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	27-OCT-20	1.350	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	27-OCT-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	27-OCT-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Initial	30-SEP-20	6.600	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Initial	18-NOV-20	1.000	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Initial	27-OCT-20	7.460	ug/L
51320	51320-2-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, 2nd Flr Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, Bottle Filler	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, Bottle Filler	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, Bottle Filler	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-BF01	Main- Between Boy's & Girls 'B' Toliet Room, Bottle Filler	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-JUN-16	0.467	ppb
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-JUN-16	0.488	ppb
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-JUN-16	0.422	ppb
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-JUN-16	0.457	ppb
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Initial	03-JUN-16	0.643	ppb
51320	51320-1-HAL-F04	Main- Between Boy's & Girls 'B' Toliet Room, Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-JUN-16	0.375	ppb
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-JUN-16	1.400	ppb
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-JUN-16	0.470	ppb
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-JUN-16	0.743	ppb
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-FEB-22	1.690	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-FEB-22	1.260	ug/L
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-FEB-22	1.140	ug/L
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Initial	03-JUN-16	0.686	ppb
51320	51320-1-HAL-F05	Main- East Corridor Across from Room 113, Left Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F08	Main- East Corridor Across from Room 113, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F08	Main- East Corridor Across from Room 113, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F08	Main- East Corridor Across from Room 113, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F08	Main- East Corridor Across from Room 113, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F08	Main- East Corridor Across from Room 113, Right Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-JUN-16	0.697	ppb
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-JUN-16	1.470	ppb
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-JUN-16	1.450	ppb
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-JUN-16	1.090	ppb
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Initial	03-JUN-16	1.280	ppb
51320	51320-2-HAL-F02	Main- East Corridor Across from Room 213 2nd Fl, F	Initial	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	30-SEP-20	1.180	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	30-SEP-20	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	30-SEP-20	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	30-SEP-20	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Initial	30-SEP-20	1.640	ug/L
51320	51320-2-HAL-F01	Main- East Corridor Across from Room 213 2nd Fl, Right Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-JUN-16	0.349	ppb
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-JUN-16	0.345	ppb
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-JUN-16	0.367	ppb
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-JUN-16	0.342	ppb
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-	Main- Gym East Wall 1st Fl,	Flush180	03-FEB-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	GYM-F06	Fountain				
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Initial	03-JUN-16	1.000	ppb
51320	51320-1-GYM-F06	Main- Gym East Wall 1st Fl, Fountain	Initial	03-FEB-22	3.100	ug/L
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-JUN-16	0.617	ppb
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-JUN-16	0.531	ppb
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-JUN-16	0.557	ppb
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-JUN-16	0.473	ppb
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Initial	03-JUN-16	0.667	ppb
51320	51320-1-101-S11	Main- Inside Room 101 East Wall Pre-K, Sink	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-101-F01	Main- Inside Room 101 Pre-K, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-F01	Main- Inside Room 101 Pre-K, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-F01	Main- Inside Room 101 Pre-K, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-F01	Main- Inside Room 101 Pre-K, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-101-F01	Main- Inside Room 101 Pre-K, Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-JUN-16	3.890	ppb
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-JUN-16	2.370	ppb
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-JUN-16	2.300	ppb
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-JUN-16	6.960	ppb
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-FEB-22	2.180	ug/L
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-FEB-22	1.090	ug/L
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Flush180	03-FEB-22	1.070	ug/L
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Initial	03-JUN-16	7.390	ppb
51320	51320-1-103-S10	Main- Inside Room 103 North Wall Kindergarden, Sin	Initial	03-FEB-22	1.750	ug/L
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-JUN-16	0.389	ppb
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-JUN-16	0.439	ppb
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-JUN-16	0.420	ppb
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-JUN-16	0.354	ppb
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Initial	03-JUN-16	0.452	ppb
51320	51320-1-105-S09	Main- Inside Room 105 North Wall Pre-K, Sink	Initial	03-FEB-22	1.060	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S09	Pre-K, Sink				
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	03-FEB-22	2.400	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	03-FEB-22	1.200	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	03-FEB-22	1.150	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	11-AUG-22	1.920	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	11-AUG-22	1.120	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	11-AUG-22	1.050	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Flush180	11-AUG-22	1.000	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Initial	03-FEB-22	33.000	ug/L
51320	51320-1-109-F01	Main- Inside Room 109 Kindergarden, Fountain	Initial	11-AUG-22	4.550	ug/L
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-JUN-16	0.571	ppb
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-JUN-16	1.990	ppb
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-JUN-16	0.754	ppb
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-JUN-16	1.060	ppb
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-FEB-22	1.470	ug/L
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Initial	03-JUN-16	1.280	ppb
51320	51320-1-109-S08	Main- Inside Room 109 South Wall Kindergarden, Sin	Initial	03-FEB-22	3.200	ug/L
51320	51320-1-KIT-KS01	Main- Kitchen East Wall 1st Fl, Sink	Flush180	03-JUN-16	0.377	ppb
51320	51320-1-KIT-KS01	Main- Kitchen East Wall 1st Fl, Sink	Flush180	03-JUN-16	0.508	ppb
51320	51320-1-KIT-KS01	Main- Kitchen East Wall 1st Fl, Sink	Flush180	03-JUN-16	0.464	ppb
51320	51320-1-KIT-KS01	Main- Kitchen East Wall 1st Fl, Sink	Flush180	03-JUN-16	0.328	ppb
51320	51320-1-KIT-KS01	Main- Kitchen East Wall 1st Fl, Sink	Initial	03-JUN-16	0.515	ppb
51320	51320-1-CAF-BF01	Main- Lunch Room North Wall 1st Fl, Bottle Filler (Right)	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-BF01	Main- Lunch Room North Wall 1st Fl, Bottle Filler (Right)	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-BF01	Main- Lunch Room North Wall 1st Fl, Bottle Filler (Right)	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-BF01	Main- Lunch Room North Wall 1st Fl, Bottle Filler (Right)	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-BF01	Main- Lunch Room North Wall 1st Fl, Bottle Filler (Right)	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-F03	Main- Lunch Room North Wall 1st Fl, Left Fountain	Flush180	03-JUN-16	0.394	ppb
51320	51320-1-CAF-F03	Main- Lunch Room North Wall 1st Fl, Left Fountain	Flush180	03-JUN-16	0.593	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51320	51320-1-CAF-F03	Main- Lunch Room North Wall 1st Fl, Left Fountain	Flush180	03-JUN-16	0.644	ppb
51320	51320-1-CAF-F03	Main- Lunch Room North Wall 1st Fl, Left Fountain	Flush180	03-JUN-16	0.489	ppb
51320	51320-1-CAF-F03	Main- Lunch Room North Wall 1st Fl, Left Fountain	Initial	03-JUN-16	0.354	ppb
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-JUN-16	0.361	ppb
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-JUN-16	0.158	ppb
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-JUN-16	0.264	ppb
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-JUN-16	0.326	ppb
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Flush180	03-FEB-22	1.000	ug/L
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Initial	03-JUN-16	1.000	ppb
51320	51320-1-CAF-F02	Main- Lunch Room North Wall 1st Fl, Right Fountain	Initial	03-FEB-22	1.000	ug/L
51320	51320-1-HAL-F01	Main- North Corridor Across from Upper Gym 2nd Fl,	Flush180	03-JUN-16	0.523	ppb
51320	51320-1-HAL-F01	Main- North Corridor Across from Upper Gym 2nd Fl,	Flush180	03-JUN-16	0.538	ppb
51320	51320-1-HAL-F01	Main- North Corridor Across from Upper Gym 2nd Fl,	Flush180	03-JUN-16	0.540	ppb
51320	51320-1-HAL-F01	Main- North Corridor Across from Upper Gym 2nd Fl,	Flush180	03-JUN-16	0.523	ppb
51320	51320-1-HAL-F01	Main- North Corridor Across from Upper Gym 2nd Fl,	Initial	03-JUN-16	0.308	ppb
51320	51320-1-HAL-F07	Main- South Corridor Across from Room 136, Fountai	Flush180	03-JUN-16	0.478	ppb
51320	51320-1-HAL-F07	Main- South Corridor Across from Room 136, Fountai	Flush180	03-JUN-16	0.393	ppb
51320	51320-1-HAL-F07	Main- South Corridor Across from Room 136, Fountai	Flush180	03-JUN-16	0.311	ppb
51320	51320-1-HAL-F07	Main- South Corridor Across from Room 136, Fountai	Flush180	03-JUN-16	0.519	ppb
51320	51320-1-HAL-F07	Main- South Corridor Across from Room 136, Fountai	Initial	03-JUN-16	0.232	ppb
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	03-JUN-16	1.540	ppb
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	03-JUN-16	1.840	ppb
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	03-JUN-16	2.790	ppb
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	03-JUN-16	1.600	ppb
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	30-SEP-20	65.500	ug/L
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	27-OCT-20	1.000	ug/L
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	27-OCT-20	1.000	ug/L
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Flush180	27-OCT-20	1.000	ug/L
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Initial	03-JUN-16	9.790	ppb
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Initial	27-OCT-20	3.840	ug/L
51320	51320-2-HAL-F03	Main- South Corridor Outside Boys Toilet 2nd Fl, F	Initial	30-SEP-20	101.000	ug/L
51320	51320-2-HAL-RBF01	Main- South Corridor Outside Girl's & Boy's 'A' Toilet 2nd Fl, RBF	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-	Main- South Corridor Outside	Flush180	03-FEB-22	1.000	ug/L



**Water Quality Assessment  
Charles W Earle Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01	Girl's & Boy's 'A' Toilet 2nd Fl, RBF				
51320	51320-2-HAL-RBF01	Main- South Corridor Outside Girl's & Boy's 'A' Toilet 2nd Fl, RBF	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-RBF01	Main- South Corridor Outside Girl's & Boy's 'A' Toilet 2nd Fl, RBF	Flush180	03-FEB-22	1.000	ug/L
51320	51320-2-HAL-RBF01	Main- South Corridor Outside Girl's & Boy's 'A' Toilet 2nd Fl, RBF	Initial	03-FEB-22	1.000	ug/L