



Sep 10, 2024

EDWARDS

4815 S KARLOV AVE, Chicago IL 60632.

Dear **EDWARDS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

EDWARDS

4815 S KARLOV AVE, Chicago IL 60632.

Estimadas familias de **EDWARDS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anejo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-16	0.869	ppb
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-16	0.998	ppb
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-16	1.130	ppb
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-16	1.360	ppb
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-23	3.070	ug/L
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-23	4.120	ug/L
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-23	4.830	ug/L
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Flush180	26-MAY-23	4.390	ug/L
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Initial	26-MAY-16	0.992	ppb
51294	51294-1-HAL-F02	Across from Room 104, Fountain 1	Initial	26-MAY-23	3.530	ug/L
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-16	1.020	ppb
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-16	1.120	ppb
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-16	1.060	ppb
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-23	4.270	ug/L
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-23	3.630	ug/L
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-23	3.240	ug/L
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Flush180	26-MAY-23	2.930	ug/L
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Initial	26-MAY-16	1.090	ppb
51294	51294-1-HAL-F03	Across from Room 104, Fountain 2	Initial	26-MAY-23	4.440	ug/L
51294	51294-1-HAL-F08	Across from Stair C and Elevator	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F08	Across from Stair C and Elevator	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F08	Across from Stair C and Elevator	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F08	Across from Stair C and Elevator	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F09	Across from Stair C and Elevator, Middle	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F09	Across from Stair C and Elevator, Middle	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F09	Across from Stair C and Elevator, Middle	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F09	Across from Stair C and Elevator, Middle	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F09	Across from Stair C and Elevator, Middle	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F10	Across from Stair C and Elevator, Right	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F10	Across from Stair C and Elevator, Right	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F10	Across from Stair C and Elevator, Right	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F10	Across from Stair C and Elevator, Right	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F10	Across from Stair C and Elevator, Right	Initial	26-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51294	51294-B-BH-F01	Boiler House, Fountain	Flush180	26-MAY-16	1.470	ppb
51294	51294-B-BH-F01	Boiler House, Fountain	Flush180	26-MAY-16	1.660	ppb
51294	51294-B-BH-F01	Boiler House, Fountain	Flush180	26-MAY-16	1.430	ppb
51294	51294-B-BH-F01	Boiler House, Fountain	Flush180	26-MAY-16	1.470	ppb
51294	51294-B-BH-F01	Boiler House, Fountain	Initial	26-MAY-16	2.090	ppb
51294	51294-1-MOD1-F02	East Modular (1) - Outside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F02	East Modular (1) - Outside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F02	East Modular (1) - Outside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F02	East Modular (1) - Outside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F02	East Modular (1) - Outside Room 502, Fountain 1	Initial	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F01	East Modular (1)- Inside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F01	East Modular (1)- Inside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F01	East Modular (1)- Inside Room 502, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD1-F01	East Modular (1)- Inside Room 502, Fountain 1	Initial	26-MAY-16	1.000	ppb
51294	51294-1-KIT-KS01	Main Building Kitchen, Sink	Flush180	26-MAY-16	0.307	ppb
51294	51294-1-KIT-KS01	Main Building Kitchen, Sink	Flush180	26-MAY-16	0.542	ppb
51294	51294-1-KIT-KS01	Main Building Kitchen, Sink	Flush180	26-MAY-16	0.458	ppb
51294	51294-1-KIT-KS01	Main Building Kitchen, Sink	Flush180	26-MAY-16	0.473	ppb
51294	51294-1-KIT-KS01	Main Building Kitchen, Sink	Initial	26-MAY-16	0.554	ppb
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-16	0.444	ppb
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-16	0.445	ppb
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-16	0.467	ppb
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-16	0.463	ppb
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Flush180	30-JUL-20	1.490	ug/L
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Initial	26-MAY-16	0.683	ppb
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F05	Outside Office, Fountain 2	Initial	30-JUL-20	1.000	ug/L
51294	51294-1-HAL-RBF01	Outside Office, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-RBF01	Outside Office, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-RBF01	Outside Office, Fountain 3	Flush180	26-MAY-23	1.260	ug/L
51294	51294-1-HAL-RBF01	Outside Office, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-RBF01	Outside Office, Fountain 3	Initial	26-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-16	0.934	ppb
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-16	1.030	ppb
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-16	0.790	ppb
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-16	1.350	ppb
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Initial	26-MAY-16	0.835	ppb
51294	51294-1-HAL-F06	Outside Room 113, Fountain 1	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-16	1.160	ppb
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-16	1.550	ppb
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-16	1.330	ppb
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Flush180	26-MAY-16	1.250	ppb
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F07	Outside Room 113, Fountain 2	Initial	26-MAY-16	1.120	ppb
51294	51294-1-HAL-F11	Outside Room 113, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F11	Outside Room 113, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F11	Outside Room 113, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F11	Outside Room 113, Fountain 3	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-16	1.020	ppb
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-16	0.979	ppb
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-16	0.995	ppb
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Flush180	26-MAY-16	1.060	ppb
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F01	Outside Room 203, Fountain 1	Initial	26-MAY-16	0.898	ppb
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-16	0.756	ppb
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-16	0.869	ppb
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-16	0.842	ppb
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	26-MAY-16	0.801	ppb
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Flush180	30-JUL-20	1.000	ug/L
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Initial	26-MAY-16	0.991	ppb
51294	51294-2-HAL-F02	Outside Room 203, Fountain 2	Initial	30-JUL-20	1.000	ug/L
51294	51294-2-HAL-F08	Outside Room 203, Fountain 3, Left	Flush180	26-MAY-23	1.050	ug/L
51294	51294-2-HAL-F08	Outside Room 203, Fountain 3, Left	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F08	Outside Room 203, Fountain 3, Left	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F08	Outside Room 203, Fountain 3, Left	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F08	Outside Room 203, Fountain 3, Left	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-16	0.714	ppb
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-16	0.728	ppb
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-16	0.704	ppb
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Flush180	26-MAY-16	0.745	ppb
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F03	Outside Room 207, Fountain 1	Initial	26-MAY-16	0.978	ppb
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-16	0.378	ppb
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-16	0.390	ppb
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-16	0.563	ppb
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Flush180	26-MAY-16	0.482	ppb
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F04	Outside Room 207, Fountain 2	Initial	26-MAY-16	0.616	ppb
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-	Outside Room 213, Fountain 2	Flush180	26-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06					
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-16	1.650	ppb
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-16	1.670	ppb
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-16	1.110	ppb
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Flush180	26-MAY-16	2.080	ppb
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F06	Outside Room 213, Fountain 2	Initial	26-MAY-16	3.190	ppb
51294	51294-2-HAL-F07	Outside Room 213, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F07	Outside Room 213, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F07	Outside Room 213, Fountain 3	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F07	Outside Room 213, Fountain 3	Flush180	26-MAY-23	1.270	ug/L
51294	51294-2-HAL-F07	Outside Room 213, Fountain 3	Initial	26-MAY-23	1.050	ug/L
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-16	0.354	ppb
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-16	0.452	ppb
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-16	0.431	ppb
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-16	0.323	ppb
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F04	Outside office, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-HAL-F04	Outside office, Fountain 1	Initial	26-MAY-16	0.689	ppb
51294	51294-1-HAL-F04	Outside office, Fountain 1	Initial	26-MAY-23	6.890	ug/L
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-16	2.090	ppb
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-16	2.900	ppb
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-16	1.990	ppb
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Flush180	26-MAY-16	2.020	ppb
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Initial	26-MAY-23	1.000	ug/L
51294	51294-2-HAL-F05	Outside room 213, Fountain 1	Initial	26-MAY-16	2.880	ppb
51294	51294-1-MOD2-F01	West Modular (2)- Outside Room 404, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F01	West Modular (2)- Outside Room 404, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F01	West Modular (2)- Outside Room 404, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F01	West Modular (2)- Outside Room 404, Fountain 1	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F01	West Modular (2)- Outside Room 404, Fountain 1	Initial	26-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51294	51294-1-MOD2-F02	West Modular (2)- Outside Room 404, Fountain 2	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F02	West Modular (2)- Outside Room 404, Fountain 2	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F02	West Modular (2)- Outside Room 404, Fountain 2	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F02	West Modular (2)- Outside Room 404, Fountain 2	Flush180	26-MAY-16	1.000	ppb
51294	51294-1-MOD2-F02	West Modular (2)- Outside Room 404, Fountain 2	Initial	26-MAY-16	1.000	ppb
51294	51294-1-CAF-BF01	addition, cafeteria bottle filler	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-BF01	addition, cafeteria bottle filler	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-BF01	addition, cafeteria bottle filler	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-BF01	addition, cafeteria bottle filler	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-F01	addition, cafeteria drinking fountain	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-F01	addition, cafeteria drinking fountain	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-F01	addition, cafeteria drinking fountain	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-F01	addition, cafeteria drinking fountain	Flush180	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-F01	addition, cafeteria drinking fountain	Initial	26-MAY-23	1.000	ug/L
51294	51294-1-CAF-F01	addition, cafeteria drinking fountain	Initial	30-JUL-20	1.000	ug/L
51294	51294-3-HAL-F02	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F02	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F02	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F02	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F03	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F03	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F03	addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F02	addition, 3rd floor hallway fountain by bathroom and elevators	Initial	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F03	addition, 3rd floor hallway fountain by bathroom and elevators	Initial	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Flush180	30-JUL-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Initial	26-MAY-23	1.000	ug/L
51294	51294-3-HAL-F01	addition, 3rd floor hallway fountain by bathroom and elevators addition, 3rd floor hallway fountain by bathroom and elevators	Initial	30-JUL-20	1.000	ug/L
51316	51316-1-HAL-F03	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F03	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F03	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F03	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F04	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F04	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F04	Corridor Outside Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F04	Corridor Outside Room 609	Flush180	30-JUL-20	1.010	ug/L
51316	51316-1-HAL-F03	Corridor Outside Room 609	Initial	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F04	Corridor Outside Room 609	Initial	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F04	Corridor Outside Room 609	Initial	30-JUL-20	1.300	ug/L
51316	51316-1-HAL-F01	Corridor Outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F01	Corridor Outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F01	Corridor Outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F01	Corridor Outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F01	Corridor Outside Teacher's Lounge	Initial	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F02	Corridor outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F02	Corridor outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F02	Corridor outside Teacher's Lounge	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F02	Corridor outside Teacher's Lounge	Flush180	30-JUL-20	3.360	ug/L
51316	51316-1-HAL-F02	Corridor outside Teacher's Lounge	Initial	21-JUN-16	1.000	ppb
51316	51316-1-HAL-F02	Corridor outside Teacher's Lounge	Initial	30-JUL-20	3.040	ug/L
51316	51316-1-601-S01	Room 601	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-601-S01	Room 601	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-601-S01	Room 601	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-601-S01	Room 601	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-601-S01	Room 601	Initial	21-JUN-16	5.930	ppb
51316	51316-1-603-S01	Room 603	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-603-S01	Room 603	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-603-S01	Room 603	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-603-S01	Room 603	Initial	21-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51316	51316-1-604-S01	Room 604	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-604-S01	Room 604	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-604-S01	Room 604	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-604-S01	Room 604	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-604-S01	Room 604	Initial	21-JUN-16	1.000	ppb
51316	51316-1-605-S01	Room 605	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-605-S01	Room 605	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-605-S01	Room 605	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-605-S01	Room 605	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-605-S01	Room 605	Initial	21-JUN-16	1.000	ppb
51316	51316-1-606-S01	Room 606	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-606-S01	Room 606	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-606-S01	Room 606	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-606-S01	Room 606	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-606-S01	Room 606	Initial	21-JUN-16	1.000	ppb
51316	51316-1-607-S01	Room 607	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-607-S01	Room 607	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-607-S01	Room 607	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-607-S01	Room 607	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-607-S01	Room 607	Initial	21-JUN-16	1.000	ppb
51316	51316-1-608-S01	Room 608	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-608-S01	Room 608	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-608-S01	Room 608	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-608-S01	Room 608	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-608-S01	Room 608	Initial	21-JUN-16	1.000	ppb
51316	51316-1-609-S01	Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-609-S01	Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-609-S01	Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-609-S01	Room 609	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-609-S01	Room 609	Initial	21-JUN-16	1.000	ppb
51316	51316-1-FS-S01	Sink in Food Storage Room	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-FS-S01	Sink in Food Storage Room	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-FS-S01	Sink in Food Storage Room	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-FS-S01	Sink in Food Storage Room	Flush180	21-JUN-16	1.000	ppb
51316	51316-1-FS-S01	Sink in Food Storage Room	Initial	21-JUN-16	1.000	ppb
52440	52440-1-HAL-F01	Annex- Next to Mechanical room, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52440	52440-1-HAL-	Annex- Next to Mechanical room,	Flush180	26-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain 1				
52440	52440-1-HAL-F01	Annex- Next to Mechanical room, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F01	Annex- Next to Mechanical room, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F01	Annex- Next to Mechanical room, Fountain 1	Initial	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Flush180	26-MAY-16	0.120	ppb
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Flush180	30-JUL-20	1.000	ug/L
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Initial	26-MAY-16	1.000	ppb
52440	52440-1-HAL-F02	Annex- Next to Mechanical room, Fountain 2	Initial	30-JUL-20	1.000	ug/L