



Sep 10, 2024

ESMOND

1865 W MONTVALE AVE, Chicago IL 60643.

Dear **ESMOND** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

ESMOND

1865 W MONTVALE AVE, Chicago IL 60643.

Estimadas familias de **ESMOND**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51431	51431-1-HAL-F04	Across from 107 and 108, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F04	Across from 107 and 108, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F04	Across from 107 and 108, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F04	Across from 107 and 108, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F04	Across from 107 and 108, Fountain	Initial	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Initial	05-JAN-19	1.000	ppb
51431	51431-1-HAL-RBF01	Addition - 1st Floor Hallway Center Retrofit Bottle Filler	Initial	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Initial	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F18	Addition - 1st Floor Hallway Left Fountain	Initial	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	25-AUG-20	1.000	ug/L
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-F20	Addition - 1st Floor Hallway Right Fountain	Initial	05-JAN-19	2.260	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51431	51431-1-CAF-F16	Addition-1st Floor Cafeteria Center Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F16	Addition-1st Floor Cafeteria Center Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F16	Addition-1st Floor Cafeteria Center Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F16	Addition-1st Floor Cafeteria Center Fountain	Initial	05-JAN-19	2.310	ppb
51431	51431-1-CAF-F16	Addition-1st Floor Cafeteria Center Fountain	Initial	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Initial	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F15	Addition-1st Floor Cafeteria Left Fountain	Initial	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Initial	05-JAN-19	2.540	ppb
51431	51431-1-CAF-F17	Addition-1st Floor Cafeteria Right Fountain	Initial	04-MAY-23	1.000	ug/L
51431	51431-1-KIT-KS13	Addition-1st Floor Hybrid Kitchen Left sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS13	Addition-1st Floor Hybrid Kitchen Left sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS13	Addition-1st Floor Hybrid Kitchen Left sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS13	Addition-1st Floor Hybrid Kitchen Left sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS13	Addition-1st Floor Hybrid Kitchen Left sink	Initial	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS14	Addition-1st Floor Hybrid Kitchen Right sink	Flush180	05-JAN-19	4.100	ppb
51431	51431-1-KIT-KS14	Addition-1st Floor Hybrid Kitchen Right sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS14	Addition-1st Floor Hybrid Kitchen Right sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS14	Addition-1st Floor Hybrid Kitchen Right sink	Flush180	05-JAN-19	1.000	ppb
51431	51431-1-KIT-KS14	Addition-1st Floor Hybrid Kitchen Right sink	Initial	05-JAN-19	1.000	ppb
51431	51431-1-114-S04	Inside Kindergarten Room 114, Sink	Flush180	04-MAY-23	23.600	ug/L
51431	51431-1-114-S04	Inside Kindergarten Room 114, Sink	Flush180	04-MAY-23	39.300	ug/L
51431	51431-1-114-	Inside Kindergarten Room 114,	Flush180	04-MAY-23	3.980	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S04	Sink				
51431	51431-1-114-S04	Inside Kindergarten Room 114, Sink	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-114-S04	Inside Kindergarten Room 114, Sink	Initial	04-MAY-23	4.320	ug/L
51431	51431-1-114-S05	Inside Kindergarten Room 114, Sink Right	Flush180	04-MAY-23	4.730	ug/L
51431	51431-1-114-S05	Inside Kindergarten Room 114, Sink Right	Flush180	04-MAY-23	5.990	ug/L
51431	51431-1-114-S05	Inside Kindergarten Room 114, Sink Right	Flush180	04-MAY-23	6.560	ug/L
51431	51431-1-114-S05	Inside Kindergarten Room 114, Sink Right	Flush180	04-MAY-23	8.060	ug/L
51431	51431-1-114-S05	Inside Kindergarten Room 114, Sink Right	Initial	04-MAY-23	4.580	ug/L
51431	51431-2-HAL-F02	Main, 2nd floor, Across from Room 203 West, Founta	Flush180	25-AUG-20	3.170	ug/L
51431	51431-2-HAL-F02	Main, 2nd floor, Across from Room 203 West, Founta	Initial	25-AUG-20	3.440	ug/L
51431	51431-2-HAL-RBF01	Main, 2nd floor, Across from Room 203 West, Retrofitted Bottle Filler	Flush180	04-MAY-23	1.240	ug/L
51431	51431-2-HAL-RBF01	Main, 2nd floor, Across from Room 203 West, Retrofitted Bottle Filler	Flush180	04-MAY-23	1.060	ug/L
51431	51431-2-HAL-RBF01	Main, 2nd floor, Across from Room 203 West, Retrofitted Bottle Filler	Flush180	04-MAY-23	1.650	ug/L
51431	51431-2-HAL-RBF01	Main, 2nd floor, Across from Room 203 West, Retrofitted Bottle Filler	Flush180	04-MAY-23	1.600	ug/L
51431	51431-2-HAL-RBF01	Main, 2nd floor, Across from Room 203 West, Retrofitted Bottle Filler	Initial	04-MAY-23	12.400	ug/L
51431	51431-B-CAF-S02	Main, Basement, Lunchroom Sink	Flush180	04-MAY-23	3.130	ug/L
51431	51431-B-CAF-S02	Main, Basement, Lunchroom Sink	Flush180	04-MAY-23	3.340	ug/L
51431	51431-B-CAF-S02	Main, Basement, Lunchroom Sink	Flush180	04-MAY-23	1.200	ug/L
51431	51431-B-CAF-S02	Main, Basement, Lunchroom Sink	Flush180	04-MAY-23	4.580	ug/L
51431	51431-B-CAF-S02	Main, Basement, Lunchroom Sink	Initial	04-MAY-23	4.120	ug/L
51431	51431-1-HAL-RBF02	Main- 1st flr corridor, Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF02	Main- 1st flr corridor, Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF02	Main- 1st flr corridor, Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF02	Main- 1st flr corridor, Retrofit Bottle Filler	Flush180	04-MAY-23	1.000	ug/L
51431	51431-1-HAL-RBF02	Main- 1st flr corridor, Retrofit Bottle Filler	Initial	04-MAY-23	1.260	ug/L
51431	51431-2-HAL-F04	Main- 2nd flr corridor, Outside Room 201, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-2-HAL-F04	Main- 2nd flr corridor, Outside Room 201, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-2-HAL-F04	Main- 2nd flr corridor, Outside Room 201, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-2-HAL-F04	Main- 2nd flr corridor, Outside Room 201, Fountain	Flush180	04-MAY-23	1.000	ug/L
51431	51431-2-HAL-F04	Main- 2nd flr corridor, Outside Room 201, Fountain	Initial	04-MAY-23	1.000	ug/L