



Sep 10, 2024

EVERETT

3419 S BELL AVE, Chicago IL 60608.

Dear **EVERETT** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

EVERETT

3419 S BELL AVE, Chicago IL 60608.

Estimadas familias de **EVERETT**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51267	51267-1-102-S01		Flush180	06-AUG-20	4.080	ug/L
51267	51267-1-102-S01		Flush180	06-AUG-20	1.170	ug/L
51267	51267-1-102-S01		Flush180	06-AUG-20	1.000	ug/L
51267	51267-1-102-S01		Flush180	06-AUG-20	1.000	ug/L
51267	51267-1-102-S01		Initial	06-AUG-20	3.040	ug/L
51267	51267-1-HAL-F07	1st Floor, Outside Restroom, Center Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F07	1st Floor, Outside Restroom, Center Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F07	1st Floor, Outside Restroom, Center Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F07	1st Floor, Outside Restroom, Center Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F07	1st Floor, Outside Restroom, Center Fountain	Initial	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F06	1st Floor, Outside Restroom, Left Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F06	1st Floor, Outside Restroom, Left Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F06	1st Floor, Outside Restroom, Left Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F06	1st Floor, Outside Restroom, Left Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F06	1st Floor, Outside Restroom, Left Fountain	Initial	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F08	1st Floor, Outside Restroom, Right Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F08	1st Floor, Outside Restroom, Right Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F08	1st Floor, Outside Restroom, Right Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F08	1st Floor, Outside Restroom, Right Fountain	Flush180	19-OCT-21	1.000	ug/L
51267	51267-1-HAL-F08	1st Floor, Outside Restroom, Right Fountain	Initial	19-OCT-21	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	09-JUN-16	0.359	ppb
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	09-JUN-16	0.816	ppb
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	09-JUN-16	0.711	ppb
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	09-JUN-16	0.498	ppb
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	28-JUL-20	2.930	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	04-OCT-19	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	04-OCT-19	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	04-OCT-19	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	04-OCT-19	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	06-OCT-20	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	06-OCT-20	1.370	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	06-OCT-20	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Flush180	06-OCT-20	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Initial	09-JUN-16	0.527	ppb
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Initial	28-JUL-20	6.890	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Initial	04-OCT-19	1.000	ug/L
51267	51267-2-HAL-F01	Main- Between The Bathrooms, Fountain	Initial	06-OCT-20	1.000	ug/L
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	29-JUN-16	4.510	ppb
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	29-JUN-16	4.740	ppb
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	29-JUN-16	4.590	ppb
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	29-JUN-16	4.350	ppb
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	04-OCT-19	4.280	ug/L
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	04-OCT-19	4.650	ug/L
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	04-OCT-19	4.270	ug/L
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Flush180	04-OCT-19	4.350	ug/L
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Initial	29-JUN-16	3.210	ppb
51267	51267-B-BPR-F01	Main- Boys Playroom, North Fountain 1	Initial	04-OCT-19	3.960	ug/L
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	29-JUN-16	4.340	ppb
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	29-JUN-16	3.860	ppb
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	29-JUN-16	3.160	ppb
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	29-JUN-16	5.850	ppb
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	04-OCT-19	4.110	ug/L
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	04-OCT-19	4.680	ug/L
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	04-OCT-19	4.920	ug/L
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Flush180	04-OCT-19	4.830	ug/L
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Initial	29-JUN-16	7.560	ppb
51267	51267-B-BPR-F02	Main- Boys Playroom, South Fountain 2	Initial	04-OCT-19	3.870	ug/L
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	29-JUN-16	13.800	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	29-JUN-16	28.700	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	29-JUN-16	7.690	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	21-JUL-16	2.500	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	21-JUL-16	2.100	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	21-JUL-16	2.500	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	29-JUN-16	15.400	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	21-JUL-16	1.000	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Initial	29-JUN-16	86.400	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Initial	21-JUL-16	6.300	ppb
51267	51267-B-GPR-F01	Main- Girls Playroom, North Fountain 1	Initial	04-OCT-19	2.040	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	29-JUN-16	34.100	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	29-JUN-16	12.500	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	29-JUN-16	18.300	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	29-JUN-16	24.100	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	21-JUL-16	5.500	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	21-JUL-16	3.300	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	21-JUL-16	4.200	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	21-JUL-16	1.000	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	04-OCT-19	2.000	ug/L
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Flush180	04-OCT-19	1.100	ug/L
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Initial	29-JUN-16	73.500	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Initial	21-JUL-16	12.000	ppb
51267	51267-B-GPR-F02	Main- Girls Playroom, South Fountain 2	Initial	04-OCT-19	3.100	ug/L
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	09-JUN-16	1.200	ppb
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	09-JUN-16	0.998	ppb
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	09-JUN-16	1.140	ppb
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	09-JUN-16	1.170	ppb
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	04-OCT-19	1.910	ug/L
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	04-OCT-19	1.980	ug/L
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	04-OCT-19	1.930	ug/L
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Flush180	04-OCT-19	1.630	ug/L
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Initial	09-JUN-16	0.921	ppb
51267	51267-1-GYM-F01	Main- Inside Gym, Fountain	Initial	04-OCT-19	1.470	ug/L
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	09-JUN-16	0.807	ppb
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	09-JUN-16	0.764	ppb
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	09-JUN-16	1.010	ppb
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	09-JUN-16	1.000	ppb
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Initial	09-JUN-16	0.648	ppb
51267	51267-1-KIT-KS02	Main- Kitchen, East Sink 2	Initial	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	09-JUN-16	1.860	ppb
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	09-JUN-16	1.630	ppb
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	09-JUN-16	1.270	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01					
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	09-JUN-16	1.010	ppb
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	04-OCT-19	1.670	ug/L
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Initial	09-JUN-16	1.900	ppb
51267	51267-1-KIT-KS01	Main- Kitchen, North Sink 1	Initial	04-OCT-19	1.640	ug/L
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	09-JUN-16	0.907	ppb
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	09-JUN-16	1.220	ppb
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	09-JUN-16	1.250	ppb
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	09-JUN-16	0.626	ppb
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	04-OCT-19	1.660	ug/L
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Initial	09-JUN-16	4.780	ppb
51267	51267-1-CAF-S03	Main- Lunchroom, East Sink 1	Initial	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	09-JUN-16	0.398	ppb
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	09-JUN-16	0.372	ppb
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	09-JUN-16	0.370	ppb
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	09-JUN-16	0.567	ppb
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Initial	09-JUN-16	1.010	ppb
51267	51267-1-CAF-S04	Main- Lunchroom, West Sink 2	Initial	04-OCT-19	1.720	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	09-JUN-16	0.441	ppb
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	09-JUN-16	0.310	ppb
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	09-JUN-16	0.316	ppb
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	09-JUN-16	0.355	ppb
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	28-JUL-20	41.300	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	04-OCT-19	1.070	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	04-OCT-19	1.050	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	04-OCT-19	1.000	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	06-OCT-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Fountain				
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	06-OCT-20	1.000	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	06-OCT-20	1.000	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Flush180	06-OCT-20	1.000	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Initial	09-JUN-16	0.570	ppb
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Initial	28-JUL-20	15.200	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Initial	04-OCT-19	1.300	ug/L
51267	51267-1-HAL-F05	Main- Outside Teachers Lounge, Fountain	Initial	06-OCT-20	1.000	ug/L
51267	51267-1-101-S01	Sink in Room 101	Flush180	06-AUG-20	1.000	ug/L
51267	51267-1-101-S01	Sink in Room 101	Flush180	06-AUG-20	1.000	ug/L
51267	51267-1-101-S01	Sink in Room 101	Flush180	06-AUG-20	1.000	ug/L
51267	51267-1-101-S01	Sink in Room 101	Flush180	06-AUG-20	1.000	ug/L
51267	51267-1-101-S01	Sink in Room 101	Initial	06-AUG-20	1.000	ug/L
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Initial	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F01	Modular- East, Fountain 1	Initial	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	29-JUN-16	0.944	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	09-JUN-16	0.944	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	09-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Flush180	29-JUN-16	1.000	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Initial	29-JUN-16	0.123	ppb
53799	53799-1-HAL-F02	Modular- West, Fountain 2	Initial	09-JUN-16	0.123	ppb