



Sep 10, 2024

FALCONER

3020 N LAMON AVE, Chicago IL 60641.

Dear **FALCONER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

FALCONER

3020 N LAMON AVE, Chicago IL 60641.

Estimadas familias de **FALCONER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F05	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F05	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F05	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F05	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F06	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F06	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F06	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F06	2nd FL Hallway between Room 201 & 202	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.280	ug/L
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.580	ug/L
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.210	ug/L
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.280	ug/L
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	2.150	ug/L
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.800	ug/L
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	3.330	ug/L
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	2.640	ug/L
51011	51011-2-HAL-F03	2nd FL Hallway between Room 201 & 202	Initial	31-MAY-22	1.710	ug/L
51011	51011-2-HAL-F04	2nd FL Hallway between Room 201 & 202	Initial	31-MAY-22	2.290	ug/L
51011	51011-2-HAL-RBF02	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.070	ug/L
51011	51011-2-HAL-RBF02	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.270	ug/L
51011	51011-2-HAL-RBF02	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	2.000	ug/L
51011	51011-2-HAL-RBF02	2nd FL Hallway between Room 201 & 202	Flush180	31-MAY-22	1.150	ug/L
51011	51011-2-HAL-RBF02	2nd FL Hallway between Room 201 & 202	Initial	31-MAY-22	1.540	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F04	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F04	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F04	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F04	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	31-MAY-22	1.500	ug/L
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	31-MAY-22	1.400	ug/L
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	31-MAY-22	2.640	ug/L
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	31-MAY-22	2.020	ug/L
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	31-MAY-22	3.330	ug/L
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	31-MAY-22	1.910	ug/L
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	31-MAY-22	1.970	ug/L
51011	51011-3-HAL-F08	Between Room 301 & 302	Flush180	31-MAY-22	2.980	ug/L
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F03	Between Room 301 & 302	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F03	Between Room 301 & 302	Initial	31-MAY-22	2.730	ug/L
51011	51011-3-HAL-F08	Between Room 301 & 302	Initial	31-MAY-22	1.460	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	06-JUL-22	2.220	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	06-JUL-22	2.220	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	06-JUL-22	2.500	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	06-JUL-22	2.280	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	31-MAY-22	5.950	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	31-MAY-22	5.320	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	31-MAY-22	1.000	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Flush180	31-MAY-22	6.110	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Initial	06-JUL-22	2.210	ug/L
51011	51011-3-HAL-RBF03	Between Room 301 & 302	Initial	31-MAY-22	4.050	ug/L
51011	51011-3-HAL-F10	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F09	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F09	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F09	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09					
51011	51011-3-HAL-F09	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F10	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F10	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F10	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F10	Between Room 306 & 307	Flush180	07-JUN-16	1.000	ppb
51011	51011-3-HAL-F09	Between Room 306 & 307	Flush180	28-JUL-20	1.000	ug/L
51011	51011-3-HAL-F09	Between Room 306 & 307	Initial	28-JUL-20	1.000	ug/L
51011	51011-3-HAL-BF03	Between Room 306 & 307	Flush180	31-MAY-22	1.200	ug/L
51011	51011-3-HAL-BF03	Between Room 306 & 307	Flush180	31-MAY-22	1.190	ug/L
51011	51011-3-HAL-BF03	Between Room 306 & 307	Flush180	31-MAY-22	1.320	ug/L
51011	51011-3-HAL-BF03	Between Room 306 & 307	Flush180	31-MAY-22	1.640	ug/L
51011	51011-3-HAL-BF03	Between Room 306 & 307	Initial	31-MAY-22	1.280	ug/L
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-HAL-F02	Between Stairs and Boys Restroom	Initial	31-MAY-22	1.000	ug/L
51011	51011-2-HAL-F01	Between Stairs and Boys Restroom	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-118-F01	Drinking fountain inside room 118	Flush180	28-JUL-20	1.000	ug/L
51011	51011-1-118-F01	Drinking fountain inside room 118	Initial	28-JUL-20	1.000	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-	Hallway between Room 101 and	Flush180	07-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	102				
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F06	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F06	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F06	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F06	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F06	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	31-MAY-22	9.990	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.700	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	31-MAY-22	2.040	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.340	ug/L
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.870	ug/L
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.260	ug/L
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.680	ug/L
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.940	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	06-JUL-22	2.230	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	06-JUL-22	2.360	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	06-JUL-22	2.250	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Flush180	06-JUL-22	1.290	ug/L
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.070	ug/L
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.140	ug/L
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.110	ug/L
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Flush180	31-MAY-22	1.490	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Initial	31-MAY-22	1.660	ug/L
51011	51011-1-HAL-F04	Hallway between Room 101 and 102	Initial	31-MAY-22	1.530	ug/L
51011	51011-1-HAL-F03	Hallway between Room 101 and 102	Initial	06-JUL-22	2.700	ug/L
51011	51011-1-HAL-F05	Hallway between Room 101 and 102	Initial	31-MAY-22	1.160	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51011	51011-1-HAL-RBF01	Hallway between Room 101 and 102, right	Flush180	31-MAY-22	1.270	ug/L
51011	51011-1-HAL-RBF01	Hallway between Room 101 and 102, right	Flush180	31-MAY-22	1.320	ug/L
51011	51011-1-HAL-RBF01	Hallway between Room 101 and 102, right	Flush180	31-MAY-22	1.400	ug/L
51011	51011-1-HAL-RBF01	Hallway between Room 101 and 102, right	Flush180	31-MAY-22	1.430	ug/L
51011	51011-1-HAL-RBF01	Hallway between Room 101 and 102, right	Initial	31-MAY-22	2.040	ug/L
51011	51011-1-HAL-F07	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F07	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F07	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F07	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F07	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	31-MAY-22	4.270	ug/L
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	31-MAY-22	3.860	ug/L
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	31-MAY-22	4.860	ug/L
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Flush180	31-MAY-22	4.110	ug/L
51011	51011-1-HAL-F08	Hallway between Room 106 and 107	Initial	31-MAY-22	1.260	ug/L
51011	51011-1-HAL-BF01	Hallway between Room 106 and 107	Flush180	31-MAY-22	2.950	ug/L
51011	51011-1-HAL-BF01	Hallway between Room 106 and 107	Flush180	31-MAY-22	2.030	ug/L
51011	51011-1-HAL-BF01	Hallway between Room 106 and 107	Flush180	31-MAY-22	2.130	ug/L
51011	51011-1-HAL-BF01	Hallway between Room 106 and 107	Flush180	31-MAY-22	1.850	ug/L
51011	51011-1-HAL-BF01	Hallway between Room 106 and 107	Initial	31-MAY-22	1.740	ug/L
51011	51011-1-KIT-KS03	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS03	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS03	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS03	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS01	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS01	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS01	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS01	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS02	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS02	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS02	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS02	Kitchen	Flush180	07-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51011	51011-1-KIT-KS02	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS03	Kitchen	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS01	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS01	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS01	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS01	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS02	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS02	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS02	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS02	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS03	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS03	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS03	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS03	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS03	Kitchen	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS01	Kitchen	Initial	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS01	Kitchen	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS02	Kitchen	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS03	Kitchen	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	07-JUN-16	6.290	ppb
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS05	Kitchen for Washing Dishes	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-KS04	Kitchen for Washing Dishes	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-KIT-	Kitchen for Washing Dishes	Initial	31-MAY-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS05					
51011	51011-1-102-F01	Room 102	Flush180	03-SEP-19	1.370	ug/L
51011	51011-1-102-F01	Room 102	Flush180	03-SEP-19	1.740	ug/L
51011	51011-1-102-F01	Room 102	Flush180	03-SEP-19	1.550	ug/L
51011	51011-1-102-F01	Room 102	Flush180	03-SEP-19	1.460	ug/L
51011	51011-1-102-S01	Room 102	Flush180	03-SEP-19	2.460	ug/L
51011	51011-1-102-S01	Room 102	Flush180	03-SEP-19	3.210	ug/L
51011	51011-1-102-S01	Room 102	Flush180	03-SEP-19	2.100	ug/L
51011	51011-1-102-S01	Room 102	Flush180	03-SEP-19	2.430	ug/L
51011	51011-1-102-S01	Room 102	Flush180	20-NOV-19	4.030	ug/L
51011	51011-1-102-S01	Room 102	Flush180	20-NOV-19	1.710	ug/L
51011	51011-1-102-S01	Room 102	Flush180	20-NOV-19	5.680	ug/L
51011	51011-1-102-S01	Room 102	Flush180	20-NOV-19	3.820	ug/L
51011	51011-1-102-S01	Room 102	Flush180	18-DEC-19	1.310	ug/L
51011	51011-1-102-S01	Room 102	Flush180	18-DEC-19	1.420	ug/L
51011	51011-1-102-S01	Room 102	Flush180	18-DEC-19	1.290	ug/L
51011	51011-1-102-S01	Room 102	Flush180	18-DEC-19	2.250	ug/L
51011	51011-1-102-F01	Room 102	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-102-F01	Room 102	Flush180	31-MAY-22	1.770	ug/L
51011	51011-1-102-F01	Room 102	Flush180	31-MAY-22	1.400	ug/L
51011	51011-1-102-F01	Room 102	Flush180	31-MAY-22	1.720	ug/L
51011	51011-1-102-S01	Room 102	Flush180	31-MAY-22	3.540	ug/L
51011	51011-1-102-S01	Room 102	Flush180	31-MAY-22	4.090	ug/L
51011	51011-1-102-S01	Room 102	Flush180	31-MAY-22	4.410	ug/L
51011	51011-1-102-S01	Room 102	Flush180	31-MAY-22	3.890	ug/L
51011	51011-1-102-F01	Room 102	Initial	03-SEP-19	1.000	ug/L
51011	51011-1-102-S01	Room 102	Initial	03-SEP-19	8.050	ug/L
51011	51011-1-102-S01	Room 102	Initial	20-NOV-19	2.430	ug/L
51011	51011-1-102-S01	Room 102	Initial	18-DEC-19	2.580	ug/L
51011	51011-1-102-F01	Room 102	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-102-S01	Room 102	Initial	31-MAY-22	2.210	ug/L
51011	51011-1-113-F01	Room 113	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-113-F01	Room 113	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-113-F01	Room 113	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-113-F01	Room 113	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-113-F01	Room 113	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-113-	Room 113	Flush180	31-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51011	51011-1-113-F01	Room 113	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-113-F01	Room 113	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-113-F01	Room 113	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-114-F01	Room 114	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-114-F01	Room 114	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-114-F01	Room 114	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-114-F01	Room 114	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-114-F01	Room 114	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-114-F01	Room 114	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-114-F01	Room 114	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-114-F01	Room 114	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-114-F01	Room 114	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-114-F01	Room 114	Initial	31-MAY-22	1.000	ug/L
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	07-JUN-16	1.000	ppb
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-116-F01	Room 116 - Kindergarten	Flush180	31-MAY-22	1.000	ug/L
51011	51011-1-116-F01	Room 116 - Kindergarten	Initial	31-MAY-22	1.000	ug/L