



Sep 10, 2024

FARRAGUT HS

2345 S CHRISTIANA AVE, Chicago IL 60623.

Dear **FARRAGUT HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

FARRAGUT HS

2345 S CHRISTIANA AVE, Chicago IL 60623.

Estimadas familias de **FARRAGUT HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in blue ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-ADD-4-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-RBF01		Flush180	02-JUN-23	1.100	ug/L
51581	51581-ADD-1-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-BF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F04		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F04		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F04		Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F04		Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-RBF01		Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-RBF01		Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-BF01		Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-RBF01		Initial	02-JUN-23	1.400	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-ADD-2-HAL-RBF01		Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-RBF01		Initial	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-BF01		Initial	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F04		Initial	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-RBF01		Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F07	ADDITION	Flush180	17-DEC-20	1.000	ug/L
51581	51581-ADD-4-HAL-F07	ADDITION	Initial	17-DEC-20	3.500	ug/L
51581	51581-ADD-2-KIT-KS02	Addition Kitchen Sink (West) 2	Flush180	17-JUN-16	0.511	ppb
51581	51581-ADD-2-KIT-KS02	Addition Kitchen Sink (West) 2	Flush180	17-JUN-16	0.621	ppb
51581	51581-ADD-2-KIT-KS02	Addition Kitchen Sink (West) 2	Flush180	17-JUN-16	0.484	ppb
51581	51581-ADD-2-KIT-KS02	Addition Kitchen Sink (West) 2	Flush180	17-JUN-16	0.668	ppb
51581	51581-ADD-2-KIT-KS02	Addition Kitchen Sink (West) 2	Initial	17-JUN-16	0.333	ppb
51581	51581-ADD-1-HAL-F03	Addition- Across Auditorium A (Hallway) North, Fou	Flush180	17-JUN-16	0.220	ppb
51581	51581-ADD-1-HAL-F03	Addition- Across Auditorium A (Hallway) North, Fou	Flush180	17-JUN-16	0.253	ppb
51581	51581-ADD-1-HAL-F03	Addition- Across Auditorium A (Hallway) North, Fou	Flush180	17-JUN-16	0.253	ppb
51581	51581-ADD-1-HAL-F03	Addition- Across Auditorium A (Hallway) North, Fou	Flush180	17-JUN-16	0.181	ppb
51581	51581-ADD-1-HAL-F03	Addition- Across Auditorium A (Hallway) North, Fou	Initial	17-JUN-16	0.190	ppb
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F04	Addition- Across Auditorium A (Hallway) South, Fou	Initial	17-JUN-16	0.168	ppb
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	17-JUN-16	0.357	ppb
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	17-JUN-16	0.201	ppb
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	17-JUN-16	0.492	ppb
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	17-DEC-20	65.000	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	04-MAR-21	7.870	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	04-MAR-21	11.200	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	04-MAR-21	12.800	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Flush180	04-MAR-21	14.300	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Initial	17-JUN-16	0.545	ppb
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Initial	17-DEC-20	100.000	ug/L
51581	51581-ADD-1-HAL-F01	Addition- Across Auditorium B (Hallway) North, Fou	Initial	04-MAR-21	14.400	ug/L
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Flush180	17-JUN-16	1.000	ppb
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-1-HAL-F02	Addition- Across Auditorium B (Hallway) South, Fou	Initial	17-JUN-16	0.517	ppb
51581	51581-ADD-2-HAL-F04	Addition- Across Room 200 (Hallway) Center, Founta	Flush180	17-JUN-16	0.376	ppb
51581	51581-ADD-2-HAL-F04	Addition- Across Room 200 (Hallway) Center, Founta	Flush180	17-JUN-16	0.401	ppb
51581	51581-ADD-2-HAL-F04	Addition- Across Room 200 (Hallway) Center, Founta	Flush180	17-JUN-16	0.381	ppb
51581	51581-ADD-2-HAL-F04	Addition- Across Room 200 (Hallway) Center, Founta	Flush180	17-JUN-16	0.394	ppb
51581	51581-ADD-2-HAL-F04	Addition- Across Room 200 (Hallway) Center, Founta	Initial	17-JUN-16	0.384	ppb
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	17-JUN-16	0.461	ppb
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	17-JUN-16	0.400	ppb
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	17-JUN-16	0.384	ppb
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Flush180	17-JUN-16	0.407	ppb
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-2-HAL-F05	Addition- Across Room 200 (Hallway) East, Fountain	Initial	17-JUN-16	0.680	ppb
51581	51581-ADD-2-HAL-F03	Addition- Across Room 200 (Hallway) West, Fountain	Flush180	17-JUN-16	0.426	ppb
51581	51581-ADD-2-HAL-F03	Addition- Across Room 200 (Hallway) West, Fountain	Flush180	17-JUN-16	0.383	ppb
51581	51581-ADD-2-HAL-F03	Addition- Across Room 200 (Hallway) West, Fountain	Flush180	17-JUN-16	0.365	ppb
51581	51581-ADD-2-HAL-F03	Addition- Across Room 200 (Hallway) West, Fountain	Flush180	17-JUN-16	0.395	ppb
51581	51581-ADD-2-HAL-F03	Addition- Across Room 200 (Hallway) West, Fountain	Initial	17-JUN-16	0.574	ppb
51581	51581-ADD-3-	Addition- Across Room 308	Flush180	02-JUN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F06	(Hallway) East, Fountain				
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	17-JUN-16	0.291	ppb
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	17-JUN-16	0.287	ppb
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	17-JUN-16	0.337	ppb
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Flush180	17-JUN-16	0.253	ppb
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F06	Addition- Across Room 308 (Hallway) East, Fountain	Initial	17-JUN-16	0.423	ppb
51581	51581-ADD-3-HAL-F05	Addition- Across Room 308 (Hallway) West, Fountain	Flush180	17-JUN-16	0.371	ppb
51581	51581-ADD-3-HAL-F05	Addition- Across Room 308 (Hallway) West, Fountain	Flush180	17-JUN-16	0.387	ppb
51581	51581-ADD-3-HAL-F05	Addition- Across Room 308 (Hallway) West, Fountain	Flush180	17-JUN-16	0.324	ppb
51581	51581-ADD-3-HAL-F05	Addition- Across Room 308 (Hallway) West, Fountain	Flush180	17-JUN-16	0.434	ppb
51581	51581-ADD-3-HAL-F05	Addition- Across Room 308 (Hallway) West, Fountain	Initial	17-JUN-16	0.435	ppb
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	17-JUN-16	0.300	ppb
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	17-JUN-16	0.262	ppb
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	17-JUN-16	0.319	ppb
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Flush180	17-JUN-16	0.299	ppb
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Initial	02-JUN-23	1.080	ug/L
51581	51581-ADD-3-HAL-F01	Addition- Across Room 322 (Hallway) North, Fountain	Initial	17-JUN-16	0.500	ppb
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	17-JUN-16	0.231	ppb
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	17-JUN-16	0.245	ppb
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	17-JUN-16	0.233	ppb
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Flush180	17-JUN-16	0.228	ppb
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F02	Addition- Across Room 322 (Hallway) South, Fountain	Initial	17-JUN-16	0.345	ppb
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-	Addition- Across Room 334	Flush180	02-JUN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03	(Hallway) North, Fountai				
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Flush180	17-JUN-16	0.428	ppb
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Flush180	17-JUN-16	0.417	ppb
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Flush180	17-JUN-16	0.443	ppb
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Flush180	17-JUN-16	0.405	ppb
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Initial	02-JUN-23	1.080	ug/L
51581	51581-ADD-3-HAL-F03	Addition- Across Room 334 (Hallway) North, Fountai	Initial	17-JUN-16	0.536	ppb
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	17-JUN-16	0.414	ppb
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	17-JUN-16	0.427	ppb
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	17-JUN-16	0.435	ppb
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Flush180	17-JUN-16	0.428	ppb
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-3-HAL-F04	Addition- Across Room 334 (Hallway) South, Fountai	Initial	17-JUN-16	0.430	ppb
51581	51581-ADD-4-HAL-F05	Addition- Across Room 406 (Hallway) East, Fountain	Flush180	17-JUN-16	0.291	ppb
51581	51581-ADD-4-HAL-F05	Addition- Across Room 406 (Hallway) East, Fountain	Flush180	17-JUN-16	0.203	ppb
51581	51581-ADD-4-HAL-F05	Addition- Across Room 406 (Hallway) East, Fountain	Flush180	17-JUN-16	0.332	ppb
51581	51581-ADD-4-HAL-F05	Addition- Across Room 406 (Hallway) East, Fountain	Flush180	17-JUN-16	0.229	ppb
51581	51581-ADD-4-HAL-F05	Addition- Across Room 406 (Hallway) East, Fountain	Initial	17-JUN-16	0.193	ppb
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	17-JUN-16	0.322	ppb
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	17-JUN-16	0.298	ppb
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	17-JUN-16	0.257	ppb
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Flush180	17-JUN-16	0.251	ppb
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Initial	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F06	Addition- Across Room 406 (Hallway) West, Fountain	Initial	17-JUN-16	0.273	ppb
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	17-JUN-16	0.399	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	17-JUN-16	0.367	ppb
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	17-JUN-16	2.350	ppb
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Flush180	17-JUN-16	0.413	ppb
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Initial	02-JUN-23	1.090	ug/L
51581	51581-ADD-4-HAL-F04	Addition- Across Room 422 (Hallway) North, Fountai	Initial	17-JUN-16	0.569	ppb
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	02-JUN-23	1.000	ug/L
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	17-JUN-16	0.399	ppb
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	17-JUN-16	0.400	ppb
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	17-JUN-16	0.394	ppb
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Flush180	17-JUN-16	0.402	ppb
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Initial	02-JUN-23	1.070	ug/L
51581	51581-ADD-4-HAL-F03	Addition- Across Room 422 (Hallway) South, Fountai	Initial	17-JUN-16	0.404	ppb
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	02-JUN-23	1.100	ug/L
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	02-JUN-23	1.080	ug/L
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	02-JUN-23	1.190	ug/L
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	02-JUN-23	1.120	ug/L
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	17-JUN-16	0.474	ppb
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	17-JUN-16	0.460	ppb
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	17-JUN-16	0.486	ppb
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Flush180	17-JUN-16	0.462	ppb
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Initial	02-JUN-23	2.070	ug/L
51581	51581-ADD-4-HAL-F02	Addition- Across Room 434 (Hallway) North, Fountai	Initial	17-JUN-16	0.572	ppb
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	02-JUN-23	1.110	ug/L
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	02-JUN-23	1.130	ug/L
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	02-JUN-23	1.070	ug/L
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	02-JUN-23	1.100	ug/L
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	17-JUN-16	0.440	ppb
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	17-JUN-16	0.455	ppb
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	17-JUN-16	0.462	ppb
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Flush180	17-JUN-16	0.429	ppb
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Initial	02-JUN-23	1.630	ug/L
51581	51581-ADD-4-HAL-F01	Addition- Across Room 434 (Hallway) South, Fountai	Initial	17-JUN-16	0.478	ppb
51581	51581-ADD-2-KIT-KS01	Addition- Kitchen Sink (East) 1	Flush180	17-JUN-16	0.409	ppb
51581	51581-ADD-2-KIT-KS01	Addition- Kitchen Sink (East) 1	Flush180	17-JUN-16	0.653	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-ADD-2-KIT-KS01	Addition- Kitchen Sink (East) 1	Flush180	17-JUN-16	1.020	ppb
51581	51581-ADD-2-KIT-KS01	Addition- Kitchen Sink (East) 1	Flush180	17-JUN-16	0.558	ppb
51581	51581-ADD-2-KIT-KS01	Addition- Kitchen Sink (East) 1	Initial	17-JUN-16	1.000	ppb
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	17-JUN-16	0.347	ppb
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	17-JUN-16	0.343	ppb
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	17-JUN-16	0.575	ppb
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Flush180	17-JUN-16	0.332	ppb
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Initial	02-JUN-23	1.000	ug/L
51581	51581-1-HAL-F01	Main Bldg- Across Room 169 (Hallway), Fountain	Initial	17-JUN-16	1.370	ppb
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	07-JUL-23	1.000	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	07-JUL-23	1.000	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	07-JUL-23	1.000	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	02-JUN-23	5.280	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	02-JUN-23	3.200	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	02-JUN-23	2.400	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	02-JUN-23	2.120	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	17-JUN-16	0.455	ppb
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	17-JUN-16	0.143	ppb
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	17-JUN-16	0.173	ppb
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Flush180	17-JUN-16	0.206	ppb
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Initial	07-JUL-23	1.000	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Initial	02-JUN-23	9.170	ug/L
51581	51581-1-HAL-F02	Main Bldg- Across Room 171 (Hallway) East, Fountai	Initial	17-JUN-16	1.320	ppb
51581	51581-1-HAL-F03	Main Bldg- Across Room 171 (Hallway) West, Fountai	Flush180	17-JUN-16	1.020	ppb
51581	51581-1-HAL-F03	Main Bldg- Across Room 171 (Hallway) West, Fountai	Flush180	17-JUN-16	1.890	ppb
51581	51581-1-HAL-F03	Main Bldg- Across Room 171 (Hallway) West, Fountai	Flush180	17-JUN-16	1.350	ppb
51581	51581-1-HAL-F03	Main Bldg- Across Room 171 (Hallway) West, Fountai	Flush180	17-JUN-16	3.630	ppb
51581	51581-1-HAL-F03	Main Bldg- Across Room 171 (Hallway) West, Fountai	Initial	17-JUN-16	10.800	ppb
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	02-JUN-23	1.190	ug/L
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	17-JUN-16	0.632	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	(Hallway) North, Founta				
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	17-JUN-16	0.553	ppb
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	17-JUN-16	0.588	ppb
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Flush180	17-JUN-16	0.670	ppb
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Initial	02-JUN-23	4.330	ug/L
51581	51581-2-HAL-F01	Main Bldg- Across Room 265 (Hallway) North, Founta	Initial	17-JUN-16	1.530	ppb
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	17-JUN-16	1.590	ppb
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	17-JUN-16	0.476	ppb
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	17-JUN-16	0.485	ppb
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	17-JUN-16	0.521	ppb
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Flush180	17-DEC-20	1.000	ug/L
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Initial	02-JUN-23	3.180	ug/L
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Initial	17-JUN-16	1.420	ppb
51581	51581-2-HAL-F02	Main Bldg- Across Room 265 (Hallway) South, Founta	Initial	17-DEC-20	1.590	ug/L
51581	51581-3-HAL-F01	Main Bldg- Across Room 365 (Hallway) North, Founta	Flush180	17-JUN-16	0.336	ppb
51581	51581-3-HAL-F01	Main Bldg- Across Room 365 (Hallway) North, Founta	Flush180	17-JUN-16	0.370	ppb
51581	51581-3-HAL-F01	Main Bldg- Across Room 365 (Hallway) North, Founta	Flush180	17-JUN-16	0.577	ppb
51581	51581-3-HAL-F01	Main Bldg- Across Room 365 (Hallway) North, Founta	Flush180	17-JUN-16	0.529	ppb
51581	51581-3-HAL-F01	Main Bldg- Across Room 365 (Hallway) North, Founta	Initial	17-JUN-16	1.370	ppb
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	15-SEP-23	4.190	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	15-SEP-23	1.970	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	15-SEP-23	1.270	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	15-SEP-23	1.520	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	07-JUL-23	10.200	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	07-JUL-23	6.100	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	02-JUN-23	1.480	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	02-JUN-23	3.890	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	02-JUN-23	1.170	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	02-JUN-23	1.460	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	07-JUL-23	4.190	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	07-JUL-23	3.860	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	25-AUG-23	12.800	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	25-AUG-23	3.860	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	25-AUG-23	3.260	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	(Hallway) South, Founta				
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	25-AUG-23	3.750	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	17-JUN-16	0.391	ppb
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	17-JUN-16	0.411	ppb
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	17-JUN-16	0.379	ppb
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Flush180	17-JUN-16	0.402	ppb
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Initial	15-SEP-23	5.470	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Initial	07-JUL-23	9.280	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Initial	02-JUN-23	5.330	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Initial	25-AUG-23	19.100	ug/L
51581	51581-3-HAL-F02	Main Bldg- Across Room 365 (Hallway) South, Founta	Initial	17-JUN-16	1.280	ppb
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Flush180	17-JUN-16	0.581	ppb
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Flush180	17-JUN-16	0.551	ppb
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Flush180	17-JUN-16	0.542	ppb
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Flush180	17-JUN-16	0.380	ppb
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Flush180	17-DEC-20	1.000	ug/L
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Initial	17-JUN-16	2.630	ppb
51581	51581-4-HAL-F01	Main Bldg- Across Room 405 (Hallway) North, Founta	Initial	17-DEC-20	3.670	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush	17-OCT-2023	14.300	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush	17-OCT-2023	3.610	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush	17-OCT-2023	61.700	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush	17-OCT-2023	3.000	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	15-SEP-23	4.720	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	15-SEP-23	5.390	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	15-SEP-23	3.490	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	15-SEP-23	10.400	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	07-JUL-23	2.200	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	07-JUL-23	3.540	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	07-JUL-23	16.900	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	07-JUL-23	2.190	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	25-AUG-23	3.670	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	25-AUG-23	1.760	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	02-JUN-23	5.500	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	02-JUN-23	1.710	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	02-JUN-23	1.000	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	25-AUG-23	7.830	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	25-AUG-23	5.960	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	17-JUN-16	2.040	ppb
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	17-JUN-16	2.860	ppb
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	17-JUN-16	5.600	ppb
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Flush180	17-JUN-16	8.930	ppb
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	15-SEP-23	3.130	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	15-SEP-23	3.130	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	07-JUL-23	4.620	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	02-JUN-23	7.250	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	25-AUG-23	3.470	ug/L
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	17-JUN-16	2.460	ppb
51581	51581-1-175-S04	Main Bldg- Inside of Room 175, Sink	Initial	17-OCT-2023	42.700	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush	17-OCT-2023	1.000	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush	17-OCT-2023	1.000	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush	17-OCT-2023	1.000	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush	17-OCT-2023	1.000	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	07-JUL-23	3.850	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	07-JUL-23	8.970	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	07-JUL-23	4.140	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	07-JUL-23	4.240	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	02-JUN-23	4.720	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	02-JUN-23	1.310	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	02-JUN-23	1.950	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	02-JUN-23	3.150	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	17-JUN-16	0.189	ppb
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	17-JUN-16	0.199	ppb
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	17-JUN-16	0.268	ppb
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Flush180	17-JUN-16	0.234	ppb
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Initial	07-JUL-23	7.350	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Initial	02-JUN-23	6.570	ug/L
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Initial	17-JUN-16	0.482	ppb
51581	51581-2-HAL-F03	Main Bldg- Outside Room 271B (Hallway) East, Fount	Initial	17-OCT-2023	1.030	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	15-SEP-23	1.150	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	15-SEP-23	1.000	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	15-SEP-23	1.000	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	15-SEP-23	1.720	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	07-JUL-23	3.300	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	07-JUL-23	3.270	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	07-JUL-23	2.700	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	07-JUL-23	2.670	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	17-JUN-16	1.000	ppb
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	17-JUN-16	0.176	ppb
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	17-JUN-16	1.000	ppb
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Flush180	17-JUN-16	1.000	ppb
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Initial	15-SEP-23	2.110	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Initial	07-JUL-23	5.270	ug/L
51581	51581-2-HAL-F04	Main Bldg- Outside Room 271B (Hallway) West, Fount	Initial	17-JUN-16	0.633	ppb
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	5.620	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.480	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	17-JUN-16	1.000	ppb
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	17-JUN-16	0.127	ppb
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	17-JUN-16	0.126	ppb
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Flush180	17-JUN-16	0.129	ppb
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Initial	02-JUN-23	1.290	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Initial	02-JUN-23	9.020	ug/L
51581	51581-3-HAL-F04	Main Bldg- Outside Room 374 (Hallway) East, Founta	Initial	17-JUN-16	0.453	ppb
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	02-JUN-23	1.350	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	02-JUN-23	1.110	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	02-JUN-23	1.000	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	07-JUL-23	1.000	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	07-JUL-23	1.000	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	07-JUL-23	1.000	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	02-JUN-23	2.100	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	07-JUL-23	1.600	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	17-JUN-16	0.137	ppb
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	17-JUN-16	0.160	ppb
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	17-JUN-16	0.168	ppb
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Flush180	17-JUN-16	0.168	ppb
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Initial	02-JUN-23	6.320	ug/L
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Initial	07-JUL-23	3.760	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	(Hallway) West, Founta				
51581	51581-3-HAL-F03	Main Bldg- Outside Room 374 (Hallway) West, Founta	Initial	17-JUN-16	0.532	ppb
51581	51581-4-HAL-F04	Main Bldg- Outside Room 475 (Hallway) East, Founta	Flush180	17-JUN-16	0.523	ppb
51581	51581-4-HAL-F04	Main Bldg- Outside Room 475 (Hallway) East, Founta	Flush180	17-JUN-16	0.526	ppb
51581	51581-4-HAL-F04	Main Bldg- Outside Room 475 (Hallway) East, Founta	Flush180	17-JUN-16	0.528	ppb
51581	51581-4-HAL-F04	Main Bldg- Outside Room 475 (Hallway) East, Founta	Flush180	17-JUN-16	0.463	ppb
51581	51581-4-HAL-F04	Main Bldg- Outside Room 475 (Hallway) East, Founta	Initial	17-JUN-16	0.919	ppb
51581	51581-4-HAL-F03	Main Bldg- Outside Room 475 (Hallway) West, Founta	Flush180	17-JUN-16	0.492	ppb
51581	51581-4-HAL-F03	Main Bldg- Outside Room 475 (Hallway) West, Founta	Flush180	17-JUN-16	0.482	ppb
51581	51581-4-HAL-F03	Main Bldg- Outside Room 475 (Hallway) West, Founta	Flush180	17-JUN-16	0.453	ppb
51581	51581-4-HAL-F03	Main Bldg- Outside Room 475 (Hallway) West, Founta	Flush180	17-JUN-16	0.396	ppb
51581	51581-4-HAL-F03	Main Bldg- Outside Room 475 (Hallway) West, Founta	Initial	17-JUN-16	0.824	ppb