



**Sep 10, 2024**

**FENGER HS**

**11220 S WALLACE ST, Chicago IL 60628.**

Dear **FENGER HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**FENGER HS**

**11220 S WALLACE ST, Chicago IL 60628.**

Estimadas familias de **FENGER HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51628	51628-2-BG-F01	Boys Gym Left Fountain	Flush180	01-NOV-16	9.000	ppb
51628	51628-2-BG-F01	Boys Gym Left Fountain	Flush180	01-NOV-16	8.800	ppb
51628	51628-2-BG-F01	Boys Gym Left Fountain	Flush180	01-NOV-16	8.600	ppb
51628	51628-2-BG-F01	Boys Gym Left Fountain	Flush180	01-NOV-16	10.000	ppb
51628	51628-2-BG-F01	Boys Gym Left Fountain	Initial	01-NOV-16	7.100	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	01-NOV-16	13.000	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	01-NOV-16	9.000	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	01-NOV-16	1.000	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	01-NOV-16	8.700	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	18-MAY-17	8.870	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	18-MAY-17	9.590	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	18-MAY-17	8.410	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Flush180	18-MAY-17	9.170	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Initial	01-NOV-16	20.000	ppb
51628	51628-2-BG-F02	Boys Gyn Right Fountain	Initial	18-MAY-17	3.410	ppb
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush180	01-NOV-16	3.700	ppb
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush180	01-NOV-16	5.200	ppb
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush180	01-NOV-16	2.700	ppb
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Flush180	01-NOV-16	2.300	ppb
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Initial	01-NOV-16	2.700	ppb
51628	51628-2-244-S01	Culinary Arts RM 244 Left Sink	Initial	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush180	01-NOV-16	3.300	ppb
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush180	01-NOV-16	3.700	ppb
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush180	01-NOV-16	5.100	ppb
51628	51628-2-244-S02	Culinary Arts Right Sink	Flush180	01-NOV-16	5.800	ppb
51628	51628-2-244-S02	Culinary Arts Right Sink	Initial	01-NOV-16	3.800	ppb
51628	51628-2-244-S02	Culinary Arts Right Sink	Initial	10-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51628	51628-2-GG-F01	Girls Gym Left Fountain	Flush180	01-NOV-16	4.700	ppb
51628	51628-2-GG-F01	Girls Gym Left Fountain	Flush180	01-NOV-16	4.600	ppb
51628	51628-2-GG-F01	Girls Gym Left Fountain	Flush180	01-NOV-16	4.400	ppb
51628	51628-2-GG-F01	Girls Gym Left Fountain	Flush180	01-NOV-16	2.500	ppb
51628	51628-2-GG-F01	Girls Gym Left Fountain	Initial	01-NOV-16	1.100	ppb
51628	51628-2-GG-F02	Girls Gym Right Fountain	Flush180	01-NOV-16	4.500	ppb
51628	51628-2-GG-F02	Girls Gym Right Fountain	Flush180	01-NOV-16	5.600	ppb
51628	51628-2-GG-F02	Girls Gym Right Fountain	Flush180	01-NOV-16	5.400	ppb
51628	51628-2-GG-F02	Girls Gym Right Fountain	Flush180	01-NOV-16	5.100	ppb
51628	51628-2-GG-F02	Girls Gym Right Fountain	Initial	01-NOV-16	4.000	ppb
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush	10-NOV-2023	4.730	ug/L
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush	10-NOV-2023	4.290	ug/L
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush	10-NOV-2023	6.020	ug/L
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush	10-NOV-2023	6.080	ug/L
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush180	01-NOV-16	1.400	ppb
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush180	01-NOV-16	1.500	ppb
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush180	01-NOV-16	3.300	ppb
51628	51628-1-KIT-KS01	Kitchen Center Sink	Flush180	01-NOV-16	1.800	ppb
51628	51628-1-KIT-KS01	Kitchen Center Sink	Initial	01-NOV-16	3.200	ppb
51628	51628-1-KIT-KS01	Kitchen Center Sink	Initial	10-NOV-2023	2.470	ug/L
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush	10-NOV-2023	1.620	ug/L
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush	10-NOV-2023	1.170	ug/L
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush	10-NOV-2023	1.090	ug/L
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush180	01-NOV-16	0.530	ppb
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush180	01-NOV-16	0.820	ppb
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush180	01-NOV-16	1.600	ppb
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Flush180	01-NOV-16	0.840	ppb
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Initial	01-NOV-16	4.800	ppb
51628	51628-1-KIT-KS02	Kitchen South Wall Sink	Initial	10-NOV-2023	1.050	ug/L
51628	51628-1-HAL-RBF01	Outside RM 103 Left Bottle Filler	Flush	10-NOV-2023	7.380	ug/L
51628	51628-1-HAL-RBF01	Outside RM 103 Left Bottle Filler	Flush	10-NOV-2023	5.630	ug/L
51628	51628-1-HAL-RBF01	Outside RM 103 Left Bottle Filler	Flush	10-NOV-2023	3.980	ug/L
51628	51628-1-HAL-RBF01	Outside RM 103 Left Bottle Filler	Flush	10-NOV-2023	3.270	ug/L
51628	51628-1-HAL-RBF01	Outside RM 103 Left Bottle Filler	Initial	10-NOV-2023	3.260	ug/L
51628	51628-1-HAL-F01	Outside RM 103 Left Fountain	Flush180	01-NOV-16	2.900	ppb
51628	51628-1-HAL-F01	Outside RM 103 Left Fountain	Flush180	01-NOV-16	2.600	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51628	51628-1-HAL-F01	Outside RM 103 Left Foutain	Flush180	01-NOV-16	7.400	ppb
51628	51628-1-HAL-F01	Outside RM 103 Left Foutain	Flush180	01-NOV-16	4.100	ppb
51628	51628-1-HAL-F01	Outside RM 103 Left Foutain	Initial	01-NOV-16	9.000	ppb
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush	10-NOV-2023	3.400	ug/L
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush	10-NOV-2023	2.750	ug/L
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush	10-NOV-2023	2.540	ug/L
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush	10-NOV-2023	2.220	ug/L
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush180	01-NOV-16	3.500	ppb
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush180	01-NOV-16	3.900	ppb
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush180	01-NOV-16	3.600	ppb
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Flush180	01-NOV-16	2.900	ppb
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Initial	01-NOV-16	8.100	ppb
51628	51628-1-HAL-F02	Outside RM 103 Right Fountain	Initial	10-NOV-2023	4.260	ug/L
51628	51628-1-HAL-F05	Outside RM 129	Flush180	01-NOV-16	5.900	ppb
51628	51628-1-HAL-F05	Outside RM 129	Flush180	01-NOV-16	6.300	ppb
51628	51628-1-HAL-F05	Outside RM 129	Flush180	01-NOV-16	4.300	ppb
51628	51628-1-HAL-F05	Outside RM 129	Flush180	01-NOV-16	7.000	ppb
51628	51628-1-HAL-F05	Outside RM 129	Initial	01-NOV-16	4.700	ppb
51628	51628-1-HAL-RBF02	Outside RM 129 Bottle Filler	Flush	10-NOV-2023	7.680	ug/L
51628	51628-1-HAL-RBF02	Outside RM 129 Bottle Filler	Flush	10-NOV-2023	7.760	ug/L
51628	51628-1-HAL-RBF02	Outside RM 129 Bottle Filler	Flush	10-NOV-2023	2.740	ug/L
51628	51628-1-HAL-RBF02	Outside RM 129 Bottle Filler	Flush	10-NOV-2023	2.170	ug/L
51628	51628-1-HAL-RBF02	Outside RM 129 Bottle Filler	Initial	10-NOV-2023	2.180	ug/L
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush	10-NOV-2023	1.810	ug/L
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush	10-NOV-2023	1.600	ug/L
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush	10-NOV-2023	1.580	ug/L
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush	10-NOV-2023	1.540	ug/L
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush180	01-NOV-16	1.900	ppb
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush180	01-NOV-16	2.900	ppb
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush180	01-NOV-16	3.400	ppb
51628	51628-1-HAL-F06	Outside RM 148 Left	Flush180	01-NOV-16	2.200	ppb
51628	51628-1-HAL-F06	Outside RM 148 Left	Initial	01-NOV-16	2.900	ppb
51628	51628-1-HAL-F06	Outside RM 148 Left	Initial	10-NOV-2023	1.590	ug/L
51628	51628-1-HAL-F07	Outside RM 148 Right Fountain	Flush180	01-NOV-16	2.400	ppb
51628	51628-1-HAL-F07	Outside RM 148 Right Fountain	Flush180	01-NOV-16	2.100	ppb
51628	51628-1-HAL-F07	Outside RM 148 Right Fountain	Flush180	01-NOV-16	2.000	ppb
51628	51628-1-HAL-F07	Outside RM 148 Right Fountain	Flush180	01-NOV-16	2.000	ppb
51628	51628-1-HAL-F07	Outside RM 148 Right Fountain	Initial	01-NOV-16	2.300	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07					
51628	51628-1-HAL-RBF03	Outside RM 148 Right Retrofitted Bottle Filler	Flush	10-NOV-2023	1.730	ug/L
51628	51628-1-HAL-RBF03	Outside RM 148 Right Retrofitted Bottle Filler	Flush	10-NOV-2023	1.210	ug/L
51628	51628-1-HAL-RBF03	Outside RM 148 Right Retrofitted Bottle Filler	Flush	10-NOV-2023	1.550	ug/L
51628	51628-1-HAL-RBF03	Outside RM 148 Right Retrofitted Bottle Filler	Flush	10-NOV-2023	1.690	ug/L
51628	51628-1-HAL-RBF03	Outside RM 148 Right Retrofitted Bottle Filler	Initial	10-NOV-2023	1.230	ug/L
51628	51628-2-HAL-RBF01	Outside RM 203 Left Bottle Filler	Flush	10-NOV-2023	24.400	ug/L
51628	51628-2-HAL-RBF01	Outside RM 203 Left Bottle Filler	Flush	10-NOV-2023	8.870	ug/L
51628	51628-2-HAL-RBF01	Outside RM 203 Left Bottle Filler	Flush	10-NOV-2023	8.370	ug/L
51628	51628-2-HAL-RBF01	Outside RM 203 Left Bottle Filler	Flush	10-NOV-2023	8.800	ug/L
51628	51628-2-HAL-RBF01	Outside RM 203 Left Bottle Filler	Initial	10-NOV-2023	8.680	ug/L
51628	51628-2-HAL-F01	Outside RM 203 Left Fountain	Flush180	01-NOV-16	1.500	ppb
51628	51628-2-HAL-F01	Outside RM 203 Left Fountain	Flush180	01-NOV-16	1.400	ppb
51628	51628-2-HAL-F01	Outside RM 203 Left Fountain	Flush180	01-NOV-16	2.300	ppb
51628	51628-2-HAL-F01	Outside RM 203 Left Fountain	Flush180	01-NOV-16	1.800	ppb
51628	51628-2-HAL-F01	Outside RM 203 Left Fountain	Initial	01-NOV-16	2.300	ppb
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush	10-NOV-2023	4.270	ug/L
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush	10-NOV-2023	4.260	ug/L
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush	10-NOV-2023	3.700	ug/L
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush	10-NOV-2023	3.310	ug/L
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush180	01-NOV-16	1.600	ppb
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush180	01-NOV-16	2.000	ppb
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush180	01-NOV-16	1.900	ppb
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Flush180	01-NOV-16	1.600	ppb
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Initial	01-NOV-16	2.500	ppb
51628	51628-2-HAL-F02	Outside RM 203 Right Fountain	Initial	10-NOV-2023	12.900	ug/L
51628	51628-2-HAL-RBF02	Outside RM 215 Left Bottle Filler	Flush	10-NOV-2023	1.400	ug/L
51628	51628-2-HAL-RBF02	Outside RM 215 Left Bottle Filler	Flush	10-NOV-2023	1.500	ug/L
51628	51628-2-HAL-RBF02	Outside RM 215 Left Bottle Filler	Flush	10-NOV-2023	1.600	ug/L
51628	51628-2-HAL-RBF02	Outside RM 215 Left Bottle Filler	Flush	10-NOV-2023	1.480	ug/L
51628	51628-2-HAL-RBF02	Outside RM 215 Left Bottle Filler	Initial	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F03	Outside RM 215 Left Fountain	Flush180	01-NOV-16	1.900	ppb
51628	51628-2-HAL-F03	Outside RM 215 Left Fountain	Flush180	01-NOV-16	1.700	ppb
51628	51628-2-HAL-F03	Outside RM 215 Left Fountain	Flush180	01-NOV-16	1.500	ppb
51628	51628-2-HAL-F03	Outside RM 215 Left Fountain	Flush180	01-NOV-16	2.500	ppb
51628	51628-2-HAL-F03	Outside RM 215 Left Fountain	Initial	01-NOV-16	2.000	ppb
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush	10-NOV-2023	1.680	ug/L
51628	51628-2-HAL-	Outside RM 215 Right Fountain	Flush	10-NOV-2023	1.690	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush	10-NOV-2023	1.800	ug/L
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush	10-NOV-2023	1.640	ug/L
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush180	01-NOV-16	2.300	ppb
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush180	01-NOV-16	1.600	ppb
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush180	01-NOV-16	1.600	ppb
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Flush180	01-NOV-16	2.200	ppb
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Initial	01-NOV-16	3.200	ppb
51628	51628-2-HAL-F04	Outside RM 215 Right Fountain	Initial	10-NOV-2023	1.710	ug/L
51628	51628-2-HAL-F05	Outside RM 229	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F05	Outside RM 229	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F05	Outside RM 229	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F05	Outside RM 229	Flush	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F05	Outside RM 229	Flush180	01-NOV-16	2.400	ppb
51628	51628-2-HAL-F05	Outside RM 229	Flush180	01-NOV-16	2.200	ppb
51628	51628-2-HAL-F05	Outside RM 229	Flush180	01-NOV-16	2.200	ppb
51628	51628-2-HAL-F05	Outside RM 229	Flush180	01-NOV-16	1.800	ppb
51628	51628-2-HAL-F05	Outside RM 229	Initial	01-NOV-16	1.300	ppb
51628	51628-2-HAL-F05	Outside RM 229	Initial	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush	10-NOV-2023	2.350	ug/L
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush	10-NOV-2023	2.860	ug/L
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush	10-NOV-2023	3.120	ug/L
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush	10-NOV-2023	2.350	ug/L
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush180	01-NOV-16	3.300	ppb
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush180	01-NOV-16	4.900	ppb
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush180	01-NOV-16	4.600	ppb
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Flush180	01-NOV-16	3.900	ppb
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Initial	01-NOV-16	5.000	ppb
51628	51628-2-HAL-F07	Outside RM 248 Right Fountain	Initial	10-NOV-2023	2.780	ug/L
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush	10-NOV-2023	1.970	ug/L
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush	10-NOV-2023	2.120	ug/L
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush	10-NOV-2023	1.970	ug/L
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush	10-NOV-2023	1.810	ug/L
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush180	01-NOV-16	2.800	ppb
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush180	01-NOV-16	2.000	ppb
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush180	01-NOV-16	1.600	ppb
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Flush180	01-NOV-16	1.400	ppb
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Initial	01-NOV-16	4.700	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51628	51628-3-HAL-F01	Outside RM 307 Left Fountain	Initial	10-NOV-2023	3.200	ug/L
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush	10-NOV-2023	2.180	ug/L
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush	10-NOV-2023	1.820	ug/L
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush	10-NOV-2023	2.030	ug/L
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush	10-NOV-2023	2.040	ug/L
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush180	01-NOV-16	1.900	ppb
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush180	01-NOV-16	1.500	ppb
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush180	01-NOV-16	2.100	ppb
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Flush180	01-NOV-16	1.900	ppb
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Initial	01-NOV-16	2.800	ppb
51628	51628-3-HAL-F02	Outside RM 307 Right Fountain	Initial	10-NOV-2023	2.450	ug/L
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush	10-NOV-2023	1.080	ug/L
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush	10-NOV-2023	1.580	ug/L
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush	10-NOV-2023	1.300	ug/L
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush180	01-NOV-16	2.600	ppb
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush180	01-NOV-16	2.400	ppb
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush180	01-NOV-16	2.300	ppb
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Flush180	01-NOV-16	2.700	ppb
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Initial	01-NOV-16	3.000	ppb
51628	51628-3-HAL-F03	Outside RM 317 Left Fountain	Initial	10-NOV-2023	2.830	ug/L
51628	51628-3-HAL-RBF01	Outside RM 317 Right Bottle Filler	Flush	10-NOV-2023	2.930	ug/L
51628	51628-3-HAL-RBF01	Outside RM 317 Right Bottle Filler	Flush	10-NOV-2023	2.520	ug/L
51628	51628-3-HAL-RBF01	Outside RM 317 Right Bottle Filler	Flush	10-NOV-2023	1.780	ug/L
51628	51628-3-HAL-RBF01	Outside RM 317 Right Bottle Filler	Flush	10-NOV-2023	2.320	ug/L
51628	51628-3-HAL-RBF01	Outside RM 317 Right Bottle Filler	Initial	10-NOV-2023	5.060	ug/L
51628	51628-3-HAL-F04	Outside RM 317 Right Fountain	Flush180	01-NOV-16	2.000	ppb
51628	51628-3-HAL-F04	Outside RM 317 Right Fountain	Flush180	01-NOV-16	2.600	ppb
51628	51628-3-HAL-F04	Outside RM 317 Right Fountain	Flush180	01-NOV-16	1.700	ppb
51628	51628-3-HAL-F04	Outside RM 317 Right Fountain	Flush180	01-NOV-16	1.600	ppb
51628	51628-3-HAL-F04	Outside RM 317 Right Fountain	Initial	01-NOV-16	2.900	ppb
51628	51628-3-HAL-BF01	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-BF01	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-BF01	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-BF01	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F05	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F05	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51628	51628-3-HAL-F05	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F05	Outside RM 329	Flush	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F05	Outside RM 329	Flush180	01-NOV-16	1.600	ppb
51628	51628-3-HAL-F05	Outside RM 329	Flush180	01-NOV-16	1.500	ppb
51628	51628-3-HAL-F05	Outside RM 329	Flush180	01-NOV-16	2.100	ppb
51628	51628-3-HAL-F05	Outside RM 329	Flush180	01-NOV-16	1.600	ppb
51628	51628-3-HAL-F05	Outside RM 329	Initial	01-NOV-16	1.500	ppb
51628	51628-3-HAL-BF01	Outside RM 329	Initial	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F05	Outside RM 329	Initial	10-NOV-2023	1.000	ug/L
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush	10-NOV-2023	58.800	ug/L
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush	10-NOV-2023	10.700	ug/L
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush	10-NOV-2023	7.650	ug/L
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush	10-NOV-2023	5.930	ug/L
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	18-MAY-17	3.760	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	18-MAY-17	3.690	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	18-MAY-17	8.510	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	18-MAY-17	4.440	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	01-NOV-16	4.700	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	01-NOV-16	16.000	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	01-NOV-16	12.000	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Flush180	01-NOV-16	6.200	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Initial	18-MAY-17	4.280	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Initial	01-NOV-16	10.000	ppb
51628	51628-3-HAL-F06	Outside RM 348 Left Fountain	Initial	10-NOV-2023	58.600	ug/L
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush	10-NOV-2023	18.000	ug/L
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush	10-NOV-2023	9.260	ug/L
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush	10-NOV-2023	5.980	ug/L
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush	10-NOV-2023	5.090	ug/L
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush180	01-NOV-16	4.200	ppb
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush180	01-NOV-16	6.000	ppb
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush180	01-NOV-16	2.400	ppb
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Flush180	01-NOV-16	3.200	ppb
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Initial	01-NOV-16	9.400	ppb
51628	51628-3-HAL-F07	Outside RM 348 Right Fountain	Initial	10-NOV-2023	38.500	ug/L
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush	10-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush180	01-NOV-16	0.450	ppb
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush180	01-NOV-16	0.670	ppb
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush180	01-NOV-16	0.550	ppb
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Flush180	01-NOV-16	0.690	ppb
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Initial	01-NOV-16	0.430	ppb
51628	51628-1-HAL-F03	Outside Rm 117 Left Fountain	Initial	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush	10-NOV-2023	1.000	ug/L
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush180	01-NOV-16	0.620	ppb
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush180	01-NOV-16	0.670	ppb
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush180	01-NOV-16	0.640	ppb
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Flush180	01-NOV-16	0.620	ppb
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Initial	01-NOV-16	0.670	ppb
51628	51628-1-HAL-F04	Outside Rm 117 Right Fountain	Initial	10-NOV-2023	1.000	ug/L
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush	10-NOV-2023	4.670	ug/L
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush	10-NOV-2023	3.140	ug/L
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush	10-NOV-2023	2.540	ug/L
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush	10-NOV-2023	2.320	ug/L
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush180	01-NOV-16	4.000	ppb
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush180	01-NOV-16	7.000	ppb
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush180	01-NOV-16	4.200	ppb
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Flush180	01-NOV-16	3.700	ppb
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Initial	01-NOV-16	5.600	ppb
51628	51628-2-HAL-F06	Outside Rm 248 Left Fountain	Initial	10-NOV-2023	3.720	ug/L
51628	51628-1-163-F01	RM 163 Pool	Flush	10-NOV-2023	5.250	ug/L
51628	51628-1-163-F01	RM 163 Pool	Flush	10-NOV-2023	3.680	ug/L
51628	51628-1-163-F01	RM 163 Pool	Flush	10-NOV-2023	25.700	ug/L
51628	51628-1-163-F01	RM 163 Pool	Flush	10-NOV-2023	46.100	ug/L
51628	51628-1-163-F01	RM 163 Pool	Flush180	01-NOV-16	1.600	ppb
51628	51628-1-163-F01	RM 163 Pool	Flush180	01-NOV-16	1.600	ppb
51628	51628-1-163-F01	RM 163 Pool	Flush180	01-NOV-16	1.900	ppb
51628	51628-1-163-F01	RM 163 Pool	Flush180	01-NOV-16	1.700	ppb
51628	51628-1-163-F01	RM 163 Pool	Initial	01-NOV-16	2.700	ppb
51628	51628-1-163-F01	RM 163 Pool	Initial	10-NOV-2023	7.150	ug/L

