



Sep 10, 2024

FERNWOOD

10041 S UNION AVE, Chicago IL 60628.

Dear **FERNWOOD** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

FERNWOOD

10041 S UNION AVE, Chicago IL 60628.

Estimadas familias de **FERNWOOD**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	3.580	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	2.750	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	2.650	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	2.430	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	3.580	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	2.430	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	2.650	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Flush180	15-JUN-16	2.750	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Initial	15-JUN-16	2.760	ppb
51432	51432-G-HAL-F04	Across From Room 005, Fountain	Initial	15-JUN-16	2.760	ppb
51432	51432-2-HAL-F06	Across from 207 center Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F06	Across from 207 center Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F06	Across from 207 center Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F06	Across from 207 center Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F06	Across from 207 center Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F05	Across from 207 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F05	Across from 207 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F05	Across from 207 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F05	Across from 207 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F05	Across from 207 left Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F06	Across from 307 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F06	Across from 307 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F06	Across from 307 left Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F06	Across from 307 left Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F07	Across from 307 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F07	Across from 307 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F07	Across from 307 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F07	Across from 307 right Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-BF02	Across from RM 107 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-BF02	Across from RM 107 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-BF02	Across from RM 107 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-BF02	Across from RM 107 right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-BF02	Across from RM 107 right Fountain	Initial	09-JUN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	2.490	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	1.800	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	4.400	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	1.800	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	2.210	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	2.210	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	2.490	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Flush180	15-JUN-16	4.400	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Initial	15-JUN-16	4.580	ppb
51432	51432-1-HAL-F02	Across from Room 107 South, Fountain 1	Initial	15-JUN-16	4.580	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	30-JUN-18	0.194	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	30-JUN-18	0.193	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	6.670	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	2.650	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	5.890	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	2.070	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	2.650	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	6.670	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	5.890	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	15-JUN-16	2.070	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	30-JUN-18	0.209	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	30-JUN-18	0.201	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Flush180	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Initial	15-JUN-16	6.590	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Initial	15-JUN-16	6.590	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Initial	30-JUN-18	0.198	ppb
51432	51432-2-HAL-F03	Across from Room 207 South, Fountain 3	Initial	09-JUN-22	1.000	ug/L
51432	51432-3-HAL-F04	Across from Room 303 East, Fountain 1	Flush180	30-JUN-16	15.100	ppb
51432	51432-3-HAL-F04	Across from Room 303 East, Fountain 1	Flush180	30-JUN-16	13.900	ppb
51432	51432-3-HAL-F04	Across from Room 303 East, Fountain 1	Flush180	30-JUN-16	22.300	ppb
51432	51432-3-HAL-F04	Across from Room 303 East, Fountain 1	Flush180	30-JUN-16	18.100	ppb
51432	51432-3-HAL-F04	Across from Room 303 East, Fountain 1	Initial	30-JUN-16	21.100	ppb
51432	51432-3-HAL-F03	Across from Room 303 West, Fountain 2	Flush180	30-JUN-17	7.070	ppb
51432	51432-3-HAL-F03	Across from Room 303 West, Fountain 2	Flush180	30-JUN-17	7.190	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51432	51432-3-HAL-F03	Across from Room 303 West, Fountain 2	Flush180	30-JUN-17	7.720	ppb
51432	51432-3-HAL-F03	Across from Room 303 West, Fountain 2	Flush180	30-JUN-17	7.250	ppb
51432	51432-3-HAL-F03	Across from Room 303 West, Fountain 2	Initial	30-JUN-17	7.000	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	0.835	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	0.444	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	0.170	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	1.000	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	0.835	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	1.000	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	0.170	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	15-JUN-16	0.444	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	09-JUN-22	1.000	ug/L
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	09-JUN-22	1.000	ug/L
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Flush180	09-JUN-22	1.000	ug/L
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Initial	15-JUN-16	0.195	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Initial	15-JUN-16	0.195	ppb
51432	51432-G-005-S02	Inside Pre-K Room 005, Sink 1	Initial	09-JUN-22	1.000	ug/L
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	1.500	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	1.500	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	1.480	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	1.340	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	1.480	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	2.440	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	1.340	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Flush180	15-JUN-16	2.440	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Initial	15-JUN-16	0.884	ppb
51432	51432-G-005-S03	Inside Pre-K Room 005, Sink 2	Initial	15-JUN-16	0.884	ppb
51432	51432-B-KIT-KS01	Kitchen Sink	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS01	Kitchen Sink	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS01	Kitchen Sink	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS01	Kitchen Sink	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS01	Kitchen Sink	Initial	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS02	Kitchen Sink Right	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS02	Kitchen Sink Right	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS02	Kitchen Sink Right	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS02	Kitchen Sink Right	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-KIT-KS02	Kitchen Sink Right	Initial	09-JUN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02					
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	1.190	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	1.190	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	0.903	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	0.903	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	1.520	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	0.415	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	1.520	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Flush180	15-JUN-16	0.415	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Initial	15-JUN-16	3.670	ppb
51432	51432-2-KIT-KS01	Kitchen, Sink	Initial	15-JUN-16	3.670	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	1.940	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	2.190	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	2.210	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	1.940	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	2.190	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	2.210	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	2.080	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Flush180	15-JUN-16	2.080	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Initial	17-MAY-23	1.000	ug/L
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Initial	15-JUN-16	6.240	ppb
51432	51432-G-HAL-F01	Next To Room 002, Fountain	Initial	15-JUN-16	6.240	ppb
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Initial	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-BF01	Outside Boys Bath right Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	21-JUN-16	1.960	ppb
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	21-JUN-16	1.350	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	21-JUN-16	1.500	ppb
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	21-JUN-16	1.940	ppb
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Initial	21-JUN-16	2.050	ppb
51432	51432-B-HAL-F01	Outside Room 063, Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	8.620	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	8.620	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	3.070	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	3.070	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	2.960	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	4.330	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	2.960	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	15-JUN-16	4.330	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	21-JUN-16	0.721	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	21-JUN-16	0.492	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	21-JUN-16	0.402	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	21-JUN-16	0.334	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Flush180	09-JUN-22	1.000	ug/L
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Initial	15-JUN-16	7.240	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Initial	15-JUN-16	7.240	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Initial	21-JUN-16	0.676	ppb
51432	51432-1-HAL-F01	Outside Room 106, Fountain	Initial	09-JUN-22	1.000	ug/L
51432	51432-2-HAL-F	Outside Room 201, Fountain	Flush180	22-JUL-16	4.100	ppb
51432	51432-2-HAL-F	Outside Room 201, Fountain	Flush180	22-JUL-16	3.800	ppb
51432	51432-2-HAL-F	Outside Room 201, Fountain	Flush180	22-JUL-16	4.400	ppb
51432	51432-2-HAL-F	Outside Room 201, Fountain	Flush180	22-JUL-16	4.100	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	5.810	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	9.720	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	12.500	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	5.340	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	5.340	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	9.720	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	12.500	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Flush180	15-JUN-16	5.810	ppb
51432	51432-2-HAL-F	Outside Room 201, Fountain	Initial	22-JUL-16	4.400	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Initial	15-JUN-16	13.600	ppb
51432	51432-2-HAL-F02	Outside Room 201, Fountain	Initial	15-JUN-16	13.600	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	02-SEP-16	19.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	02-SEP-16	18.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	02-SEP-16	18.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	13-SEP-16	140.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	13-SEP-16	140.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	13-SEP-16	130.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	13-SEP-16	120.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	02-SEP-16	25.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	22-JUL-16	14.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	22-JUL-16	20.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	22-JUL-16	34.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Flush180	22-JUL-16	16.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Initial	13-SEP-16	120.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Initial	22-JUL-16	44.000	ppb
51432	51432-3-HAL-F	Outside Room 303, Fountain	Initial	02-SEP-16	38.000	ppb
51432	51432-B-HAL-F02	Outside Room G2 Basement, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-F02	Outside Room G2 Basement, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-F02	Outside Room G2 Basement, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-F02	Outside Room G2 Basement, Fountain	Flush180	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-F	Outside Room G2 Basement, Fountain	Flush180	22-JUL-16	1.000	ppb
51432	51432-B-HAL-F	Outside Room G2 Basement, Fountain	Flush180	22-JUL-16	1.000	ppb
51432	51432-B-HAL-F	Outside Room G2 Basement, Fountain	Flush180	22-JUL-16	1.000	ppb
51432	51432-B-HAL-F	Outside Room G2 Basement, Fountain	Flush180	22-JUL-16	1.000	ppb
51432	51432-B-HAL-F02	Outside Room G2 Basement, Fountain	Initial	17-MAY-23	1.000	ug/L
51432	51432-B-HAL-F	Outside Room G2 Basement, Fountain	Initial	22-JUL-16	1.000	ppb