



Sep 10, 2024

FOSTER PARK

8530 S WOOD ST, Chicago IL 60620.

Dear **FOSTER PARK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

FOSTER PARK

8530 S WOOD ST, Chicago IL 60620.

Estimadas familias de **FOSTER PARK**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51434	51434-1-HAL-F02	Main- Across from Room 102 North, Left Fountain 1	Flush180	07-JUN-16	0.474	ppb
51434	51434-1-HAL-F02	Main- Across from Room 102 North, Left Fountain 1	Flush180	07-JUN-16	0.400	ppb
51434	51434-1-HAL-F02	Main- Across from Room 102 North, Left Fountain 1	Flush180	07-JUN-16	0.416	ppb
51434	51434-1-HAL-F02	Main- Across from Room 102 North, Left Fountain 1	Flush180	07-JUN-16	0.506	ppb
51434	51434-1-HAL-F02	Main- Across from Room 102 North, Left Fountain 1	Initial	07-JUN-16	0.686	ppb
51434	51434-1-HAL-RBF01	Main- Across from Room 102 North, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF01	Main- Across from Room 102 North, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF01	Main- Across from Room 102 North, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF01	Main- Across from Room 102 North, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF01	Main- Across from Room 102 North, Left Retrofit Bottle Filler	Initial	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	07-JUN-16	0.367	ppb
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	07-JUN-16	0.386	ppb
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	07-JUN-16	0.429	ppb
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	07-JUN-16	0.368	ppb
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Initial	07-JUN-16	0.557	ppb
51434	51434-1-HAL-F03	Main- Across from Room 102 North, Right Fountain 2	Initial	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF02	Main- By Room 106, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF02	Main- By Room 106, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF02	Main- By Room 106, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF02	Main- By Room 106, Left Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-RBF02	Main- By Room 106, Left Retrofit Bottle Filler	Initial	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	07-JUN-16	0.477	ppb
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	07-JUN-16	1.500	ppb
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	07-JUN-16	1.370	ppb
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	07-JUN-16	1.430	ppb
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Flush180	22-APR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Initial	07-JUN-16	1.460	ppb
51434	51434-1-HAL-F01	Main- By Room 106, Right Fountain	Initial	22-APR-22	1.000	ug/L
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	07-JUN-16	1.450	ppb
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	07-JUN-16	1.540	ppb
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	07-JUN-16	1.410	ppb
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	07-JUN-16	1.500	ppb
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	22-APR-22	1.180	ug/L
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	22-APR-22	1.160	ug/L
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	22-APR-22	1.230	ug/L
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Flush180	22-APR-22	1.400	ug/L
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Initial	07-JUN-16	1.580	ppb
51434	51434-2-HAL-F01	Main- By Room 206, Left Fountain	Initial	22-APR-22	2.130	ug/L
51434	51434-2-HAL-F04	Main- By Room 206, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-F04	Main- By Room 206, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-F04	Main- By Room 206, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-F04	Main- By Room 206, Right Fountain	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-F04	Main- By Room 206, Right Fountain	Initial	22-APR-22	1.000	ug/L
51434	51434-2-HAL-F02	Main- By room 203 North, Fountain 1	Flush180	07-JUN-16	0.627	ppb
51434	51434-2-HAL-F02	Main- By room 203 North, Fountain 1	Flush180	07-JUN-16	0.607	ppb
51434	51434-2-HAL-F02	Main- By room 203 North, Fountain 1	Flush180	07-JUN-16	0.534	ppb
51434	51434-2-HAL-F02	Main- By room 203 North, Fountain 1	Flush180	07-JUN-16	0.585	ppb
51434	51434-2-HAL-F02	Main- By room 203 North, Fountain 1	Initial	07-JUN-16	0.725	ppb
51434	51434-2-HAL-F03	Main- By room 203 South, Fountain 2	Flush180	07-JUN-16	0.393	ppb
51434	51434-2-HAL-F03	Main- By room 203 South, Fountain 2	Flush180	07-JUN-16	0.521	ppb
51434	51434-2-HAL-F03	Main- By room 203 South, Fountain 2	Flush180	07-JUN-16	0.437	ppb
51434	51434-2-HAL-F03	Main- By room 203 South, Fountain 2	Flush180	07-JUN-16	0.409	ppb
51434	51434-2-HAL-F03	Main- By room 203 South, Fountain 2	Initial	07-JUN-16	1.120	ppb
51434	51434-2-HAL-RBF01	Main- By room 203 South, Right Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-RBF01	Main- By room 203 South, Right Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-RBF01	Main- By room 203 South, Right Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-RBF01	Main- By room 203 South, Right Retrofit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
51434	51434-2-HAL-RBF01	Main- By room 203 South, Right Retrofit Bottle Filler	Initial	22-APR-22	1.000	ug/L
52445	52445-1-HAL-F07	Annex- First Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.820	ppb
52445	52445-1-HAL-F07	Annex- First Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.446	ppb
52445	52445-1-HAL-F07	Annex- First Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.563	ppb
52445	52445-1-HAL-F07	Annex- First Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.560	ppb
52445	52445-1-HAL-	Annex- First Floor Outside	Initial	07-JUN-16	0.906	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07	Bathroom East, Fountain				
52445	52445-1-HAL-RBF01	Annex- First Floor Outside Bathroom East, RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-HAL-RBF01	Annex- First Floor Outside Bathroom East, RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-HAL-RBF01	Annex- First Floor Outside Bathroom East, RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-HAL-RBF01	Annex- First Floor Outside Bathroom East, RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-HAL-RBF01	Annex- First Floor Outside Bathroom East, RetroFit Bottle Filler	Initial	22-APR-22	1.000	ug/L
52445	52445-1-HAL-F08	Annex- First Floor Outside Bathroom West, Fountain	Flush180	07-JUN-16	0.530	ppb
52445	52445-1-HAL-F08	Annex- First Floor Outside Bathroom West, Fountain	Flush180	07-JUN-16	0.543	ppb
52445	52445-1-HAL-F08	Annex- First Floor Outside Bathroom West, Fountain	Flush180	07-JUN-16	0.512	ppb
52445	52445-1-HAL-F08	Annex- First Floor Outside Bathroom West, Fountain	Flush180	07-JUN-16	0.552	ppb
52445	52445-1-HAL-F08	Annex- First Floor Outside Bathroom West, Fountain	Initial	07-JUN-16	0.667	ppb
52445	52445-1-113-S06	Annex- Inside Room 113, Sink	Flush180	07-JUN-16	1.550	ppb
52445	52445-1-113-S06	Annex- Inside Room 113, Sink	Flush180	07-JUN-16	2.570	ppb
52445	52445-1-113-S06	Annex- Inside Room 113, Sink	Flush180	07-JUN-16	2.920	ppb
52445	52445-1-113-S06	Annex- Inside Room 113, Sink	Flush180	07-JUN-16	2.780	ppb
52445	52445-1-113-S06	Annex- Inside Room 113, Sink	Initial	07-JUN-16	4.940	ppb
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Initial	28-SEP-21	1.000	ug/L
52445	52445-1-114-F01	Annex- Inside Room 114, Fountain	Initial	22-APR-22	1.000	ug/L
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	07-JUN-16	0.506	ppb
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	07-JUN-16	0.502	ppb
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	07-JUN-16	0.504	ppb
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	07-JUN-16	0.499	ppb
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Initial	07-JUN-16	0.766	ppb
52445	52445-1-114-S05	Annex- Inside Room 114, Sink	Initial	22-APR-22	1.290	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S05					
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Initial	28-SEP-21	1.000	ug/L
52445	52445-1-118-F01	Annex- Inside Room 118, Fountain	Initial	22-APR-22	1.000	ug/L
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	07-JUN-16	1.730	ppb
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	07-JUN-16	1.560	ppb
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	07-JUN-16	1.590	ppb
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	07-JUN-16	1.530	ppb
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Initial	07-JUN-16	5.600	ppb
52445	52445-1-118-S04	Annex- Inside Room 118, Sink	Initial	22-APR-22	1.130	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	28-SEP-21	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Initial	28-SEP-21	1.000	ug/L
52445	52445-1-119-S01	Annex- Inside Room 119, Fountain	Initial	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS04	Annex- Kitchen Table Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS04	Annex- Kitchen Table Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS04	Annex- Kitchen Table Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS04	Annex- Kitchen Table Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS04	Annex- Kitchen Table Sink	Initial	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	07-JUN-16	0.892	ppb
52445	52445-1-KIT-	Annex- Kitchen West, Center Sink	Flush180	07-JUN-16	1.110	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02					
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	07-JUN-16	2.050	ppb
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	07-JUN-16	1.600	ppb
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Initial	07-JUN-16	0.670	ppb
52445	52445-1-KIT-KS02	Annex- Kitchen West, Center Sink	Initial	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS01	Annex- Kitchen West, Left Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS01	Annex- Kitchen West, Left Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS01	Annex- Kitchen West, Left Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS01	Annex- Kitchen West, Left Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS01	Annex- Kitchen West, Left Sink	Initial	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	07-JUN-16	1.960	ppb
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	07-JUN-16	0.395	ppb
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	07-JUN-16	0.509	ppb
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	07-JUN-16	0.409	ppb
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Flush180	22-APR-22	1.000	ug/L
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Initial	07-JUN-16	0.870	ppb
52445	52445-1-KIT-KS03	Annex- Kitchen West, Right Sink	Initial	22-APR-22	1.000	ug/L
52445	52445-2-HAL-F01	Annex- Second Floor Outside Bathroom East, Fountai	Flush180	07-JUN-16	0.332	ppb
52445	52445-2-HAL-F01	Annex- Second Floor Outside Bathroom East, Fountai	Flush180	07-JUN-16	1.000	ppb
52445	52445-2-HAL-F01	Annex- Second Floor Outside Bathroom East, Fountai	Flush180	07-JUN-16	0.515	ppb
52445	52445-2-HAL-F01	Annex- Second Floor Outside Bathroom East, Fountai	Flush180	07-JUN-16	0.339	ppb
52445	52445-2-HAL-F01	Annex- Second Floor Outside Bathroom East, Fountai	Initial	07-JUN-16	0.399	ppb
52445	52445-2-HAL-RBF01	Annex- Second Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-2-HAL-RBF01	Annex- Second Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-2-HAL-RBF01	Annex- Second Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-2-HAL-RBF01	Annex- Second Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-2-HAL-RBF01	Annex- Second Floor Outside Bathroom, Left RetroFit Bottle Filler	Initial	22-APR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
		Filler				
52445	52445-3-HAL-F01	Annex- Third Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.571	ppb
52445	52445-3-HAL-F01	Annex- Third Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.567	ppb
52445	52445-3-HAL-F01	Annex- Third Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.574	ppb
52445	52445-3-HAL-F01	Annex- Third Floor Outside Bathroom East, Fountain	Flush180	07-JUN-16	0.558	ppb
52445	52445-3-HAL-F01	Annex- Third Floor Outside Bathroom East, Fountain	Initial	07-JUN-16	0.697	ppb
52445	52445-3-HAL-RBF01	Annex- Third Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-RBF01	Annex- Third Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-RBF01	Annex- Third Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-RBF01	Annex- Third Floor Outside Bathroom, Left RetroFit Bottle Filler	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-RBF01	Annex- Third Floor Outside Bathroom, Left RetroFit Bottle Filler	Initial	22-APR-22	1.000	ug/L
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	07-JUN-16	0.586	ppb
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	07-JUN-16	0.626	ppb
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	07-JUN-16	0.595	ppb
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	07-JUN-16	0.602	ppb
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Flush180	22-APR-22	1.000	ug/L
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Initial	07-JUN-16	0.846	ppb
52445	52445-3-HAL-F02	Annex- Third Floor Outside Bathroom, Right Fountain	Initial	22-APR-22	1.000	ug/L