



**Sep 10, 2024**

**FRAZIER PROSPECTIVE**

**4027 W GRENSHAW ST, Chicago IL 60624.**

Dear **FRAZIER PROSPECTIVE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**FRAZIER PROSPECTIVE**

**4027 W GRENSHAW ST, Chicago IL 60624.**

Estimadas familias de **FRAZIER PROSPECTIVE:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anejo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51222	51222-1-107-S01	107 Pre-k	Flush180	22-SEP-16	1.600	ppb
51222	51222-1-107-S01	107 Pre-k	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-107-S01	107 Pre-k	Flush180	22-SEP-16	1.200	ppb
51222	51222-1-107-S01	107 Pre-k	Flush180	22-SEP-16	1.700	ppb
51222	51222-1-107-S01	107 Pre-k	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-107-S01	107 Pre-k	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-107-S01	107 Pre-k	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-107-S01	107 Pre-k	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-107-S01	107 Pre-k	Initial	22-SEP-16	1.700	ppb
51222	51222-1-107-S01	107 Pre-k	Initial	24-FEB-23	1.000	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	31-MAY-23	1.000	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	31-MAY-23	1.000	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	31-MAY-23	1.000	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	31-MAY-23	1.000	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	22-SEP-16	9.500	ppb
51222	51222-1-109-S01	109 Pre-k	Flush180	22-SEP-16	1.500	ppb
51222	51222-1-109-S01	109 Pre-k	Flush180	22-SEP-16	1.800	ppb
51222	51222-1-109-S01	109 Pre-k	Flush180	22-SEP-16	2.000	ppb
51222	51222-1-109-S01	109 Pre-k	Flush180	24-FEB-23	5.700	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	24-FEB-23	5.450	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	24-FEB-23	4.810	ug/L
51222	51222-1-109-S01	109 Pre-k	Flush180	24-FEB-23	8.160	ug/L
51222	51222-1-109-S01	109 Pre-k	Initial	31-MAY-23	2.540	ug/L
51222	51222-1-109-S01	109 Pre-k	Initial	22-SEP-16	2.400	ppb
51222	51222-1-109-S01	109 Pre-k	Initial	24-FEB-23	7.540	ug/L
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	22-SEP-16	0.370	ppb
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	22-SEP-16	0.360	ppb
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	22-SEP-16	0.330	ppb
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	22-SEP-16	0.390	ppb
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	24-FEB-23	3.320	ug/L
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	24-FEB-23	3.370	ug/L
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	24-FEB-23	3.060	ug/L
51222	51222-1-HAL-F03	Across 111 Left Fountain	Flush180	24-FEB-23	3.140	ug/L
51222	51222-1-HAL-F03	Across 111 Left Fountain	Initial	22-SEP-16	0.400	ppb
51222	51222-1-HAL-F03	Across 111 Left Fountain	Initial	24-FEB-23	3.380	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	22-SEP-16	0.350	ppb
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	22-SEP-16	0.420	ppb
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	22-SEP-16	0.310	ppb
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	22-SEP-16	0.460	ppb
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	24-FEB-23	3.080	ug/L
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	24-FEB-23	3.280	ug/L
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	24-FEB-23	2.520	ug/L
51222	51222-1-HAL-F02	Across 111 Right Fountain	Flush180	24-FEB-23	3.130	ug/L
51222	51222-1-HAL-F02	Across 111 Right Fountain	Initial	22-SEP-16	0.440	ppb
51222	51222-1-HAL-F02	Across 111 Right Fountain	Initial	24-FEB-23	2.060	ug/L
51222	51222-2-HAL-F01	Across 206	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F01	Across 206	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F01	Across 206	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F01	Across 206	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F01	Across 206	Flush180	30-JUL-20	1.000	ug/L
51222	51222-2-HAL-F01	Across 206	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F01	Across 206	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F01	Across 206	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F01	Across 206	Initial	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F01	Across 206	Initial	30-JUL-20	1.000	ug/L
51222	51222-2-HAL-F01	Across 206	Initial	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-BF01	Across 206 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-BF01	Across 206 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-BF01	Across 206 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-BF01	Across 206 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-BF01	Across 206 Bottle Filler	Initial	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F02	Across 206 Right Fountain	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F02	Across 206 Right Fountain	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F02	Across 206 Right Fountain	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F02	Across 206 Right Fountain	Flush180	22-SEP-16	1.000	ppb
51222	51222-2-HAL-F02	Across 206 Right Fountain	Initial	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F01	Across 306	Flush180	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F01	Across 306	Flush180	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F01	Across 306	Flush180	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F01	Across 306	Flush180	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F01	Across 306	Flush180	24-FEB-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51222	51222-3-HAL-F01	Across 306	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-F01	Across 306	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-F01	Across 306	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-F01	Across 306	Initial	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F01	Across 306	Initial	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-BF01	Across 306 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-BF01	Across 306 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-BF01	Across 306 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-BF01	Across 306 Bottle Filler	Flush180	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-BF01	Across 306 Bottle Filler	Initial	24-FEB-23	1.000	ug/L
51222	51222-3-HAL-F02	Across 306 Right Fountain	Flush180	22-SEP-16	1.000	ppb
51222	51222-3-HAL-F02	Across 306 Right Fountain	Flush180	22-SEP-16	0.230	ppb
51222	51222-3-HAL-F02	Across 306 Right Fountain	Flush180	22-SEP-16	0.190	ppb
51222	51222-3-HAL-F02	Across 306 Right Fountain	Flush180	22-SEP-16	0.210	ppb
51222	51222-3-HAL-F02	Across 306 Right Fountain	Initial	22-SEP-16	0.160	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	22-SEP-16	17.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	22-SEP-16	19.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	22-SEP-16	22.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	22-SEP-16	15.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	24-FEB-23	1.970	ug/L
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	24-FEB-23	2.020	ug/L
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	24-FEB-23	2.010	ug/L
51222	51222-3-HAL-F03	Across 315 Left Fountain	Flush180	24-FEB-23	2.030	ug/L
51222	51222-3-HAL-F03	Across 315 Left Fountain	Initial	22-SEP-16	4.200	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Initial	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F03	Across 315 Left Fountain	Initial	24-FEB-23	2.130	ug/L
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	22-SEP-16	4.400	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	22-SEP-16	20.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	22-SEP-16	23.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	22-SEP-16	20.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	21-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	24-FEB-23	1.890	ug/L
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	24-FEB-23	1.890	ug/L
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	24-FEB-23	1.940	ug/L
51222	51222-3-HAL-F04	Across 315 Right Fountain	Flush180	24-FEB-23	1.850	ug/L
51222	51222-3-HAL-F04	Across 315 Right Fountain	Initial	22-SEP-16	0.690	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Initial	21-OCT-16	1.000	ppb
51222	51222-3-HAL-F04	Across 315 Right Fountain	Initial	24-FEB-23	1.960	ug/L
51222	51222-1-HAL-BF01	Across from main office	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-BF01	Across from main office	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-BF01	Across from main office	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-BF01	Across from main office	Initial	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	22-SEP-16	0.480	ppb
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	22-SEP-16	0.470	ppb
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	22-SEP-16	0.440	ppb
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	22-SEP-16	0.470	ppb
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Initial	22-SEP-16	0.370	ppb
51222	51222-2-HAL-F03	Hall Across 215 Left Fountain	Initial	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	22-SEP-16	0.330	ppb
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	22-SEP-16	0.430	ppb
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	22-SEP-16	0.420	ppb
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	22-SEP-16	0.370	ppb
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Flush180	24-FEB-23	1.000	ug/L
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Initial	22-SEP-16	0.480	ppb
51222	51222-2-HAL-F04	Hall Across 215 Right Fountain	Initial	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-S01	Hall Across Main Office Left	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-S01	Hall Across Main Office Left	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-S01	Hall Across Main Office Left	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-S01	Hall Across Main Office Left	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-S01	Hall Across Main Office Left	Initial	22-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	22-SEP-16	1.000	ppb
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-F01	Hall Across Main Office Right	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-HAL-F01	Hall Across Main Office Right	Initial	22-SEP-16	1.000	ppb
51222	51222-1-HAL-F01	Hall Across Main Office Right	Initial	24-FEB-23	1.000	ug/L
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	22-SEP-16	0.210	ppb
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	22-SEP-16	0.250	ppb
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	22-SEP-16	0.250	ppb
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	22-SEP-16	0.340	ppb
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	30-JUL-20	1.000	ug/L
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	01-DEC-20	1.000	ug/L
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	01-DEC-20	1.000	ug/L
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Flush180	01-DEC-20	1.000	ug/L
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Initial	22-SEP-16	0.240	ppb
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Initial	30-JUL-20	9.800	ug/L
51222	51222-1-KIT-S01	Kitchen Left Sink on South Wall	Initial	01-DEC-20	1.640	ug/L
51222	51222-1-KIT-S02	Kitchen Middle Sink South Wall	Flush180	22-SEP-16	0.570	ppb
51222	51222-1-KIT-S02	Kitchen Middle Sink South Wall	Flush180	22-SEP-16	1.200	ppb
51222	51222-1-KIT-S02	Kitchen Middle Sink South Wall	Flush180	22-SEP-16	1.500	ppb
51222	51222-1-KIT-S02	Kitchen Middle Sink South Wall	Flush180	22-SEP-16	1.700	ppb
51222	51222-1-KIT-S02	Kitchen Middle Sink South Wall	Initial	22-SEP-16	1.200	ppb
51222	51222-1-KIT-S03	Kitchen Right Sink South Wall	Flush180	22-SEP-16	0.360	ppb
51222	51222-1-KIT-S03	Kitchen Right Sink South Wall	Flush180	22-SEP-16	0.180	ppb
51222	51222-1-KIT-S03	Kitchen Right Sink South Wall	Flush180	22-SEP-16	0.170	ppb
51222	51222-1-KIT-S03	Kitchen Right Sink South Wall	Flush180	22-SEP-16	0.160	ppb
51222	51222-1-KIT-S03	Kitchen Right Sink South Wall	Initial	22-SEP-16	0.420	ppb
51222	51222-1-111-F01	Pre-k 111	Flush180	22-SEP-16	0.930	ppb
51222	51222-1-111-F01	Pre-k 111	Flush180	22-SEP-16	0.960	ppb
51222	51222-1-111-F01	Pre-k 111	Flush180	22-SEP-16	1.400	ppb
51222	51222-1-111-F01	Pre-k 111	Flush180	22-SEP-16	2.700	ppb
51222	51222-1-111-F01	Pre-k 111	Flush180	24-FEB-23	1.110	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51222	51222-1-111-F01	Pre-k 111	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-F01	Pre-k 111	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-F01	Pre-k 111	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-F01	Pre-k 111	Initial	22-SEP-16	13.000	ppb
51222	51222-1-111-F01	Pre-k 111	Initial	24-FEB-23	1.190	ug/L
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	22-SEP-16	1.200	ppb
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	22-SEP-16	1.100	ppb
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	22-SEP-16	0.920	ppb
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	22-SEP-16	1.100	ppb
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-S01	Pre-k 111 Left Sink	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-S01	Pre-k 111 Left Sink	Initial	22-SEP-16	1.800	ppb
51222	51222-1-111-S01	Pre-k 111 Left Sink	Initial	24-FEB-23	1.000	ug/L
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	22-SEP-16	0.550	ppb
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	22-SEP-16	0.340	ppb
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	22-SEP-16	0.250	ppb
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	22-SEP-16	0.340	ppb
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	24-FEB-23	1.260	ug/L
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	24-FEB-23	1.260	ug/L
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-S02	Pre-k 111 Right Sink	Flush180	24-FEB-23	1.000	ug/L
51222	51222-1-111-S02	Pre-k 111 Right Sink	Initial	22-SEP-16	0.590	ppb
51222	51222-1-111-S02	Pre-k 111 Right Sink	Initial	24-FEB-23	1.950	ug/L
51222	51222-1-KIT-S04	Single Sink, Next to Serving Line	Flush180	22-SEP-16	1.500	ppb
51222	51222-1-KIT-S04	Single Sink, Next to Serving Line	Flush180	22-SEP-16	0.570	ppb
51222	51222-1-KIT-S04	Single Sink, Next to Serving Line	Flush180	22-SEP-16	1.700	ppb
51222	51222-1-KIT-S04	Single Sink, Next to Serving Line	Flush180	22-SEP-16	0.690	ppb
51222	51222-1-KIT-S04	Single Sink, Next to Serving Line	Initial	22-SEP-16	0.500	ppb
51222	51222-1-KIT-S05	Sprayer/Pot Filler	Flush180	22-SEP-16	0.260	ppb
51222	51222-1-KIT-S05	Sprayer/Pot Filler	Flush180	22-SEP-16	0.410	ppb
51222	51222-1-KIT-S05	Sprayer/Pot Filler	Flush180	22-SEP-16	0.230	ppb
51222	51222-1-KIT-S05	Sprayer/Pot Filler	Flush180	22-SEP-16	0.210	ppb
51222	51222-1-KIT-S05	Sprayer/Pot Filler	Initial	22-SEP-16	0.300	ppb