



Nov 15, 2023

FULLER

4214 S ST LAWRENCE AVE, Chicago IL 60653.

Dear **FULLER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb. These fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Nov 15, 2023

FULLER

4214 S ST LAWRENCE AVE, Chicago IL 60653.

Estimadas familias de **FULLER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	31-AUG-19	1.930	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	31-AUG-19	2.320	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	31-AUG-19	1.840	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	31-AUG-19	1.740	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Initial	31-AUG-19	6.070	ug/L
51351	51351-1-N-105-S01	1st Floor, North End, Room 105	Initial	05-NOV-19	1.000	ug/L
51351	51351-1-HAL-F09	Across From Room 108 (Center), Fountain 2	Flush180	18-JUN-16	0.598	ppb
51351	51351-1-HAL-F09	Across From Room 108 (Center), Fountain 2	Flush180	18-JUN-16	0.622	ppb
51351	51351-1-HAL-F09	Across From Room 108 (Center), Fountain 2	Flush180	18-JUN-16	0.598	ppb
51351	51351-1-HAL-F09	Across From Room 108 (Center), Fountain 2	Flush180	18-JUN-16	0.683	ppb
51351	51351-1-HAL-F09	Across From Room 108 (Center), Fountain 2	Initial	18-JUN-16	0.528	ppb
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	18-JUN-16	0.997	ppb
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	18-JUN-16	0.893	ppb
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	18-JUN-16	1.070	ppb
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	18-JUN-16	0.910	ppb
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Initial	18-JUN-16	0.828	ppb
51351	51351-1-W-HAL-F08	Across From Room 108 (North), Fountain 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-2-HAL-F05	Across From Room 208 (Center), Fountain 2	Flush180	18-JUN-16	0.354	ppb
51351	51351-2-HAL-F05	Across From Room 208 (Center), Fountain 2	Flush180	18-JUN-16	0.311	ppb
51351	51351-2-HAL-F05	Across From Room 208 (Center), Fountain 2	Flush180	18-JUN-16	0.340	ppb
51351	51351-2-HAL-F05	Across From Room 208 (Center), Fountain 2	Flush180	18-JUN-16	0.308	ppb
51351	51351-2-HAL-F05	Across From Room 208 (Center), Fountain 2	Initial	18-JUN-16	0.330	ppb
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	18-JUN-16	0.485	ppb
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	18-JUN-16	0.740	ppb
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	18-JUN-16	0.493	ppb
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	18-JUN-16	0.610	ppb
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Initial	18-JUN-16	0.794	ppb
51351	51351-2-W-HAL-F04	Across From Room 208 (North), Fountain 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	18-JUN-16	0.307	ppb
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	18-JUN-16	0.311	ppb
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	18-JUN-16	0.314	ppb
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	18-JUN-16	0.318	ppb
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	05-NOV-19	1.070	ug/L
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Initial	18-JUN-16	0.308	ppb
51351	51351-2-W-HAL-F06	Across From Room 208 (South), Fountain 3	Initial	05-NOV-19	1.000	ug/L
51351	51351-3-HAL-F05	Across From Room 308 (Center), Fountain 2	Flush180	18-JUN-16	0.716	ppb
51351	51351-3-HAL-F05	Across From Room 308 (Center), Fountain 2	Flush180	18-JUN-16	0.735	ppb
51351	51351-3-HAL-F05	Across From Room 308 (Center), Fountain 2	Flush180	18-JUN-16	0.712	ppb
51351	51351-3-HAL-F05	Across From Room 308 (Center), Fountain 2	Flush180	18-JUN-16	0.735	ppb
51351	51351-3-HAL-F05	Across From Room 308 (Center), Fountain 2	Initial	18-JUN-16	0.561	ppb
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	18-JUN-16	0.623	ppb
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	18-JUN-16	1.230	ppb
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	18-JUN-16	0.880	ppb
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Flush180	18-JUN-16	1.240	ppb
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F04	Across From Room 308 (North), Fountain 1	Initial	18-JUN-16	0.265	ppb
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	18-JUN-16	0.580	ppb
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	18-JUN-16	0.512	ppb
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	18-JUN-16	0.661	ppb
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	18-JUN-16	0.676	ppb
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Initial	18-JUN-16	0.589	ppb
51351	51351-3-W-HAL-F06	Across From Room 308 (South), Fountain 3	Initial	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	18-JUN-16	0.546	ppb
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	18-JUN-16	0.549	ppb
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	18-JUN-16	0.542	ppb
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	18-JUN-16	0.508	ppb
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Initial	18-JUN-16	0.460	ppb
51351	51351-1-W-HAL-F10	Corridor Across Rm 108 (South), Fountain 3	Initial	05-NOV-19	1.000	ug/L
51351	51351-1-HAL-F02	Corridor Outside Room 107 (Center), Fountain 2	Flush180	18-JUN-16	0.623	ppb
51351	51351-1-HAL-F02	Corridor Outside Room 107 (Center), Fountain 2	Flush180	18-JUN-16	0.630	ppb
51351	51351-1-HAL-F02	Corridor Outside Room 107 (Center), Fountain 2	Flush180	18-JUN-16	0.659	ppb
51351	51351-1-HAL-F02	Corridor Outside Room 107 (Center), Fountain 2	Flush180	18-JUN-16	0.692	ppb
51351	51351-1-HAL-F02	Corridor Outside Room 107 (Center), Fountain 2	Initial	18-JUN-16	0.529	ppb
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	18-JUN-16	0.765	ppb
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	18-JUN-16	0.684	ppb
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	18-JUN-16	0.785	ppb
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	18-JUN-16	0.775	ppb
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Initial	18-JUN-16	0.736	ppb
51351	51351-1-E-HAL-F01	Corridor Outside Room 107 (North), Fountain 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	18-JUN-16	0.724	ppb
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	18-JUN-16	0.783	ppb
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	18-JUN-16	0.794	ppb
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	18-JUN-16	0.853	ppb
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Initial	18-JUN-16	0.724	ppb
51351	51351-1-E-HAL-F03	Corridor Outside Room 107 (South), Fountain 3	Initial	05-NOV-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03	(South), Fountain 3				
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	18-JUN-16	1.960	ppb
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	18-JUN-16	2.000	ppb
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	18-JUN-16	2.030	ppb
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	18-JUN-16	2.130	ppb
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	05-NOV-19	1.190	ug/L
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	05-NOV-19	1.400	ug/L
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Initial	18-JUN-16	1.720	ppb
51351	51351-1-S-107-S04	Inside Head Start Room 107, Sink	Initial	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	18-JUN-16	1.430	ppb
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	18-JUN-16	0.841	ppb
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	18-JUN-16	0.468	ppb
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	18-JUN-16	0.493	ppb
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Flush180	31-JUL-20	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Initial	18-JUN-16	1.140	ppb
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS11	Kitchen - (East Wall), Sink 1	Initial	31-JUL-20	2.990	ug/L
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	18-JUN-16	6.720	ppb
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	18-JUN-16	6.170	ppb
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	18-JUN-16	5.130	ppb
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	18-JUN-16	8.290	ppb
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Flush180	05-NOV-19	1.000	ug/L
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Initial	18-JUN-16	7.650	ppb
51351	51351-1-E-KIT-KS12	Kitchen - (South Wall) Sink 2	Initial	05-NOV-19	1.810	ug/L
51351	51351-2-HAL-F02	Outside Room 207 (Center), Fountain 2	Flush180	18-JUN-16	0.240	ppb
51351	51351-2-HAL-F02	Outside Room 207 (Center), Fountain 2	Flush180	18-JUN-16	0.204	ppb
51351	51351-2-HAL-F02	Outside Room 207 (Center), Fountain 2	Flush180	18-JUN-16	0.177	ppb
51351	51351-2-HAL-F02	Outside Room 207 (Center), Fountain 2	Flush180	18-JUN-16	0.168	ppb
51351	51351-2-HAL-	Outside Room 207 (Center),	Initial	18-JUN-16	0.241	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain 2				
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	18-JUN-16	0.240	ppb
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	18-JUN-16	0.229	ppb
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	18-JUN-16	0.241	ppb
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	18-JUN-16	0.326	ppb
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	05-NOV-19	1.300	ug/L
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	05-NOV-19	1.910	ug/L
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Flush180	05-NOV-19	1.110	ug/L
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Initial	18-JUN-16	0.269	ppb
51351	51351-2-E-HAL-F01	Outside Room 207 (North), Fountain 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	18-JUN-16	0.313	ppb
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	18-JUN-16	0.290	ppb
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	18-JUN-16	0.283	ppb
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	18-JUN-16	0.280	ppb
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	05-NOV-19	1.940	ug/L
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	05-NOV-19	1.350	ug/L
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	05-NOV-19	1.010	ug/L
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Flush180	05-NOV-19	1.310	ug/L
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Initial	18-JUN-16	0.341	ppb
51351	51351-2-E-HAL-F03	Outside Room 207 (South), Fountain 3	Initial	05-NOV-19	1.000	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	18-JUN-16	0.848	ppb
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	18-JUN-16	0.826	ppb
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	18-JUN-16	0.782	ppb
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	31-JUL-20	4.600	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	29-SEP-20	1.000	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	29-SEP-20	1.000	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	29-SEP-20	1.010	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	29-SEP-20	1.000	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Flush180	18-JUN-16	0.834	ppb
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Initial	18-JUN-16	0.625	ppb
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Initial	31-JUL-20	9.250	ug/L
51351	51351-3-HAL-F02	Outside Room 307 (Center), Fountain 2	Initial	29-SEP-20	1.000	ug/L
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	18-JUN-16	0.746	ppb
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	18-JUN-16	0.782	ppb
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	18-JUN-16	0.698	ppb
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	18-JUN-16	0.614	ppb
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	05-NOV-19	1.020	ug/L
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Initial	18-JUN-16	0.463	ppb
51351	51351-3-E-HAL-F01	Outside Room 307 (North), Fountain 1	Initial	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	05-NOV-19	1.010	ug/L
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	18-JUN-16	0.603	ppb
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	18-JUN-16	0.535	ppb
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	18-JUN-16	0.471	ppb
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Flush180	18-JUN-16	0.396	ppb
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Initial	05-NOV-19	1.000	ug/L
51351	51351-3-E-HAL-F03	Outside Room 307 (South), Fountain 3	Initial	18-JUN-16	0.528	ppb
51351	51351-1-N-105-F01	Room 105	Flush180	31-AUG-19	2.070	ug/L
51351	51351-1-N-105-F01	Room 105	Flush180	31-AUG-19	1.510	ug/L
51351	51351-1-N-105-F01	Room 105	Flush180	31-AUG-19	1.410	ug/L
51351	51351-1-N-105-F01	Room 105	Flush180	31-AUG-19	1.480	ug/L
51351	51351-1-N-105-F01	Room 105	Initial	31-AUG-19	1.560	ug/L