



**Sep 10, 2024**

**FUNSTON**

**3616 W ARMITAGE AVE, Chicago IL 60647.**

Dear **FUNSTON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**FUNSTON**

**3616 W ARMITAGE AVE, Chicago IL 60647.**

Estimadas familias de **FUNSTON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Flush180	29-JUL-20	1.000	ug/L
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Initial	29-JUL-20	1.020	ug/L
51114	51114-B-HAL-F04	Main-Basement Next to Engineers Office, Farthest Right	Initial	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F03	Main-Basement Next to Engineers Office, Fountain 2, Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F03	Main-Basement Next to Engineers Office, Fountain 2, Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F03	Main-Basement Next to Engineers Office, Fountain 2, Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F03	Main-Basement Next to Engineers Office, Fountain 2, Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F03	Main-Basement Next to Engineers Office, Fountain 2, Left	Initial	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-RBF01	Main Outside Room 306, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-RBF01	Main Outside Room 306, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-RBF01	Main Outside Room 306, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-RBF01	Main Outside Room 306, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-RBF01	Main Outside Room 306, Retrofit Bottle Filler	Initial	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-RBF01	Main Outside Room 406, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-RBF01	Main Outside Room 406, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-RBF01	Main Outside Room 406, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-RBF01	Main Outside Room 406, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-RBF01	Main Outside Room 406, Retrofit Bottle Filler	Initial	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-RBF01	Main Outside Room 506, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-RBF01	Main Outside Room 506, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-RBF01	Main Outside Room 506, Retrofit Bottle Filler	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-RBF01	Main Outside Room 506, Retrofit Bottle Filler	Initial	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F01	Main- Basement Next to Engineers Office Fountain 1, Farthest Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F01	Main- Basement Next to Engineers Office Fountain 1, Farthest Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F01	Main- Basement Next to Engineers Office Fountain 1, Farthest Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F01	Main- Basement Next to Engineers Office Fountain 1, Farthest Left	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F01	Main- Basement Next to Engineers Office Fountain 1, Farthest Left	Initial	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F01	Main- Basement Next to Engineers Office Fountain 1, Farthest Left	Flush180	03-MAR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Office Fountain 1, Right				
51114	51114-B-HAL-F02	Main- Basement Next to Engineers Office Fountain 1, Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F02	Main- Basement Next to Engineers Office Fountain 1, Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F02	Main- Basement Next to Engineers Office Fountain 1, Right	Flush180	03-MAR-23	1.000	ug/L
51114	51114-B-HAL-F02	Main- Basement Next to Engineers Office Fountain 1, Right	Initial	03-MAR-23	1.000	ug/L
51114	51114-B-KIT-KS01	Main- Kitchen, Sink 1	Flush180	04-JUN-16	0.989	ppb
51114	51114-B-KIT-KS01	Main- Kitchen, Sink 1	Flush180	04-JUN-16	2.990	ppb
51114	51114-B-KIT-KS01	Main- Kitchen, Sink 1	Flush180	04-JUN-16	0.897	ppb
51114	51114-B-KIT-KS01	Main- Kitchen, Sink 1	Flush180	04-JUN-16	2.080	ppb
51114	51114-B-KIT-KS01	Main- Kitchen, Sink 1	Initial	04-JUN-16	8.890	ppb
51114	51114-B-KIT-KS02	Main- Kitchen, Sink 2	Flush180	04-JUN-16	1.490	ppb
51114	51114-B-KIT-KS02	Main- Kitchen, Sink 2	Flush180	04-JUN-16	2.310	ppb
51114	51114-B-KIT-KS02	Main- Kitchen, Sink 2	Flush180	04-JUN-16	1.660	ppb
51114	51114-B-KIT-KS02	Main- Kitchen, Sink 2	Flush180	04-JUN-16	1.520	ppb
51114	51114-B-KIT-KS02	Main- Kitchen, Sink 2	Initial	04-JUN-16	2.390	ppb
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	04-JUN-16	3.420	ppb
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	04-JUN-16	2.880	ppb
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	04-JUN-16	2.460	ppb
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	04-JUN-16	4.310	ppb
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	03-MAR-23	2.000	ug/L
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	03-MAR-23	2.200	ug/L
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	03-MAR-23	1.900	ug/L
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Flush180	03-MAR-23	2.100	ug/L
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Initial	04-JUN-16	4.440	ppb
51114	51114-B-CAF-F03	Main- Lunchroom, Fountain 1	Initial	03-MAR-23	1.600	ug/L
51114	51114-B-CAF-F04	Main- Lunchroom, Fountain 2	Flush180	04-JUN-16	2.380	ppb
51114	51114-B-CAF-F04	Main- Lunchroom, Fountain 2	Flush180	04-JUN-16	2.410	ppb
51114	51114-B-CAF-F04	Main- Lunchroom, Fountain 2	Flush180	04-JUN-16	3.150	ppb
51114	51114-B-CAF-F04	Main- Lunchroom, Fountain 2	Flush180	04-JUN-16	3.570	ppb
51114	51114-B-CAF-F04	Main- Lunchroom, Fountain 2	Initial	04-JUN-16	5.440	ppb
51114	51114-B-CAF-F05	Main- Lunchroom, Fountain 3	Flush180	04-JUN-16	0.515	ppb
51114	51114-B-CAF-F05	Main- Lunchroom, Fountain 3	Flush180	04-JUN-16	0.545	ppb
51114	51114-B-CAF-F05	Main- Lunchroom, Fountain 3	Flush180	04-JUN-16	0.581	ppb
51114	51114-B-CAF-F05	Main- Lunchroom, Fountain 3	Flush180	04-JUN-16	0.707	ppb
51114	51114-B-CAF-F05	Main- Lunchroom, Fountain 3	Initial	04-JUN-16	1.240	ppb
51114	51114-B-CAF-F06	Main- Lunchroom, Fountain 4	Flush180	04-JUN-16	0.957	ppb
51114	51114-B-CAF-F06	Main- Lunchroom, Fountain 4	Flush180	04-JUN-16	0.797	ppb
51114	51114-B-CAF-F06	Main- Lunchroom, Fountain 4	Flush180	04-JUN-16	1.200	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06					
51114	51114-B-CAF-F06	Main- Lunchroom, Fountain 4	Flush180	04-JUN-16	0.766	ppb
51114	51114-B-CAF-F06	Main- Lunchroom, Fountain 4	Initial	04-JUN-16	1.370	ppb
51114	51114-B-CAF-RBF01	Main- Lunchroom, Retrofit BF	Flush180	03-MAR-23	1.900	ug/L
51114	51114-B-CAF-RBF01	Main- Lunchroom, Retrofit BF	Flush180	03-MAR-23	1.900	ug/L
51114	51114-B-CAF-RBF01	Main- Lunchroom, Retrofit BF	Flush180	03-MAR-23	1.800	ug/L
51114	51114-B-CAF-RBF01	Main- Lunchroom, Retrofit BF	Flush180	03-MAR-23	1.700	ug/L
51114	51114-B-CAF-RBF01	Main- Lunchroom, Retrofit BF	Initial	03-MAR-23	1.600	ug/L
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	04-JUN-16	0.939	ppb
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	04-JUN-16	0.279	ppb
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	04-JUN-16	0.241	ppb
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	04-JUN-16	0.523	ppb
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Initial	04-JUN-16	0.584	ppb
51114	51114-1-HAL-F01	Main- Outside Room 306, Fountain	Initial	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	04-JUN-16	1.980	ppb
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	04-JUN-16	0.940	ppb
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	04-JUN-16	2.370	ppb
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	04-JUN-16	2.240	ppb
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Initial	04-JUN-16	0.730	ppb
51114	51114-2-HAL-F01	Main- Outside Room 406, Fountain	Initial	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	04-JUN-16	2.280	ppb
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	04-JUN-16	1.530	ppb
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	04-JUN-16	2.070	ppb
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	04-JUN-16	2.120	ppb
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	29-JUL-20	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Flush180	03-MAR-23	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Initial	04-JUN-16	1.300	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Initial	29-JUL-20	1.000	ug/L
51114	51114-3-HAL-F01	Main- Outside Room 506, Fountain	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	04-JUN-16	0.863	ppb
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	04-JUN-16	0.937	ppb
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	04-JUN-16	0.818	ppb
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	04-JUN-16	0.510	ppb
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Initial	04-JUN-16	1.200	ppb
54119	54119-1-101-S13	Addition- Inside Room 101, Sink 1	Initial	03-MAR-23	1.100	ug/L
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	04-JUN-16	9.700	ppb
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	04-JUN-16	6.700	ppb
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	04-JUN-16	4.660	ppb
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	04-JUN-16	8.490	ppb
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Initial	04-JUN-16	4.950	ppb
54119	54119-1-101-S14	Addition- Inside Room 101, Sink 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	25-AUG-16	1.000	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	25-AUG-16	1.000	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	04-JUN-16	1.220	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	04-JUN-16	1.890	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	04-JUN-16	2.540	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	25-AUG-16	1.000	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	04-JUN-16	1.520	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	25-AUG-16	1.000	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Initial	04-JUN-16	16.000	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Initial	25-AUG-16	1.000	ppb
54119	54119-1-102-S11	Addition- Inside Room 102, Sink 1	Initial	03-MAR-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	04-JUN-16	0.961	ppb
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	04-JUN-16	1.440	ppb
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	04-JUN-16	1.420	ppb
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	04-JUN-16	0.833	ppb
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Initial	04-JUN-16	4.980	ppb
54119	54119-1-102-S12	Addition- Inside Room 102, Sink 2	Initial	03-MAR-23	1.600	ug/L
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	04-JUN-16	0.497	ppb
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	04-JUN-16	0.538	ppb
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	04-JUN-16	0.245	ppb
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Initial	04-JUN-16	0.617	ppb
54119	54119-1-103-S09	Addition- Inside Room 103, Sink 1	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Initial	04-JUN-16	0.184	ppb
54119	54119-1-103-S10	Addition- Inside Room 103, Sink 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	04-JUN-16	0.485	ppb
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	04-JUN-16	0.881	ppb
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	04-JUN-16	0.466	ppb
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	04-JUN-16	0.451	ppb
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Flush180	03-MAR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S05					
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Initial	04-JUN-16	2.490	ppb
54119	54119-1-104-S05	Addition- Inside Room 104, Sink 1	Initial	03-MAR-23	1.300	ug/L
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Initial	04-JUN-16	0.597	ppb
54119	54119-1-104-S06	Addition- Inside Room 104, Sink 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Initial	04-JUN-16	0.498	ppb
54119	54119-1-105-S03	Addition- Inside Room 105, Sink 1	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	04-JUN-16	0.198	ppb
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	04-JUN-16	0.199	ppb
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	04-JUN-16	0.589	ppb
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	04-JUN-16	0.223	ppb
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Initial	04-JUN-16	0.238	ppb
54119	54119-1-105-S04	Addition- Inside Room 105, Sink 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	04-JUN-16	0.154	ppb
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	04-JUN-16	0.306	ppb
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	04-JUN-16	0.227	ppb
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	04-JUN-16	0.259	ppb
54119	54119-2-205-	Addition- Inside Room 205, Sink	Flush180	03-MAR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S03					
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Initial	04-JUN-16	0.479	ppb
54119	54119-2-205-S03	Addition- Inside Room 205, Sink	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	04-JUN-16	0.143	ppb
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	04-JUN-16	0.330	ppb
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	04-JUN-16	0.266	ppb
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	04-JUN-16	0.271	ppb
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Initial	04-JUN-16	0.505	ppb
54119	54119-1-KIT-KS01	Addition- Kitchen, Sink 1	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	04-JUN-16	0.655	ppb
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	04-JUN-16	0.601	ppb
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	04-JUN-16	1.610	ppb
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	04-JUN-16	0.394	ppb
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Initial	04-JUN-16	0.579	ppb
54119	54119-1-KIT-KS02	Addition- Kitchen, Sink 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-F07	Addition- Outside Room 108, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-HAL-F07	Addition- Outside Room 108, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-HAL-F07	Addition- Outside Room 108, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-HAL-F07	Addition- Outside Room 108, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-1-HAL-F07	Addition- Outside Room 108, Fountain 1	Initial	04-JUN-16	1.000	ppb
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	04-JUN-16	0.142	ppb
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	04-JUN-16	0.154	ppb
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	04-JUN-16	0.177	ppb
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	04-JUN-16	0.213	ppb
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	29-JUL-20	1.000	ug/L
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Initial	04-JUN-16	0.377	ppb
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Initial	29-JUL-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-F08	Addition- Outside Room 108, Fountain 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-RBF01	Addition- Outside Room 108, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-RBF01	Addition- Outside Room 108, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-RBF01	Addition- Outside Room 108, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-RBF01	Addition- Outside Room 108, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-1-HAL-RBF01	Addition- Outside Room 108, Retrofit BF	Initial	03-MAR-23	1.000	ug/L
54119	54119-2-HALF02	Addition- Outside Room 205, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HALF02	Addition- Outside Room 205, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HALF02	Addition- Outside Room 205, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HALF02	Addition- Outside Room 205, Fountain 2	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HALF02	Addition- Outside Room 205, Fountain 2	Initial	03-MAR-23	1.000	ug/L
54119	54119-2-HAL-F01	Addition- Ououtside Room 205, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F01	Addition- Ououtside Room 205, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F01	Addition- Ououtside Room 205, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F01	Addition- Ououtside Room 205, Fountain 1	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F01	Addition- Ououtside Room 205, Fountain 1	Initial	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Flush180	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Flush180	29-JUL-20	1.000	ug/L
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Initial	04-JUN-16	1.000	ppb
54119	54119-2-HAL-F02	Addition- Ououtside Room 205, Fountain 2	Initial	29-JUL-20	1.000	ug/L
54119	54119-2-HAL-RBF01	Addition- Ououtside Room 205, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HAL-RBF01	Addition- Ououtside Room 205, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HAL-RBF01	Addition- Ououtside Room 205, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HAL-RBF01	Addition- Ououtside Room 205, Retrofit BF	Flush180	03-MAR-23	1.000	ug/L
54119	54119-2-HAL-RBF01	Addition- Ououtside Room 205, Retrofit BF	Initial	03-MAR-23	1.000	ug/L