



Sep 10, 2024

GAGE PARK HS

5630 S ROCKWELL ST, Chicago IL 60629.

Dear **GAGE PARK HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

GAGE PARK HS

5630 S ROCKWELL ST, Chicago IL 60629.

Estimadas familias de **GAGE PARK HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	04-OCT-16	0.260	ppb
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	04-OCT-16	0.240	ppb
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	04-OCT-16	0.280	ppb
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	04-OCT-16	0.210	ppb
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	04-OCT-16	0.600	ppb
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	04-OCT-16	0.330	ppb
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	04-OCT-16	0.310	ppb
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	04-OCT-16	0.380	ppb
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F03	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F04	1st FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F03	1st FL Hall NE end	Initial	04-OCT-16	0.450	ppb
51609	51609-1-HAL-F04	1st FL Hall NE end	Initial	04-OCT-16	1.600	ppb
51609	51609-1-HAL-F03	1st FL Hall NE end	Initial	19-DEC-19	1.390	ug/L
51609	51609-1-HAL-F04	1st FL Hall NE end	Initial	19-DEC-19	2.220	ug/L
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	04-OCT-16	0.360	ppb
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	04-OCT-16	0.760	ppb
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	04-OCT-16	0.630	ppb
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	04-OCT-16	0.450	ppb
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	04-OCT-16	0.350	ppb
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	04-OCT-16	0.820	ppb
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	04-OCT-16	0.710	ppb
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	04-OCT-16	0.820	ppb
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F01	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51609	51609-1-HAL-F02	1st FL Hall North end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F01	1st FL Hall North end	Initial	04-OCT-16	1.200	ppb
51609	51609-1-HAL-F02	1st FL Hall North end	Initial	04-OCT-16	1.900	ppb
51609	51609-1-HAL-F01	1st FL Hall North end	Initial	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F02	1st FL Hall North end	Initial	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	04-OCT-16	0.590	ppb
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	04-OCT-16	0.370	ppb
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	04-OCT-16	0.350	ppb
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	04-OCT-16	0.490	ppb
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	04-OCT-16	0.360	ppb
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	04-OCT-16	0.670	ppb
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	04-OCT-16	0.460	ppb
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	04-OCT-16	0.380	ppb
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	19-DEC-19	2.120	ug/L
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	19-DEC-19	1.960	ug/L
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	19-DEC-19	1.710	ug/L
51609	51609-1-HAL-F05	1st FL Hall SE end	Flush180	19-DEC-19	1.310	ug/L
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F06	1st FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F06	1st FL Hall SE end	Initial	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F05	1st FL Hall SE end	Initial	04-OCT-16	1.800	ppb
51609	51609-1-HAL-F05	1st FL Hall SE end	Initial	19-DEC-19	1.870	ug/L
51609	51609-1-HAL-F06	1st FL Hall SE end	Initial	19-DEC-19	1.040	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	04-OCT-16	2.000	ppb
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	04-OCT-16	1.800	ppb
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	04-OCT-16	3.600	ppb
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	04-OCT-16	1.200	ppb
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	04-OCT-16	1.800	ppb
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	04-OCT-16	0.710	ppb
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	04-OCT-16	0.660	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	04-OCT-16	0.660	ppb
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	04-OCT-16	0.670	ppb
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	04-OCT-16	1.700	ppb
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	04-OCT-16	1.000	ppb
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	19-DEC-19	4.910	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	19-DEC-19	3.780	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	19-DEC-19	3.100	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	19-DEC-19	5.140	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	19-DEC-19	2.470	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	19-DEC-19	2.290	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	19-DEC-19	2.250	ug/L
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F07	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	19-DEC-19	1.030	ug/L
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F08	1st FL Hall South end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	19-DEC-19	13.900	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	21-FEB-20	1.470	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	21-FEB-20	3.040	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	21-FEB-20	1.780	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	21-FEB-20	1.580	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Flush180	21-FEB-20	1.460	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	21-FEB-20	1.740	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	21-FEB-20	1.530	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Flush180	21-FEB-20	1.530	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Initial	04-OCT-16	2.200	ppb
51609	51609-1-HAL-F07	1st FL Hall South end	Initial	04-OCT-16	5.900	ppb
51609	51609-1-HAL-F08	1st FL Hall South end	Initial	04-OCT-16	0.790	ppb
51609	51609-1-HAL-F09	1st FL Hall South end	Initial	04-OCT-16	2.500	ppb
51609	51609-1-HAL-F10	1st FL Hall South end	Initial	19-DEC-19	2.460	ug/L
51609	51609-1-HAL-F07	1st FL Hall South end	Initial	19-DEC-19	1.110	ug/L
51609	51609-1-HAL-F08	1st FL Hall South end	Initial	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F09	1st FL Hall South end	Initial	19-DEC-19	1.000	ug/L
51609	51609-1-HAL-F10	1st FL Hall South end	Initial	21-FEB-20	4.200	ug/L
51609	51609-1-HAL-	1st FL Hall South end	Initial	21-FEB-20	2.460	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09					
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	04-OCT-16	0.760	ppb
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	04-OCT-16	0.360	ppb
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	04-OCT-16	0.490	ppb
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	04-OCT-16	0.330	ppb
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	04-OCT-16	0.320	ppb
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	04-OCT-16	0.420	ppb
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	04-OCT-16	0.730	ppb
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	04-OCT-16	0.270	ppb
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F01	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F02	2nd FL Hall N end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F01	2nd FL Hall N end	Initial	04-OCT-16	1.500	ppb
51609	51609-2-HAL-F02	2nd FL Hall N end	Initial	04-OCT-16	0.990	ppb
51609	51609-2-HAL-F01	2nd FL Hall N end	Initial	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F02	2nd FL Hall N end	Initial	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	04-OCT-16	0.960	ppb
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	04-OCT-16	1.200	ppb
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	04-OCT-16	1.800	ppb
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	04-OCT-16	1.600	ppb
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	04-OCT-16	1.700	ppb
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	04-OCT-16	1.700	ppb
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	04-OCT-16	1.100	ppb
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	04-OCT-16	3.000	ppb
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F03	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F04	2nd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F04	2nd FL Hall NE end	Initial	04-OCT-16	2.000	ppb

Water Quality Assessment Gage Park High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51609	51609-2-HAL-F03	2nd FL Hall NE end	Initial	04-OCT-16	1.600	ppb
51609	51609-2-HAL-F03	2nd FL Hall NE end	Initial	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F04	2nd FL Hall NE end	Initial	19-DEC-19	1.090	ug/L
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	04-OCT-16	0.440	ppb
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	04-OCT-16	0.430	ppb
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	04-OCT-16	0.390	ppb
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	04-OCT-16	0.400	ppb
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	04-OCT-16	0.440	ppb
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	04-OCT-16	0.390	ppb
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	04-OCT-16	0.420	ppb
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	04-OCT-16	0.390	ppb
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F07	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F08	2nd FL Hall S end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F07	2nd FL Hall S end	Initial	04-OCT-16	0.870	ppb
51609	51609-2-HAL-F08	2nd FL Hall S end	Initial	04-OCT-16	0.560	ppb
51609	51609-2-HAL-F07	2nd FL Hall S end	Initial	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F08	2nd FL Hall S end	Initial	19-DEC-19	1.040	ug/L
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	04-OCT-16	0.510	ppb
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	04-OCT-16	0.420	ppb
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	04-OCT-16	0.380	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	04-OCT-16	1.200	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	04-OCT-16	1.600	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	04-OCT-16	1.100	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	04-OCT-16	1.300	ppb
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	04-OCT-16	0.490	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	19-DEC-19	1.100	ug/L
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	19-DEC-19	1.160	ug/L
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	19-DEC-19	1.030	ug/L
51609	51609-2-HAL-F05	2nd FL Hall SE end	Flush180	19-DEC-19	1.260	ug/L
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	19-DEC-19	1.350	ug/L
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	19-DEC-19	1.130	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F06	2nd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-2-HAL-F06	2nd FL Hall SE end	Initial	04-OCT-16	1.200	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Initial	04-OCT-16	5.900	ppb
51609	51609-2-HAL-F05	2nd FL Hall SE end	Initial	19-DEC-19	1.600	ug/L
51609	51609-2-HAL-F06	2nd FL Hall SE end	Initial	19-DEC-19	1.210	ug/L
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	04-OCT-16	2.600	ppb
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	04-OCT-16	2.600	ppb
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	04-OCT-16	2.500	ppb
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	04-OCT-16	2.600	ppb
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	04-OCT-16	2.000	ppb
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	04-OCT-16	1.700	ppb
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	04-OCT-16	1.700	ppb
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	04-OCT-16	1.800	ppb
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	19-DEC-19	1.730	ug/L
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	19-DEC-19	1.520	ug/L
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	19-DEC-19	1.480	ug/L
51609	51609-2-HAL-F10	2nd FL Hall SW end	Flush180	19-DEC-19	1.410	ug/L
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	19-DEC-19	2.110	ug/L
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	19-DEC-19	1.800	ug/L
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	19-DEC-19	1.650	ug/L
51609	51609-2-HAL-F09	2nd FL Hall SW end	Flush180	19-DEC-19	1.420	ug/L
51609	51609-2-HAL-F09	2nd FL Hall SW end	Initial	04-OCT-16	3.600	ppb
51609	51609-2-HAL-F10	2nd FL Hall SW end	Initial	04-OCT-16	1.800	ppb
51609	51609-2-HAL-F09	2nd FL Hall SW end	Initial	19-DEC-19	2.610	ug/L
51609	51609-2-HAL-F10	2nd FL Hall SW end	Initial	19-DEC-19	1.700	ug/L
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	04-OCT-16	0.980	ppb
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	04-OCT-16	0.940	ppb
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	04-OCT-16	0.990	ppb
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	04-OCT-16	1.100	ppb
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	04-OCT-16	0.890	ppb
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	04-OCT-16	0.910	ppb
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	04-OCT-16	0.940	ppb
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	04-OCT-16	0.940	ppb
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51609	51609-3-HAL-F02	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	19-DEC-19	1.570	ug/L
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F03	3rd FL Hall NE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F02	3rd FL Hall NE end	Initial	04-OCT-16	1.200	ppb
51609	51609-3-HAL-F03	3rd FL Hall NE end	Initial	04-OCT-16	1.000	ppb
51609	51609-3-HAL-F02	3rd FL Hall NE end	Initial	19-DEC-19	1.680	ug/L
51609	51609-3-HAL-F03	3rd FL Hall NE end	Initial	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F10	3rd FL Hall NE end-Not on Wall	Flush180	19-DEC-19	1.440	ug/L
51609	51609-3-HAL-F10	3rd FL Hall NE end-Not on Wall	Flush180	19-DEC-19	1.610	ug/L
51609	51609-3-HAL-F10	3rd FL Hall NE end-Not on Wall	Flush180	19-DEC-19	1.590	ug/L
51609	51609-3-HAL-F10	3rd FL Hall NE end-Not on Wall	Flush180	19-DEC-19	1.630	ug/L
51609	51609-3-HAL-F10	3rd FL Hall NE end-Not on Wall	Initial	19-DEC-19	1.750	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	04-OCT-16	0.730	ppb
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	04-OCT-16	0.540	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	04-OCT-16	0.520	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	04-OCT-16	0.540	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	04-OCT-16	0.560	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	04-OCT-16	0.530	ppb
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	04-OCT-16	0.570	ppb
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	04-OCT-16	0.570	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	19-DEC-19	1.480	ug/L
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	19-DEC-19	1.400	ug/L
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	19-DEC-19	1.310	ug/L
51609	51609-3-HAL-F06	3rd FL Hall S end	Flush180	19-DEC-19	1.160	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	19-DEC-19	2.370	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	19-DEC-19	2.210	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	19-DEC-19	1.570	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Flush180	19-DEC-19	1.290	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Initial	04-OCT-16	1.200	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Initial	04-OCT-16	0.920	ppb
51609	51609-3-HAL-F06	3rd FL Hall S end	Initial	19-DEC-19	1.510	ug/L
51609	51609-3-HAL-F07	3rd FL Hall S end	Initial	19-DEC-19	1.660	ug/L
51609	51609-3-HAL-F05	3rd FL Hall SE end	Flush180	04-OCT-16	1.200	ppb
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	04-OCT-16	0.940	ppb
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	04-OCT-16	0.880	ppb
51609	51609-3-HAL-	3rd FL Hall SE end	Flush180	04-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51609	51609-3-HAL-F05	3rd FL Hall SE end	Flush180	04-OCT-16	1.000	ppb
51609	51609-3-HAL-F05	3rd FL Hall SE end	Flush180	04-OCT-16	1.000	ppb
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	04-OCT-16	0.990	ppb
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	04-OCT-16	1.000	ppb
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F04	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F05	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F05	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F05	3rd FL Hall SE end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F04	3rd FL Hall SE end	Initial	04-OCT-16	1.300	ppb
51609	51609-3-HAL-F05	3rd FL Hall SE end	Initial	04-OCT-16	1.900	ppb
51609	51609-3-HAL-F04	3rd FL Hall SE end	Initial	19-DEC-19	1.020	ug/L
51609	51609-3-HAL-F05	3rd FL Hall SE end	Initial	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	04-OCT-16	3.200	ppb
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	04-OCT-16	2.600	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	04-OCT-16	2.600	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	04-OCT-16	2.500	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	04-OCT-16	2.400	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	04-OCT-16	2.600	ppb
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	04-OCT-16	2.500	ppb
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	04-OCT-16	2.500	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F09	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F08	3rd FL Hall SW end	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F09	3rd FL Hall SW end	Initial	04-OCT-16	2.800	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Initial	04-OCT-16	3.000	ppb
51609	51609-3-HAL-F08	3rd FL Hall SW end	Initial	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-F09	3rd FL Hall SW end	Initial	19-DEC-19	1.000	ug/L
51609	51609-3-HAL-	Across Cafeteria	Flush180	04-OCT-16	0.310	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	04-OCT-16	0.340	ppb
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	04-OCT-16	0.350	ppb
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	04-OCT-16	0.330	ppb
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	19-DEC-19	1.520	ug/L
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	19-DEC-19	1.310	ug/L
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	19-DEC-19	1.250	ug/L
51609	51609-3-HAL-F01	Across Cafeteria	Flush180	19-DEC-19	1.270	ug/L
51609	51609-3-HAL-F01	Across Cafeteria	Initial	04-OCT-16	0.670	ppb
51609	51609-3-HAL-F01	Across Cafeteria	Initial	19-DEC-19	2.040	ug/L
51609	51609-B-S01	Basement Mechanical Room	Flush180	04-OCT-16	0.990	ppb
51609	51609-B-S01	Basement Mechanical Room	Flush180	04-OCT-16	1.800	ppb
51609	51609-B-S01	Basement Mechanical Room	Flush180	04-OCT-16	2.100	ppb
51609	51609-B-S01	Basement Mechanical Room	Flush180	04-OCT-16	0.730	ppb
51609	51609-B-S01	Basement Mechanical Room	Flush180	19-DEC-19	1.000	ug/L
51609	51609-B-S01	Basement Mechanical Room	Flush180	19-DEC-19	1.000	ug/L
51609	51609-B-S01	Basement Mechanical Room	Flush180	19-DEC-19	1.000	ug/L
51609	51609-B-S01	Basement Mechanical Room	Flush180	19-DEC-19	1.000	ug/L
51609	51609-B-S01	Basement Mechanical Room	Initial	04-OCT-16	2.100	ppb
51609	51609-B-S01	Basement Mechanical Room	Initial	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	04-OCT-16	0.210	ppb
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	04-OCT-16	0.280	ppb
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	04-OCT-16	0.300	ppb
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	04-OCT-16	0.300	ppb
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S03	Kitchen near Music RM	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S03	Kitchen near Music RM	Initial	04-OCT-16	0.510	ppb
51609	51609-3-KIT-S03	Kitchen near Music RM	Initial	19-DEC-19	1.000	ug/L
51609	51609-1-POOL-F01	Pool	Flush180	04-OCT-16	1.800	ppb
51609	51609-1-POOL-F01	Pool	Flush180	04-OCT-16	2.000	ppb
51609	51609-1-POOL-F01	Pool	Flush180	04-OCT-16	2.000	ppb
51609	51609-1-POOL-F01	Pool	Flush180	04-OCT-16	3.400	ppb
51609	51609-1-POOL-F02	Pool	Flush180	04-OCT-16	2.100	ppb
51609	51609-1-POOL-F02	Pool	Flush180	04-OCT-16	2.100	ppb
51609	51609-1-POOL-F02	Pool	Flush180	04-OCT-16	2.100	ppb
51609	51609-1-POOL-F02	Pool	Flush180	04-OCT-16	2.200	ppb
51609	51609-1-POOL-F01	Pool	Flush180	19-DEC-19	3.560	ug/L
51609	51609-1-POOL-F01	Pool	Flush180	19-DEC-19	2.690	ug/L
51609	51609-1-POOL-F01	Pool	Flush180	19-DEC-19	1.170	ug/L
51609	51609-1-POOL-F01	Pool	Flush180	19-DEC-19	1.020	ug/L
51609	51609-1-POOL-F01	Pool	Flush180	19-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	POOL-F02					
51609	51609-1-POOL-F02	Pool	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-POOL-F02	Pool	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-POOL-F02	Pool	Flush180	19-DEC-19	1.000	ug/L
51609	51609-1-POOL-F01	Pool	Initial	04-OCT-16	3.800	ppb
51609	51609-1-POOL-F02	Pool	Initial	04-OCT-16	2.400	ppb
51609	51609-1-POOL-F01	Pool	Initial	19-DEC-19	2.020	ug/L
51609	51609-1-POOL-F02	Pool	Initial	19-DEC-19	2.570	ug/L
51609	51609-1-122-S01	RM 122 Main Office	Flush180	04-OCT-16	1.500	ppb
51609	51609-1-122-S01	RM 122 Main Office	Flush180	04-OCT-16	1.500	ppb
51609	51609-1-122-S01	RM 122 Main Office	Flush180	04-OCT-16	1.600	ppb
51609	51609-1-122-S01	RM 122 Main Office	Flush180	04-OCT-16	1.200	ppb
51609	51609-1-122-S01	RM 122 Main Office	Flush180	19-DEC-19	1.140	ug/L
51609	51609-1-122-S01	RM 122 Main Office	Flush180	19-DEC-19	1.140	ug/L
51609	51609-1-122-S01	RM 122 Main Office	Flush180	19-DEC-19	1.200	ug/L
51609	51609-1-122-S01	RM 122 Main Office	Flush180	19-DEC-19	1.260	ug/L
51609	51609-1-122-S01	RM 122 Main Office	Initial	04-OCT-16	1.300	ppb
51609	51609-1-122-S01	RM 122 Main Office	Initial	19-DEC-19	1.050	ug/L
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	04-OCT-16	0.560	ppb
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	04-OCT-16	0.420	ppb
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	04-OCT-16	0.410	ppb
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	04-OCT-16	0.500	ppb
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S01	Sink on East Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S01	Sink on East Wall	Initial	04-OCT-16	1.500	ppb
51609	51609-3-KIT-S01	Sink on East Wall	Initial	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	04-OCT-16	1.000	ppb
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	04-OCT-16	1.000	ppb
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	04-OCT-16	0.210	ppb
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	04-OCT-16	1.000	ppb
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S02	Sink on North Wall	Flush180	19-DEC-19	1.000	ug/L
51609	51609-3-KIT-S02	Sink on North Wall	Initial	04-OCT-16	0.380	ppb
51609	51609-3-KIT-S02	Sink on North Wall	Initial	19-DEC-19	1.000	ug/L

Water Quality Assessment
Gage Park High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					