



**Sep 10, 2024**

**GALLISTEL**

**10347 S EWING AVE, Chicago IL 60617.**

Dear **GALLISTEL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**GALLISTEL**

**10347 S EWING AVE, Chicago IL 60617.**

Estimadas familias de **GALLISTEL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Initial	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F03	Main Building- Boys play room Fountain 1	Initial	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Initial	28-MAY-16	1.000	ppb
51505	51505-B-W-BPR-F04	Main Building- Boys play room Fountain 2	Initial	03-DEC-19	1.000	ug/L
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	03-DEC-19	2.970	ug/L
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	03-DEC-19	1.170	ug/L
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	03-DEC-19	2.410	ug/L
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Flush180	03-DEC-19	1.520	ug/L
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Initial	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F05	Main Building- Girls play room Fountain 1	Initial	03-DEC-19	1.650	ug/L
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	03-DEC-19	2.890	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	03-DEC-19	2.820	ug/L
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	03-DEC-19	2.480	ug/L
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Flush180	03-DEC-19	3.140	ug/L
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Initial	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F06	Main Building- Girls play room Fountain 2	Initial	03-DEC-19	1.000	ug/L
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	03-DEC-19	1.230	ug/L
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	03-DEC-19	2.100	ug/L
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	03-DEC-19	2.960	ug/L
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Flush180	03-DEC-19	2.580	ug/L
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Initial	28-MAY-16	1.000	ppb
51505	51505-B-W-GPR-F07	Main Building- Girls play room Fountain 3	Initial	03-DEC-19	3.300	ug/L
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Initial	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F01	Main Building- Outside Room 104 Fountain 1	Initial	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Initial	28-MAY-16	1.000	ppb
51505	51505-1-W-HAL-F02	Main Building- Outside Room 104 Fountain 2	Initial	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	28-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Initial	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F01	Main Building- Outside Room 204 Fountain 1	Initial	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Initial	28-MAY-16	1.000	ppb
51505	51505-2-W-HAL-F02	Main Building- Outside Room 204 Fountain 2	Initial	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	01-SEP-20	4.300	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	13-OCT-20	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	13-OCT-20	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	13-OCT-20	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Flush180	13-OCT-20	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Initial	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Initial	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Initial	01-SEP-20	13.400	ug/L
51505	51505-3-W-HAL-F01	Main Building- Outside Room 304 Fountain 1	Initial	13-OCT-20	1.000	ug/L
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Fountain 2				
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Initial	28-MAY-16	1.000	ppb
51505	51505-3-W-HAL-F02	Main Building- Outside Room 304 Fountain 2	Initial	03-DEC-19	1.000	ug/L
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	28-MAY-16	0.356	ppb
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	28-MAY-16	0.488	ppb
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	28-MAY-16	0.376	ppb
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	28-MAY-16	0.380	ppb
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Initial	28-MAY-16	0.698	ppb
51505	51505-B-N-KIT-KS01	Main- Kitchen, Sink 1	Initial	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Flush180	01-SEP-20	1.000	ug/L
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Initial	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Initial	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F01	Main- South Lunchroom, Fountain 1	Initial	01-SEP-20	1.000	ug/L
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Flush180	03-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	CAF-F02	2				
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Initial	28-MAY-16	1.000	ppb
51505	51505-B-S-CAF-F02	Main- South Lunchroom, Fountain 2	Initial	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Flush180	01-SEP-20	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Initial	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Initial	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F01	Modular 1- By Room 503 West, Fountain 1	Initial	01-SEP-20	1.000	ug/L
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Flush180	03-DEC-19	1.000	ug/L
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Initial	28-MAY-16	1.000	ppb
53812	53812-1-S-HAL-F02	Modular 1- By Room 503 West, Fountain 2	Initial	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	28-MAY-16	0.278	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Flush180	01-SEP-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Initial	28-MAY-16	0.145	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Initial	18-AUG-16	1.000	ppb
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Initial	03-DEC-19	1.000	ug/L
53914	53914-1-E-110-S01	Modular 2- Inside Room 110, Sink 1	Initial	01-SEP-20	1.000	ug/L
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Initial	18-AUG-16	1.000	ppb
53914	53914-1-110-S02	Modular 2- Inside Room 110, Sink 2	Initial	28-MAY-16	0.222	ppb
53914	53914-1-W-111-S02	Modular 2- Inside Room 111, Sink 2	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-W-111-S02	Modular 2- Inside Room 111, Sink 2	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-W-111-S02	Modular 2- Inside Room 111, Sink 2	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-W-111-S02	Modular 2- Inside Room 111, Sink 2	Flush180	03-DEC-19	1.000	ug/L
53914	53914-1-W-111-S02	Modular 2- Inside Room 111, Sink 2	Initial	03-DEC-19	1.000	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	28-MAY-16	7.020	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	28-MAY-16	1.000	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	28-MAY-16	1.400	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	16-NOV-16	2.200	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	28-MAY-16	1.190	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	18-AUG-16	1.000	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	16-NOV-16	1.260	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	16-NOV-16	1.640	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	16-NOV-16	1.300	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	23-APR-20	1.000	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	23-APR-20	1.000	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	23-APR-20	1.000	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	23-APR-20	1.000	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	03-DEC-19	2.310	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	03-DEC-19	1.710	ug/L



**Water Quality Assessment**  
**Matthew Gallistel Elementary Language Academy**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	03-DEC-19	1.640	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Flush180	03-DEC-19	1.270	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Initial	28-MAY-16	22.800	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Initial	18-AUG-16	1.000	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Initial	16-NOV-16	7.100	ppb
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Initial	23-APR-20	1.000	ug/L
53914	53914-1-S-KIT-KS03	Modular 2- Kitchen, Sink	Initial	03-DEC-19	7.750	ug/L