



Sep 10, 2024

GRAHAM ES

4436 S UNION AVE, Chicago IL 60609.

Dear **GRAHAM ES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

GRAHAM ES

4436 S UNION AVE, Chicago IL 60609.

Estimadas familias de **GRAHAM ES:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-JUL-23	2.930	ug/L
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-JUL-23	2.610	ug/L
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-JUL-23	2.570	ug/L
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-JUL-23	1.800	ug/L
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-AUG-16	4.900	ppb
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-AUG-16	3.200	ppb
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-AUG-16	5.400	ppb
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Flush180	12-AUG-16	5.300	ppb
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Initial	12-JUL-23	4.390	ug/L
51352	51352-B-HAL-F13R	Fountain Outside Boys Play Room, Right Fountain	Initial	12-AUG-16	3.100	ppb
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Initial	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F01	Main- Across Room 202, Fountain	Initial	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	09-APR-19	1.070	ug/L
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Initial	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F03	Main- Boys Play Room North,	Initial	09-APR-19	1.160	ug/L
51352	51352-B-KIT-KS02	Main- Kitchen Faucet Above Stove	Flush180	10-JUN-16	75.700	ppb
51352	51352-B-KIT-KS02	Main- Kitchen Faucet Above Stove	Flush180	10-JUN-16	19.200	ppb
51352	51352-B-KIT-KS02	Main- Kitchen Faucet Above Stove	Flush180	10-JUN-16	14.200	ppb
51352	51352-B-KIT-KS02	Main- Kitchen Faucet Above Stove	Flush180	10-JUN-16	25.300	ppb
51352	51352-B-KIT-KS02	Main- Kitchen Faucet Above Stove	Initial	10-JUN-16	136.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51352	51352-B-KIT-KS01	Main- Kitchen West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-KIT-KS01	Main- Kitchen West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-KIT-KS01	Main- Kitchen West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-KIT-KS01	Main- Kitchen West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-KIT-KS01	Main- Kitchen West Wall, Sink	Initial	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Flush180	31-JUL-20	1.000	ug/L
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Initial	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Initial	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F01	Main- Outside Room 101, Fountain	Initial	31-JUL-20	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Initial	10-JUN-16	1.000	ppb
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Initial	09-APR-19	1.070	ug/L
51352	51352-1-N-HAL-F04	Main- Outside Room 109, Fountain	Initial	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	09-APR-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Initial	10-JUN-16	1.000	ppb
51352	51352-2-N-HAL-F02	Main- Outside Room 209, Fountain	Initial	09-APR-19	1.000	ug/L
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	09-APR-19	1.610	ug/L
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	09-APR-19	1.330	ug/L
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Initial	10-JUN-16	1.000	ppb
51352	51352-3-N-HAL-F01	Main- Outside Room 301, Fountain	Initial	09-APR-19	1.280	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	10-JUN-16	1.000	ppb
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	09-APR-19	1.000	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Flush180	31-JUL-20	1.000	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Initial	10-JUN-16	1.000	ppb
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Initial	09-APR-19	1.290	ug/L
51352	51352-3-S-HAL-F03	Main- Outside Room 309, Fountain	Initial	31-JUL-20	1.000	ug/L
51352	51352-B-N-HAL-F06	Main- Outside Room 98	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F06	Main- Outside Room 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F06	Main- Outside Room 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F06	Main- Outside Room 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F06	Main- Outside Room 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F06	Main- Outside Room 98	Initial	09-APR-19	1.000	ug/L
51352	51352-B-HAL-F07	Main- Outside Room 98 East Center, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F07	Main- Outside Room 98 East Center, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F07	Main- Outside Room 98 East Center, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F07	Main- Outside Room 98 East Center, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F07	Main- Outside Room 98 East Center, Fountain 2	Initial	10-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07	Center, Fountain 2				
51352	51352-B-HAL-F08	Main- Outside Room 98 East, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F08	Main- Outside Room 98 East, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F08	Main- Outside Room 98 East, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F08	Main- Outside Room 98 East, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-HAL-F08	Main- Outside Room 98 East, Fountain 1	Initial	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	09-APR-19	1.080	ug/L
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	09-APR-19	1.050	ug/L
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	09-APR-19	1.250	ug/L
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Flush180	09-APR-19	1.060	ug/L
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Initial	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F02	Main- Outside Room boys bathroom West, Fountain 4	Initial	09-APR-19	1.300	ug/L
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	09-APR-19	1.480	ug/L
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	09-APR-19	1.690	ug/L
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	09-APR-19	1.520	ug/L
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Flush180	09-APR-19	1.460	ug/L
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Initial	10-JUN-16	1.000	ppb
51352	51352-B-W-HAL-F01	Main- Outside bathrooms	Initial	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F05	Outside 98	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F05	Outside 98	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F05	Outside 98	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F05	Outside 98	Flush180	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F05	Outside 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F05	Outside 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F05	Outside 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F05	Outside 98	Flush180	09-APR-19	1.000	ug/L
51352	51352-B-N-HAL-F05	Outside 98	Initial	10-JUN-16	1.000	ppb
51352	51352-B-N-HAL-F05	Outside 98	Initial	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F02	Outside room 101	Flush180	09-APR-19	1.390	ug/L
51352	51352-1-N-HAL-F02	Outside room 101	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-	Outside room 101	Flush180	09-APR-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02					
51352	51352-1-N-HAL-F02	Outside room 101	Flush180	09-APR-19	1.000	ug/L
51352	51352-1-N-HAL-F02	Outside room 101	Initial	09-APR-19	1.620	ug/L
51352	51352-B-N-HAL-F04	Outside room 98, left fountain on #1	Flush180	12-AUG-16	3.600	ppb
51352	51352-B-N-HAL-F04	Outside room 98, left fountain on #1	Flush180	12-AUG-16	2.100	ppb
51352	51352-B-N-HAL-F04	Outside room 98, left fountain on #1	Flush180	12-AUG-16	3.700	ppb
51352	51352-B-N-HAL-F04	Outside room 98, left fountain on #1	Flush180	12-AUG-16	3.400	ppb
51352	51352-B-N-HAL-F04	Outside room 98, left fountain on #1	Initial	12-AUG-16	3.200	ppb
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Flush180	31-JUL-20	1.000	ug/L
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Initial	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F06	Branch- Across Room 112 Hallway, Fountain 2	Initial	31-JUL-20	1.000	ug/L
53814	53814-1-HAL-F05	Branch- Across Room 112 Hallway, Fountain, 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F05	Branch- Across Room 112 Hallway, Fountain, 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F05	Branch- Across Room 112 Hallway, Fountain, 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-HAL-F05	Branch- Across Room 112 Hallway, Fountain, 1	Initial	10-JUN-16	1.000	ppb
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Flush180	31-JUL-20	1.790	ug/L
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Initial	10-JUN-16	6.750	ppb
53814	53814-2-HAL-F02	Branch- Across Room 212 Hallway, Fountain 2	Initial	31-JUL-20	4.130	ug/L
53814	53814-1-110-S03	Branch- Inside Room 110 East Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-110-S03	Branch- Inside Room 110 East Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-110-S03	Branch- Inside Room 110 East Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-110-S03	Branch- Inside Room 110 East Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-110-S03	Branch- Inside Room 110 East Wall, Sink	Initial	10-JUN-16	1.000	ppb
53814	53814-1-112-S04	Branch- Inside Room 112 West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-112-S04	Branch- Inside Room 112 West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-112-S04	Branch- Inside Room 112 West Wall, Sink	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-112-S04	Branch- Inside Room 112 West Wall, Sink	Initial	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS02	Branch- Kitchen Center, Sink 2	Flush180	10-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53814	53814-1-KIT-KS02	Branch- Kitchen Center, Sink 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS02	Branch- Kitchen Center, Sink 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS02	Branch- Kitchen Center, Sink 2	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS02	Branch- Kitchen Center, Sink 2	Initial	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS01	Branch- Kitchen, Sink 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS01	Branch- Kitchen, Sink 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS01	Branch- Kitchen, Sink 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS01	Branch- Kitchen, Sink 1	Flush180	10-JUN-16	1.000	ppb
53814	53814-1-KIT-KS01	Branch- Kitchen, Sink 1	Initial	10-JUN-16	1.000	ppb