



**Sep 10, 2024**

**GRESHAM**

**8524 S GREEN ST, Chicago IL 60620.**

Dear **GRESHAM** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**GRESHAM**

**8524 S GREEN ST, Chicago IL 60620.**

Estimadas familias de **GRESHAM**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	17-JUN-16	2.360	ppb
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	17-JUN-16	1.930	ppb
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	17-JUN-16	1.900	ppb
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	17-JUN-16	2.130	ppb
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	02-MAY-23	1.160	ug/L
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Initial	17-JUN-16	2.360	ppb
51435	51435-1-101-F02	1st Floor Inside Room 101, Fountain	Initial	02-MAY-23	1.200	ug/L
51435	51435-1-110-S10	1st Floor Inside Room 110, Sink	Flush180	17-JUN-16	0.749	ppb
51435	51435-1-110-S10	1st Floor Inside Room 110, Sink	Flush180	17-JUN-16	0.356	ppb
51435	51435-1-110-S10	1st Floor Inside Room 110, Sink	Flush180	17-JUN-16	0.541	ppb
51435	51435-1-110-S10	1st Floor Inside Room 110, Sink	Flush180	17-JUN-16	0.396	ppb
51435	51435-1-110-S10	1st Floor Inside Room 110, Sink	Initial	17-JUN-16	0.766	ppb
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	17-JUN-16	0.217	ppb
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	17-JUN-16	1.000	ppb
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	17-JUN-16	1.000	ppb
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	17-JUN-16	1.000	ppb
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	19-AUG-20	1.000	ug/L
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Initial	17-JUN-16	0.429	ppb
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Initial	19-AUG-20	1.000	ug/L
51435	51435-1-112-F11	1st Floor Inside Room 112, Fountain	Initial	02-MAY-23	1.000	ug/L
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	17-JUN-16	2.480	ppb
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	17-JUN-16	4.290	ppb
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	17-JUN-16	3.810	ppb
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	17-JUN-16	2.220	ppb
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Flush180	02-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Initial	17-JUN-16	1.100	ppb
51435	51435-1-112-S12	1st Floor Inside Room 112, Sink	Initial	02-MAY-23	1.000	ug/L
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	17-JUN-16	1.480	ppb
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	17-JUN-16	1.360	ppb
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	17-JUN-16	2.050	ppb
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	17-JUN-16	1.720	ppb
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	02-MAY-23	1.770	ug/L
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	02-MAY-23	1.450	ug/L
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	02-MAY-23	1.660	ug/L
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Flush180	02-MAY-23	1.850	ug/L
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Initial	17-JUN-16	1.840	ppb
51435	51435-1-118-S07	1st Floor Inside Room 118, Sink	Initial	02-MAY-23	1.840	ug/L
51435	51435-1-KIT-KS01	1st Floor Kitchen Sink	Flush180	17-JUN-16	1.010	ppb
51435	51435-1-KIT-KS01	1st Floor Kitchen Sink	Flush180	17-JUN-16	0.542	ppb
51435	51435-1-KIT-KS01	1st Floor Kitchen Sink	Flush180	17-JUN-16	0.447	ppb
51435	51435-1-KIT-KS01	1st Floor Kitchen Sink	Flush180	17-JUN-16	0.638	ppb
51435	51435-1-KIT-KS01	1st Floor Kitchen Sink	Initial	17-JUN-16	0.755	ppb
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.409	ppb
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.250	ppb
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.298	ppb
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.322	ppb
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Initial	17-JUN-16	0.287	ppb
51435	51435-1-HAL-F09	1st Floor Outside Bathrooms East, Fountain 1	Initial	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-F08	1st Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.331	ppb
51435	51435-1-HAL-F08	1st Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.332	ppb
51435	51435-1-HAL-F08	1st Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.604	ppb
51435	51435-1-HAL-F08	1st Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.441	ppb
51435	51435-1-HAL-F08	1st Floor Outside Bathrooms West, Fountain 2	Initial	17-JUN-16	0.489	ppb
51435	51435-1-HAL-RBF01	1st Floor Outside Bathrooms West, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-RBF01	1st Floor Outside Bathrooms West, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-RBF01	1st Floor Outside Bathrooms West, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-RBF01	1st Floor Outside Bathrooms West, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-1-HAL-RBF01	1st Floor Outside Bathrooms West, Retrofit Bottle Filler	Initial	02-MAY-23	1.000	ug/L





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	South, Fountain 2				
51435	51435-1-HAL-F06	1st Floor Outside of Lunchroom South, Fountain 2	Initial	17-JUN-16	1.510	ppb
51435	51435-1-HAL-F06	1st Floor Outside of Lunchroom South, Fountain 2	Initial	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	17-JUN-16	0.713	ppb
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	17-JUN-16	0.670	ppb
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	17-JUN-16	0.638	ppb
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	17-JUN-16	0.650	ppb
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Initial	17-JUN-16	0.687	ppb
51435	51435-2-HAL-F04	2nd Floor Outside Room 212, Fountain	Initial	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	17-JUN-16	1.790	ppb
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	17-JUN-16	1.690	ppb
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	17-JUN-16	1.980	ppb
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	17-JUN-16	1.560	ppb
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Initial	17-JUN-16	1.620	ppb
51435	51435-2-HAL-F03	2nd Floor Outside Rooms 214/215, Fountain	Initial	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.503	ppb
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.456	ppb
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.897	ppb
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.770	ppb
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Initial	17-JUN-16	0.613	ppb
51435	51435-2-HAL-F06	2nd floor Outside Bathrooms East, Fountain 1	Initial	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.315	ppb
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.347	ppb
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.410	ppb
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.634	ppb
51435	51435-2-HAL-	2nd floor Outside Bathrooms	Flush180	02-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	West, Fountain 2				
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Initial	17-JUN-16	0.303	ppb
51435	51435-2-HAL-F05	2nd floor Outside Bathrooms West, Fountain 2	Initial	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F01	2nd floor Outside Room 204 North, Fountain 1	Flush180	17-JUN-16	3.760	ppb
51435	51435-2-HAL-F01	2nd floor Outside Room 204 North, Fountain 1	Flush180	17-JUN-16	3.760	ppb
51435	51435-2-HAL-F01	2nd floor Outside Room 204 North, Fountain 1	Flush180	17-JUN-16	3.840	ppb
51435	51435-2-HAL-F01	2nd floor Outside Room 204 North, Fountain 1	Flush180	17-JUN-16	3.900	ppb
51435	51435-2-HAL-F01	2nd floor Outside Room 204 North, Fountain 1	Initial	17-JUN-16	2.000	ppb
51435	51435-2-HAL-RBF01	2nd floor Outside Room 204 North, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-RBF01	2nd floor Outside Room 204 North, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-RBF01	2nd floor Outside Room 204 North, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-RBF01	2nd floor Outside Room 204 North, Retrofit Bottle Filler	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-RBF01	2nd floor Outside Room 204 North, Retrofit Bottle Filler	Initial	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	17-JUN-16	3.710	ppb
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	17-JUN-16	3.610	ppb
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	17-JUN-16	3.640	ppb
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	17-JUN-16	2.560	ppb
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Initial	17-JUN-16	2.470	ppb
51435	51435-2-HAL-F02	2nd floor Outside Room 204 South, Fountain 2	Initial	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F06	3rd Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.271	ppb
51435	51435-3-HAL-F06	3rd Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.685	ppb
51435	51435-3-HAL-F06	3rd Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.220	ppb
51435	51435-3-HAL-F06	3rd Floor Outside Bathrooms East, Fountain 1	Flush180	17-JUN-16	0.263	ppb
51435	51435-3-HAL-F06	3rd Floor Outside Bathrooms East, Fountain 1	Initial	17-JUN-16	0.729	ppb
51435	51435-3-HAL-RBF01	3rd Floor Outside Bathrooms East, Retrofitted Bottle Filler	Flush180	02-MAY-23	1.680	ug/L
51435	51435-3-HAL-RBF01	3rd Floor Outside Bathrooms East, Retrofitted Bottle Filler	Flush180	02-MAY-23	1.690	ug/L
51435	51435-3-HAL-RBF01	3rd Floor Outside Bathrooms East, Retrofitted Bottle Filler	Flush180	02-MAY-23	1.470	ug/L
51435	51435-3-HAL-RBF01	3rd Floor Outside Bathrooms East, Retrofitted Bottle Filler	Flush180	02-MAY-23	1.300	ug/L
51435	51435-3-HAL-RBF01	3rd Floor Outside Bathrooms East, Retrofitted Bottle Filler	Initial	02-MAY-23	1.680	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.657	ppb
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.286	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.322	ppb
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	17-JUN-16	0.328	ppb
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	19-AUG-20	1.000	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Initial	17-JUN-16	0.354	ppb
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Initial	19-AUG-20	1.000	ug/L
51435	51435-3-HAL-F05	3rd Floor Outside Bathrooms West, Fountain 2	Initial	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	17-JUN-16	4.510	ppb
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	17-JUN-16	4.360	ppb
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	17-JUN-16	4.290	ppb
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	17-JUN-16	4.630	ppb
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	02-MAY-23	1.980	ug/L
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	02-MAY-23	1.930	ug/L
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	02-MAY-23	2.100	ug/L
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Flush180	02-MAY-23	2.120	ug/L
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Initial	17-JUN-16	9.360	ppb
51435	51435-3-HAL-F01	3rd Floor Outside Room 304 North, Fountain 1	Initial	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	17-JUN-16	4.080	ppb
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	17-JUN-16	3.780	ppb
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	17-JUN-16	3.630	ppb
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	17-JUN-16	5.610	ppb
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Initial	17-JUN-16	3.680	ppb
51435	51435-3-HAL-F02	3rd Floor Outside Room 304 South, Fountain 2	Initial	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	17-JUN-16	1.020	ppb
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	17-JUN-16	0.974	ppb
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	17-JUN-16	1.190	ppb
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	17-JUN-16	1.110	ppb
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	02-MAY-23	1.000	ug/L



**Water Quality Assessment  
Walter Q Gresham Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Initial	17-JUN-16	0.952	ppb
51435	51435-3-HAL-F04	3rd floor Outside Room 312, Fountain	Initial	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	17-JUN-16	1.500	ppb
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	17-JUN-16	1.600	ppb
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	17-JUN-16	1.510	ppb
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	17-JUN-16	1.260	ppb
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	02-MAY-23	1.000	ug/L
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	02-MAY-23	1.550	ug/L
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Flush180	02-MAY-23	1.200	ug/L
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Initial	17-JUN-16	1.350	ppb
51435	51435-3-HAL-F03	3rd floor Outside Rooms 314/315, Fountain	Initial	02-MAY-23	1.000	ug/L