



**Sep 10, 2024**

**GUNSAULUS**

**4420 S SACRAMENTO AVE, Chicago IL 60632.**

Dear **GUNSAULUS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**GUNSAULUS**

**4420 S SACRAMENTO AVE, Chicago IL 60632.**

Estimadas familias de **GUNSAULUS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51272	51272-1-HAL-BF01	Across from Room 105	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF01	Across from Room 105	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF01	Across from Room 105	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF01	Across from Room 105	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF01	Across from Room 105	Initial	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-F04	Fountain 1 Across from room 105	Flush180	28-MAY-16	0.928	ppb
51272	51272-1-HAL-F04	Fountain 1 Across from room 105	Flush180	28-MAY-16	0.711	ppb
51272	51272-1-HAL-F04	Fountain 1 Across from room 105	Flush180	28-MAY-16	0.529	ppb
51272	51272-1-HAL-F04	Fountain 1 Across from room 105	Flush180	28-MAY-16	0.813	ppb
51272	51272-1-HAL-F04	Fountain 1 Across from room 105	Initial	28-MAY-16	0.951	ppb
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Flush180	28-MAY-16	0.727	ppb
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Flush180	28-MAY-16	0.895	ppb
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Flush180	28-MAY-16	1.020	ppb
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Flush180	28-MAY-16	1.040	ppb
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Flush180	28-OCT-20	1.000	ug/L
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Initial	28-MAY-16	1.040	ppb
51272	51272-1-HAL-F07	Fountain 1 outside room 114	Initial	28-OCT-20	1.000	ug/L
51272	51272-2-HAL-F01	Fountain 1 outside room 202	Flush180	28-MAY-16	0.568	ppb
51272	51272-2-HAL-F01	Fountain 1 outside room 202	Flush180	28-MAY-16	0.692	ppb
51272	51272-2-HAL-F01	Fountain 1 outside room 202	Flush180	28-MAY-16	0.472	ppb
51272	51272-2-HAL-F01	Fountain 1 outside room 202	Flush180	28-MAY-16	0.475	ppb
51272	51272-2-HAL-F01	Fountain 1 outside room 202	Initial	28-MAY-16	0.815	ppb
51272	51272-2-HAL-F03	Fountain 1 outside room 207	Flush180	28-MAY-16	0.520	ppb
51272	51272-2-HAL-F03	Fountain 1 outside room 207	Flush180	28-MAY-16	0.498	ppb
51272	51272-2-HAL-F03	Fountain 1 outside room 207	Flush180	28-MAY-16	0.497	ppb
51272	51272-2-HAL-F03	Fountain 1 outside room 207	Flush180	28-MAY-16	0.535	ppb
51272	51272-2-HAL-F03	Fountain 1 outside room 207	Initial	28-MAY-16	0.729	ppb
51272	51272-1-HAL-F05	Fountain 2 Across from room 105	Flush180	28-MAY-16	0.460	ppb
51272	51272-1-HAL-F05	Fountain 2 Across from room 105	Flush180	28-MAY-16	0.919	ppb
51272	51272-1-HAL-F05	Fountain 2 Across from room 105	Flush180	28-MAY-16	0.572	ppb
51272	51272-1-HAL-F05	Fountain 2 Across from room 105	Flush180	28-MAY-16	0.472	ppb
51272	51272-1-HAL-F05	Fountain 2 Across from room 105	Initial	28-MAY-16	0.645	ppb
51272	51272-1-HAL-F08	Fountain 2 outside room 114	Flush180	28-MAY-16	1.730	ppb
51272	51272-1-HAL-F08	Fountain 2 outside room 114	Flush180	28-MAY-16	1.300	ppb
51272	51272-1-HAL-F08	Fountain 2 outside room 114	Flush180	28-MAY-16	2.110	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51272	51272-1-HAL-F08	Fountain 2 outside room 114	Flush180	28-MAY-16	1.350	ppb
51272	51272-1-HAL-F08	Fountain 2 outside room 114	Initial	28-MAY-16	1.240	ppb
51272	51272-2-HAL-F02	Fountain 2 outside room 202	Flush180	28-MAY-16	0.517	ppb
51272	51272-2-HAL-F02	Fountain 2 outside room 202	Flush180	28-MAY-16	0.525	ppb
51272	51272-2-HAL-F02	Fountain 2 outside room 202	Flush180	28-MAY-16	0.489	ppb
51272	51272-2-HAL-F02	Fountain 2 outside room 202	Flush180	28-MAY-16	0.515	ppb
51272	51272-2-HAL-F02	Fountain 2 outside room 202	Initial	28-MAY-16	0.870	ppb
51272	51272-2-HAL-F04	Fountain 2 outside room 207	Flush180	28-MAY-16	0.571	ppb
51272	51272-2-HAL-F04	Fountain 2 outside room 207	Flush180	28-MAY-16	0.560	ppb
51272	51272-2-HAL-F04	Fountain 2 outside room 207	Flush180	28-MAY-16	0.550	ppb
51272	51272-2-HAL-F04	Fountain 2 outside room 207	Flush180	28-MAY-16	0.521	ppb
51272	51272-2-HAL-F04	Fountain 2 outside room 207	Initial	28-MAY-16	0.810	ppb
51272	51272-3-HAL-F01	Fountain outside room 302	Flush180	28-MAY-16	0.553	ppb
51272	51272-3-HAL-F01	Fountain outside room 302	Flush180	28-MAY-16	0.447	ppb
51272	51272-3-HAL-F01	Fountain outside room 302	Flush180	28-MAY-16	0.470	ppb
51272	51272-3-HAL-F01	Fountain outside room 302	Flush180	28-MAY-16	0.473	ppb
51272	51272-3-HAL-F01	Fountain outside room 302	Initial	28-MAY-16	0.744	ppb
51272	51272-3-HAL-F02	Fountain outside room 307	Flush180	28-MAY-16	0.563	ppb
51272	51272-3-HAL-F02	Fountain outside room 307	Flush180	28-MAY-16	0.568	ppb
51272	51272-3-HAL-F02	Fountain outside room 307	Flush180	28-MAY-16	0.700	ppb
51272	51272-3-HAL-F02	Fountain outside room 307	Flush180	28-MAY-16	0.644	ppb
51272	51272-3-HAL-F02	Fountain outside room 307	Flush180	28-OCT-20	1.000	ug/L
51272	51272-3-HAL-F02	Fountain outside room 307	Initial	28-MAY-16	0.744	ppb
51272	51272-3-HAL-F02	Fountain outside room 307	Initial	28-OCT-20	1.000	ug/L
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	28-MAY-16	0.358	ppb
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	28-MAY-16	0.768	ppb
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	28-MAY-16	0.562	ppb
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	28-MAY-16	0.579	ppb
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Initial	28-MAY-16	0.356	ppb
51272	51272-1-KIT-KS02	Kitchen, Sink 2 West Side	Initial	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	28-MAY-16	0.818	ppb
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	28-MAY-16	0.781	ppb
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	28-MAY-16	0.805	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	28-MAY-16	0.688	ppb
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Initial	28-MAY-16	0.673	ppb
51272	51272-1-KIT-KS03	Kitchen, Sink 3 East Side	Initial	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF02	Outside Room 114	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF02	Outside Room 114	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF02	Outside Room 114	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF02	Outside Room 114	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-HAL-BF02	Outside Room 114	Initial	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF01	Outside Room 202	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF01	Outside Room 202	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF01	Outside Room 202	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF01	Outside Room 202	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF01	Outside Room 202	Initial	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF02	Outside Room 207	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF02	Outside Room 207	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF02	Outside Room 207	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF02	Outside Room 207	Flush180	14-DEC-21	1.000	ug/L
51272	51272-2-HAL-BF02	Outside Room 207	Initial	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF02	Outside Room 302	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF02	Outside Room 302	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF02	Outside Room 302	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF02	Outside Room 302	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF02	Outside Room 302	Initial	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF01	Outside Room 307	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF01	Outside Room 307	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF01	Outside Room 307	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF01	Outside Room 307	Flush180	14-DEC-21	1.000	ug/L
51272	51272-3-HAL-BF01	Outside Room 307	Initial	14-DEC-21	1.000	ug/L
51272	51272-1-101-F01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-F01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-F01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-F01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-BF01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-	Room 101	Flush180	02-SEP-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51272	51272-1-101-BF01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-BF01	Room 101	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-101-F01	Room 101	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-101-BF01	Room 101	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-101-S01	Room 101, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S01	Room 101, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S01	Room 101, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S01	Room 101, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S01	Room 101, Left Sink	Initial	08-SEP-22	2.740	ug/L
51272	51272-1-101-S02	Room 101, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S02	Room 101, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S02	Room 101, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S02	Room 101, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-101-S02	Room 101, Right Sink	Initial	08-SEP-22	1.000	ug/L
51272	51272-1-102-F01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-F01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-F01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-F01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-BF01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-BF01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-BF01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-BF01	Room 102	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-F01	Room 102	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-102-BF01	Room 102	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-102-S01	Room 102, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S01	Room 102, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S01	Room 102, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S01	Room 102, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S01	Room 102, Left Sink	Initial	02-SEP-22	1.580	ug/L
51272	51272-1-102-S02	Room 102, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S02	Room 102, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S02	Room 102, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S02	Room 102, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-102-S02	Room 102, Right Sink	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-103-F01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-BF01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-	Room 103	Flush180	02-SEP-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51272	51272-1-103-BF01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-BF01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-F01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-F01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-F01	Room 103	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-F01	Room 103	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-103-BF01	Room 103	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	06-OCT-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	22-SEP-22	2.420	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	22-SEP-22	1.100	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	02-SEP-22	1.130	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	06-OCT-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Flush180	06-OCT-22	1.000	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Initial	06-OCT-22	1.080	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Initial	22-SEP-22	13.700	ug/L
51272	51272-1-103-S01	Room 103, Left Sink	Initial	02-SEP-22	9.550	ug/L
51272	51272-1-103-S02	Room 103, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-S02	Room 103, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-S02	Room 103, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-103-S02	Room 103, Right Sink	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-104-F01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-F01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-F01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-F01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-BF01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-BF01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-BF01	Room 104	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-F01	Room 104	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-104-BF01	Room 104	Initial	02-SEP-22	1.000	ug/L





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51272	51272-1-104-S01	Room 104, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S01	Room 104, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S01	Room 104, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S01	Room 104, Left Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S01	Room 104, Left Sink	Initial	02-SEP-22	1.550	ug/L
51272	51272-1-104-S02	Room 104, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S02	Room 104, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S02	Room 104, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S02	Room 104, Right Sink	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-104-S02	Room 104, Right Sink	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-105-F01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-F01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-F01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-F01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-BF01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-BF01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-BF01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-BF01	Room 105	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-105-F01	Room 105	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-105-BF01	Room 105	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-105-S01	Room 105, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S01	Room 105, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S01	Room 105, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S01	Room 105, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S01	Room 105, Left Sink	Initial	08-SEP-22	2.020	ug/L
51272	51272-1-105-S02	Room 105, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S02	Room 105, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S02	Room 105, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S02	Room 105, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-105-S02	Room 105, Right Sink	Initial	08-SEP-22	1.000	ug/L
51272	51272-1-106-F01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-F01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-F01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-F01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-BF01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-BF01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-BF01	Room 106	Flush180	02-SEP-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51272	51272-1-106-BF01	Room 106	Flush180	02-SEP-22	1.000	ug/L
51272	51272-1-106-F01	Room 106	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-106-BF01	Room 106	Initial	02-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Initial	22-SEP-22	1.860	ug/L
51272	51272-1-106-S01	Room 106, Left Sink	Initial	08-SEP-22	5.230	ug/L
51272	51272-1-106-S02	Room 106, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-106-S02	Room 106, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-106-S02	Room 106, Right Sink	Flush180	08-SEP-22	1.000	ug/L
51272	51272-1-106-S02	Room 106, Right Sink	Initial	08-SEP-22	1.000	ug/L
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	28-MAY-16	1.250	ppb
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	28-MAY-16	1.910	ppb
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	28-MAY-16	4.360	ppb
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	28-MAY-16	12.600	ppb
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Initial	28-MAY-16	34.700	ppb
51272	51272-1-KIT-KS01	Sink In kitchen above stove (faucet)	Initial	14-DEC-21	1.000	ug/L
51272	51272-1-114-S06	Sink inside room 114	Flush180	28-MAY-16	1.380	ppb
51272	51272-1-114-S0651272-1-114-S06	Sink inside room 114	Flush180	28-MAY-16	2.310	ppb
51272	51272-1-114-S06	Sink inside room 114	Flush180	28-MAY-16	1.660	ppb
51272	51272-1-114-S06	Sink inside room 114	Flush180	28-MAY-16	1.800	ppb
51272	51272-1-114-S06	Sink inside room 114	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-114-S06	Sink inside room 114	Flush180	14-DEC-21	1.000	ug/L
51272	51272-1-114-S06	Sink inside room 114	Flush180	14-DEC-21	1.060	ug/L
51272	51272-1-114-S06	Sink inside room 114	Flush180	14-DEC-21	1.080	ug/L
51272	51272-1-114-S06	Sink inside room 114	Initial	28-MAY-16	2.460	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51272	51272-1-114-S06	Sink inside room 114	Initial	14-DEC-21	1.800	ug/L