



**Sep 10, 2024**

**HAINES**

**247 W 23RD PL, Chicago IL 60616.**

Dear **HAINES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**HAINES**

**247 W 23RD PL, Chicago IL 60616.**

Estimadas familias de **HAINES**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51236	51236-1-HAL-F01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-F01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-F01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-F01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-BF01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-BF01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-BF01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-BF01	Across from Cafeteria (Rm 114)	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-F01	Across from Cafeteria (Rm 114)	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-BF01	Across from Cafeteria (Rm 114)	Initial	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-F01	Inside Gym	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F01	Inside Gym	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F01	Inside Gym	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F01	Inside Gym	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F01	Inside Gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-F01	Inside Gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-F01	Inside Gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-F01	Inside Gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-F01	Inside Gym	Initial	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F01	Inside Gym	Initial	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-BF01	Inside gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-BF01	Inside gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-BF01	Inside gym	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-GYM-BF01	Inside gym	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Flush180	01-SEP-20	1.000	ug/L
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Initial	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F06	Main- 1st Floor Across From Room 114 Left, Fountai	Initial	01-SEP-20	1.000	ug/L
51236	51236-1-HAL-F07	Main- 1st Floor Across From Room 114 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F07	Main- 1st Floor Across From Room 114 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F07	Main- 1st Floor Across From Room 114 Right, Founta	Flush180	23-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51236	51236-1-HAL-F07	Main- 1st Floor Across From Room 114 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-HAL-F07	Main- 1st Floor Across From Room 114 Right, Founta	Initial	23-SEP-16	1.000	ppb
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-117-S08	Main- 1st Floor Inside Room 117 Left, Sink	Initial	23-SEP-16	0.141	ppb
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	23-SEP-16	0.211	ppb
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-117-S09	Main- 1st Floor Inside Room 117 Right, Sink	Initial	23-SEP-16	0.138	ppb
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	23-SEP-16	0.405	ppb
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	23-SEP-16	0.521	ppb
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	23-SEP-16	0.412	ppb
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Flush180	23-SEP-16	0.594	ppb
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Initial	07-JAN-22	1.210	ug/L
51236	51236-1-119-S11	Main- 1st Floor Inside Room 119 Left, Sink	Initial	23-SEP-16	2.520	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	07-JAN-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Initial	23-SEP-16	0.154	ppb
51236	51236-1-119-S12	Main- 1st Floor Inside Room 119 Right, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Initial	23-SEP-16	1.000	ppb
51236	51236-1-120-S10	Main- 1st Floor Inside Room 120, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	23-SEP-16	0.477	ppb
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	23-SEP-16	0.282	ppb
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	23-SEP-16	0.785	ppb
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	23-SEP-16	0.202	ppb
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Initial	23-SEP-16	6.890	ppb
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	23-SEP-16	0.266	ppb
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	23-SEP-16	2.510	ppb
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	23-SEP-16	0.386	ppb
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Initial	23-SEP-16	0.453	ppb
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-	Main- 1st Floor Kitchen North Wall,	Flush180	07-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01	Sink				
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS01	Main- 1st Floor Kitchen North Wall, Sink	Initial	23-SEP-16	0.253	ppb
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	23-SEP-16	0.192	ppb
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	23-SEP-16	0.197	ppb
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	23-SEP-16	0.120	ppb
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Initial	07-JAN-22	1.000	ug/L
51236	51236-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Initial	23-SEP-16	0.507	ppb
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-AUG-22	1.000	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	07-JAN-22	663.000	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	07-JAN-22	21.700	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	07-JAN-22	8.830	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	07-JAN-22	28.000	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-AUG-22	1.000	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-AUG-22	1.000	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-AUG-22	1.010	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Flush180	23-SEP-16	1.000	ppb
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Initial	23-AUG-22	1.150	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Initial	07-JAN-22	186.000	ug/L
51236	51236-1-KIT-KS05	Main- 1st Floor Kitchen South Wall, Sink	Initial	23-SEP-16	0.380	ppb
51236	51236-2-GYM-F02	Main- 2nd Floor Inside Gym Right, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F02	Main- 2nd Floor Inside Gym Right, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F02	Main- 2nd Floor Inside Gym Right, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-GYM-F02	Main- 2nd Floor Inside Gym Right, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-	Main- 2nd Floor Inside Gym Right,	Initial	23-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	GYM-F02	Fountain				
51236	51236-2-HAL-BF02	Main- 2nd FloorAcross From Room 208	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-BF02	Main- 2nd FloorAcross From Room 208	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-BF02	Main- 2nd FloorAcross From Room 208	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-BF02	Main- 2nd FloorAcross From Room 208	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-BF02	Main- 2nd FloorAcross From Room 208	Initial	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-F04	Main- 2nd FloorAcross From Room 208 Right, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F04	Main- 2nd FloorAcross From Room 208 Right, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F04	Main- 2nd FloorAcross From Room 208 Right, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F04	Main- 2nd FloorAcross From Room 208 Right, Fountai	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F04	Main- 2nd FloorAcross From Room 208 Right, Fountai	Initial	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Initial	23-SEP-16	1.000	ppb
51236	51236-2-HAL-F02	Main- 2nd FloorAcross From Room 208, Fountain	Initial	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-F02	Main- 3rd Floor Across From Room 308 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F02	Main- 3rd Floor Across From Room 308 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F02	Main- 3rd Floor Across From Room 308 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F02	Main- 3rd Floor Across From Room 308 Right, Founta	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F02	Main- 3rd Floor Across From Room 308 Right, Founta	Initial	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	01-SEP-20	1.000	ug/L
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Initial	23-SEP-16	1.000	ppb
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Initial	01-SEP-20	1.000	ug/L
51236	51236-3-HAL-F01	Main- 3rd Floor Across From Room 308, Fountain	Initial	07-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51236	51236-3-HAL-BF01	Main- 3rd FloorAcross From Room 308	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-BF01	Main- 3rd FloorAcross From Room 308	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-BF01	Main- 3rd FloorAcross From Room 308	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-BF01	Main- 3rd FloorAcross From Room 308	Flush180	07-JAN-22	1.000	ug/L
51236	51236-3-HAL-BF01	Main- 3rd FloorAcross From Room 308	Initial	07-JAN-22	1.000	ug/L