



**Sep 10, 2024**

**HAMLIN**

**4747 S BISHOP ST, Chicago IL 60609.**

Dear **HAMLIN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**HAMLIN**

**4747 S BISHOP ST, Chicago IL 60609.**

Estimadas familias de **HAMLIN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51324	51324-2-N-HAL-F01	HAL	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-N-HAL-F01	HAL	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-N-HAL-F01	HAL	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-N-HAL-F01	HAL	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-N-HAL-F01	HAL	Initial	13-MAR-19	1.000	ug/L
51324	51324-1-S-HAL-F01	Main- By Room 105, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-S-HAL-F01	Main- By Room 105, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-S-HAL-F01	Main- By Room 105, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-S-HAL-F01	Main- By Room 105, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-S-HAL-F01	Main- By Room 105, Fountain	Initial	13-MAR-19	1.000	ug/L
51324	51324-1-N-HAL-F02	Main- By Room 110, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-N-HAL-F02	Main- By Room 110, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-N-HAL-F02	Main- By Room 110, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-N-HAL-F02	Main- By Room 110, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-1-N-HAL-F02	Main- By Room 110, Fountain	Initial	13-MAR-19	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Flush180	31-JUL-20	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Initial	13-MAR-19	1.000	ug/L
51324	51324-2-S-HAL-F02	Main- By Room 210, Fountain	Initial	31-JUL-20	1.000	ug/L
51324	51324-3-N-HAL-F01	Main- By Room 305, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-N-HAL-F01	Main- By Room 305, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-N-HAL-F01	Main- By Room 305, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-N-HAL-F01	Main- By Room 305, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-N-HAL-F01	Main- By Room 305, Fountain	Initial	13-MAR-19	1.000	ug/L
51324	51324-3-S-HAL-F02	Main- By Room 310, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-S-HAL-F02	Main- By Room 310, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-S-HAL-F02	Main- By Room 310, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-S-HAL-F02	Main- By Room 310, Fountain	Flush180	13-MAR-19	1.000	ug/L
51324	51324-3-S-HAL-F02	Main- By Room 310, Fountain	Initial	13-MAR-19	1.000	ug/L
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Flush180	04-JUN-16	1.000	ppb
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Flush180	04-JUN-16	1.000	ppb
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Flush180	04-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Flush180	04-JUN-16	1.000	ppb
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Flush180	31-JUL-20	1.000	ug/L
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Flush180	06-JAN-21	1.000	ug/L
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Initial	04-JUN-16	1.000	ppb
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Initial	31-JUL-20	1.000	ug/L
51324	51324-B-KIT-KS02	Main- Kitchen East, Sink 2	Initial	06-JAN-21	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Flush180	13-MAR-19	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Flush180	13-MAR-19	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Flush180	13-MAR-19	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Flush180	13-MAR-19	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Flush180	06-JAN-21	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Initial	13-MAR-19	1.000	ug/L
51324	51324-B-E-KIT-KS01	Main- Kitchen North, Sink 1	Initial	06-JAN-21	1.000	ug/L
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Flush180	04-JUN-16	25.500	ppb
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Flush180	04-JUN-16	10.300	ppb
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Flush180	04-JUN-16	11.600	ppb
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Flush180	04-JUN-16	12.800	ppb
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Flush180	06-JAN-21	1.000	ug/L
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Initial	04-JUN-16	506.000	ppb
51324	51324-B-KIT-KS03	Main- Kitchen West, Sink 3	Initial	06-JAN-21	1.000	ug/L
51343	51343-1-HAL-F12	1st floor next to women's staff bathroom, Fountain	Flush180	28-SEP-22	1.000	ug/L
51343	51343-1-HAL-F12	1st floor next to women's staff bathroom, Fountain	Flush180	28-SEP-22	1.000	ug/L
51343	51343-1-HAL-F12	1st floor next to women's staff bathroom, Fountain	Flush180	28-SEP-22	1.000	ug/L
51343	51343-1-HAL-F12	1st floor next to women's staff bathroom, Fountain	Flush180	28-SEP-22	1.000	ug/L
51343	51343-1-HAL-F12	1st floor next to women's staff bathroom, Fountain	Initial	28-SEP-22	1.000	ug/L
51343	51343-1-HAL-F07	Branch- First Floor Corridor North, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F07	Branch- First Floor Corridor North, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F07	Branch- First Floor Corridor North, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F07	Branch- First Floor Corridor North, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F07	Branch- First Floor Corridor North, Fountain 1	Initial	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F08	Branch- First Floor Corridor South, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F08	Branch- First Floor Corridor South, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F08	Branch- First Floor Corridor South, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F08	Branch- First Floor Corridor South, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-HAL-F08	Branch- First Floor Corridor South, Fountain 2	Initial	04-JUN-16	1.000	ppb
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Flush180	04-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Flush180	31-JUL-20	1.000	ug/L
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-1-100-S01	Branch- Inside Room 100, Sink	Initial	31-JUL-20	1.000	ug/L
51343	51343-1-101-S02	Branch- Inside Room 101, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-101-S02	Branch- Inside Room 101, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-101-S02	Branch- Inside Room 101, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-101-S02	Branch- Inside Room 101, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-101-S02	Branch- Inside Room 101, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-1-102-S03	Branch- Inside Room 102, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-102-S03	Branch- Inside Room 102, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-102-S03	Branch- Inside Room 102, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-102-S03	Branch- Inside Room 102, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-102-S03	Branch- Inside Room 102, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-1-103-S04	Branch- Inside Room 103, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-103-S04	Branch- Inside Room 103, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-103-S04	Branch- Inside Room 103, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-103-S04	Branch- Inside Room 103, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-103-S04	Branch- Inside Room 103, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-1-104-S05	Branch- Inside Room 104, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-104-S05	Branch- Inside Room 104, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-104-S05	Branch- Inside Room 104, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-104-S05	Branch- Inside Room 104, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-104-S05	Branch- Inside Room 104, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-1-105-S06	Branch- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-105-S06	Branch- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-105-S06	Branch- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-105-S06	Branch- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-1-105-S06	Branch- Inside Room 105, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-B-KIT-KS01	Branch- Kitchen Sink, Center Faucet	Flush180	22-JUN-16	1.000	ppb
51343	51343-B-KIT-KS01	Branch- Kitchen Sink, Center Faucet	Flush180	22-JUN-16	1.000	ppb
51343	51343-B-KIT-KS01	Branch- Kitchen Sink, Center Faucet	Flush180	22-JUN-16	0.155	ppb
51343	51343-B-KIT-KS01	Branch- Kitchen Sink, Center Faucet	Flush180	22-JUN-16	0.466	ppb
51343	51343-B-KIT-KS01	Branch- Kitchen Sink, Center Faucet	Initial	22-JUN-16	1.590	ppb
51343	51343-B-KIT-KS02	Branch- Kitchen Sink, South Faucet	Flush180	22-JUN-16	0.424	ppb
51343	51343-B-KIT-KS02	Branch- Kitchen Sink, South Faucet	Flush180	22-JUN-16	1.190	ppb
51343	51343-B-KIT-	Branch- Kitchen Sink, South	Flush180	22-JUN-16	0.388	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02	Faucet				
51343	51343-B-KIT-KS02	Branch- Kitchen Sink, South Faucet	Flush180	22-JUN-16	0.388	ppb
51343	51343-B-KIT-KS02	Branch- Kitchen Sink, South Faucet	Initial	22-JUN-16	1.260	ppb
51343	51343-2-HAL-F01	Branch- Second Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F01	Branch- Second Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F01	Branch- Second Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F01	Branch- Second Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F01	Branch- Second Floor Corridor East, Fountain 1	Initial	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F02	Branch- Second Floor Corridor West, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F02	Branch- Second Floor Corridor West, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F02	Branch- Second Floor Corridor West, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-2-HAL-F02	Branch- Second Floor Corridor West, Fountain 2	Initial	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F02	Branch- Third Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F02	Branch- Third Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F02	Branch- Third Floor Corridor East, Fountain 1	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F02	Branch- Third Floor Corridor East, Fountain 1	Initial	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F03	Branch- Third Floor Corridor West, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F03	Branch- Third Floor Corridor West, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F03	Branch- Third Floor Corridor West, Fountain 2	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-HAL-F03	Branch- Third Floor Corridor West, Fountain 2	Initial	04-JUN-16	1.000	ppb
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	04-JUN-16	1.000	ppb
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	31-JUL-20	1.000	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	09-OCT-20	5.190	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	09-OCT-20	1.000	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	09-OCT-20	2.160	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	09-OCT-20	1.450	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	18-DEC-20	1.000	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	18-DEC-20	1.000	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	18-DEC-20	1.000	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Flush180	18-DEC-20	1.000	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Initial	04-JUN-16	1.000	ppb
51343	51343-3-TL-	Branch- Third Floor Teachers	Initial	31-JUL-20	10.500	ug/L

**Water Quality Assessment**  
**John H Hamline Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01	Lounge, Sink				
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Initial	09-OCT-20	1.590	ug/L
51343	51343-3-TL-S01	Branch- Third Floor Teachers Lounge, Sink	Initial	18-DEC-20	3.060	ug/L