



Sep 10, 2024

HANSON PARK

5411 W FULLERTON AVE, Chicago IL 60639.

Dear **HANSON PARK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HANSON PARK

5411 W FULLERTON AVE, Chicago IL 60639.

Estimadas familias de **HANSON PARK**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51121	51121-1-HAL-F03	Hallway across from Room 122, East Fountain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F03	Hallway across from Room 122, East Fountain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F03	Hallway across from Room 122, East Fountain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F03	Hallway across from Room 122, East Fountain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F03	Hallway across from Room 122, East Fountain 1	Initial	26-MAY-16	1.000	ppb
51121	51121-HAL-E-F04	Hallway across from Room 122, East Fountain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-HAL-E-F04	Hallway across from Room 122, East Fountain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-HAL-E-F04	Hallway across from Room 122, East Fountain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-HAL-E-F04	Hallway across from Room 122, East Fountain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-HAL-E-F04	Hallway across from Room 122, East Fountain 2	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F05	Hallway across from Room 122, East Fountain 3	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F05	Hallway across from Room 122, East Fountain 3	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F05	Hallway across from Room 122, East Fountain 3	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F05	Hallway across from Room 122, East Fountain 3	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F05	Hallway across from Room 122, East Fountain 3	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F06	Hallway across from Room 122, East Fountain 4	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F06	Hallway across from Room 122, East Fountain 4	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F06	Hallway across from Room 122, East Fountain 4	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F06	Hallway across from Room 122, East Fountain 4	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F06	Hallway across from Room 122, East Fountain 4	Initial	26-MAY-16	1.000	ppb
51121	51121-1-N-115-F11	Inside Kindergarten Room 115, Foutain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-N-115-F11	Inside Kindergarten Room 115, Foutain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-N-115-F11	Inside Kindergarten Room 115, Foutain 1	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-N-115-F11	Inside Kindergarten Room 115, Foutain 1	Flush180	31-JUL-20	1.000	ug/L
51121	51121-1-N-115-F11	Inside Kindergarten Room 115, Foutain 1	Initial	26-MAY-16	1.000	ppb
51121	51121-1-N-115-F11	Inside Kindergarten Room 115, Foutain 1	Initial	31-JUL-20	1.000	ug/L
51121	51121-1-115-F12	Inside Kindergarten Room 115, Foutain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-115-F12	Inside Kindergarten Room 115, Foutain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-115-F12	Inside Kindergarten Room 115, Foutain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-115-F12	Inside Kindergarten Room 115, Foutain 2	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-115-F12	Inside Kindergarten Room 115, Foutain 2	Initial	26-MAY-16	1.000	ppb
51121	51121-1-KIT-KS07	Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-KIT-KS07	Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-KIT-KS07	Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51121	51121-1-KIT-KS07	Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-KIT-KS07	Kitchen, Sink	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F14	Outside classroom 101, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F14	Outside classroom 101, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F14	Outside classroom 101, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F14	Outside classroom 101, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F14	Outside classroom 101, Fountain	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F10	Pod A across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F10	Pod A across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F10	Pod A across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F10	Pod A across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F10	Pod A across bathrooms, Fountain	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F09	Pod B across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F09	Pod B across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F09	Pod B across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F09	Pod B across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F09	Pod B across bathrooms, Fountain	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F08	Pod C across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F08	Pod C across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F08	Pod C across bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F08	Pod C across bathrooms, Fountain	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F02	Pod E across from girls toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F02	Pod E across from girls toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F02	Pod E across from girls toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F02	Pod E across from girls toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F02	Pod E across from girls toilet, Fountain	Initial	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F01	Pod F across from boys toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F01	Pod F across from boys toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F01	Pod F across from boys toilet, Fountain	Flush180	26-MAY-16	1.000	ppb
51121	51121-1-HAL-F01	Pod F across from boys toilet, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-HAL-F23	Modular- Hallway across bathroom, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-HAL-F23	Modular- Hallway across bathroom, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-HAL-F23	Modular- Hallway across bathroom, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-HAL-F23	Modular- Hallway across bathroom, Fountain 1	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-HAL-F23	Modular- Hallway across bathroom, Fountain 1	Initial	26-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Flush180	31-JUL-20	1.110	ug/L
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Initial	26-MAY-16	1.000	ppb
52212	52212-1-W-HAL-F24	Modular- Hallway across bathroom, Fountain 2	Initial	31-JUL-20	1.000	ug/L
52212	52212--1-001-F16	Modular- Room 001 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212--1-001-F16	Modular- Room 001 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212--1-001-F16	Modular- Room 001 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212--1-001-F16	Modular- Room 001 - South Wall, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-001-S15	Modular- Room 001 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-001-S15	Modular- Room 001 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-001-S15	Modular- Room 001 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-001-S15	Modular- Room 001 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-001-S15	Modular- Room 001 - South Wall, Sink	Initial	26-MAY-16	1.000	ppb
52212	52212-1-002-F17	Modular- Room 002 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-F17	Modular- Room 002 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-F17	Modular- Room 002 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-F17	Modular- Room 002 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-F17	Modular- Room 002 - South Wall, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-002-S18	Modular- Room 002 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-S18	Modular- Room 002 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-S18	Modular- Room 002 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-S18	Modular- Room 002 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-002-S18	Modular- Room 002 - South Wall, Sink	Initial	26-MAY-16	1.000	ppb
52212	52212-1-003-F20	Modular- Room 003 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-F20	Modular- Room 003 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-F20	Modular- Room 003 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-F20	Modular- Room 003 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-F20	Modular- Room 003 - South Wall, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-003-S19	Modular- Room 003 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-S19	Modular- Room 003 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-S19	Modular- Room 003 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-003-S19	Modular- Room 003 - South Wall, Sink	Initial	26-MAY-16	1.000	ppb
52212	52212-004-	Modular- Room 004 - South Wall,	Flush180	26-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F21	Fountain				
52212	52212-004-F21	Modular- Room 004 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-004-F21	Modular- Room 004 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-004-F21	Modular- Room 004 - South Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-004-F21	Modular- Room 004 - South Wall, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-004-S22	Modular- Room 004 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-004-S22	Modular- Room 004 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-004-S22	Modular- Room 004 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-004-S22	Modular- Room 004 - South Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-004-S22	Modular- Room 004 - South Wall, Sink	Initial	26-MAY-16	1.000	ppb
52212	52212-1-005-F26	Modular- Room 005 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-F26	Modular- Room 005 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-F26	Modular- Room 005 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-F26	Modular- Room 005 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-F26	Modular- Room 005 - North Wall, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-005-S25	Modular- Room 005 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-S25	Modular- Room 005 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-S25	Modular- Room 005 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-S25	Modular- Room 005 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-005-S25	Modular- Room 005 - North Wall, Sink	Initial	26-MAY-16	1.000	ppb
52212	52212-1-006-F27	Modular- Room 006 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-F27	Modular- Room 006 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-F27	Modular- Room 006 - North Wall, Fountain	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-F27	Modular- Room 006 - North Wall, Fountain	Initial	26-MAY-16	1.000	ppb
52212	52212-1-006-S28	Modular- Room 006 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-S28	Modular- Room 006 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-S28	Modular- Room 006 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-S28	Modular- Room 006 - North Wall, Sink	Flush180	26-MAY-16	1.000	ppb
52212	52212-1-006-S28	Modular- Room 006 - North Wall, Sink	Initial	26-MAY-16	1.000	ppb
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Flush180	31-JUL-20	9.590	ug/L
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Flush180	29-SEP-20	1.000	ug/L
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Flush180	29-SEP-20	1.000	ug/L
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Flush180	29-SEP-20	1.000	ug/L
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Flush180	29-SEP-20	1.000	ug/L
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Initial	31-JUL-20	8.050	ug/L
53425	53425-1-S-HAL-F24	1st Floor, Hallway	Initial	29-SEP-20	1.000	ug/L
53425	53425-2-W-	Branch- 2nd floor Across from	Flush180	26-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	room 207, Fountain				
53425	53425-2-W-HAL-F01	Branch- 2nd floor Across from room 207, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-2-W-HAL-F01	Branch- 2nd floor Across from room 207, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-2-W-HAL-F01	Branch- 2nd floor Across from room 207, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-2-W-HAL-F01	Branch- 2nd floor Across from room 207, Fountain	Flush180	31-JUL-20	1.600	ug/L
53425	53425-2-W-HAL-F01	Branch- 2nd floor Across from room 207, Fountain	Initial	26-MAY-16	1.000	ppb
53425	53425-2-W-HAL-F01	Branch- 2nd floor Across from room 207, Fountain	Initial	31-JUL-20	1.500	ug/L
53425	53425-1-HAL-F32	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F32	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F32	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F32	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F31	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F31	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F31	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F31	Branch- Hallway South Wall by bathrooms, Fountain	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F31	Branch- Hallway South Wall by bathrooms, Fountain	Initial	26-MAY-16	1.000	ppb
53425	53425-1-HAL-F32	Branch- Hallway South Wall by bathrooms, Fountain	Initial	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS29	Branch- Kitchen East Wall, Sink 1	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS29	Branch- Kitchen East Wall, Sink 1	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS29	Branch- Kitchen East Wall, Sink 1	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS29	Branch- Kitchen East Wall, Sink 1	Initial	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS30	Branch- Kitchen East Wall, Sink 2	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS30	Branch- Kitchen East Wall, Sink 2	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS30	Branch- Kitchen East Wall, Sink 2	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS30	Branch- Kitchen East Wall, Sink 2	Flush180	26-MAY-16	1.000	ppb
53425	53425-1-KIT-KS30	Branch- Kitchen East Wall, Sink 2	Initial	26-MAY-16	1.000	ppb