



Sep 10, 2024

HARVARD

7527 S HARVARD AVE, Chicago IL 60620.

Dear **HARVARD** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HARVARD

7527 S HARVARD AVE, Chicago IL 60620.

Estimadas familias de **HARVARD**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51378	51378-2-HAL-BF01	By Room 201	Flush180	02-FEB-21	5.000	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	02-FEB-21	3.450	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	05-JAN-21	8.500	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	25-FEB-21	2.030	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	25-FEB-21	1.470	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	25-FEB-21	1.380	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	25-FEB-21	1.460	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	02-FEB-21	1.000	ug/L
51378	51378-2-HAL-BF01	By Room 201	Flush180	02-FEB-21	1.510	ug/L
51378	51378-2-HAL-BF01	By Room 201	Initial	02-FEB-21	5.270	ug/L
51378	51378-2-HAL-BF01	By Room 201	Initial	05-JAN-21	37.500	ug/L
51378	51378-2-HAL-BF01	By Room 201	Initial	25-FEB-21	4.570	ug/L
51378	51378-3-HAL-BF01	By room 301	Flush180	05-JAN-21	1.000	ug/L
51378	51378-3-HAL-BF01	By room 301	Initial	05-JAN-21	1.000	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	25-MAY-16	1.370	ppb
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	25-MAY-16	0.907	ppb
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	25-MAY-16	0.856	ppb
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	25-MAY-16	0.992	ppb
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	11-DEC-19	1.750	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	11-DEC-19	1.750	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	11-DEC-19	2.240	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	11-DEC-19	1.680	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Flush180	25-AUG-20	1.190	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Initial	25-MAY-16	1.290	ppb
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Initial	11-DEC-19	1.230	ug/L
51378	51378-1-E-HAL-F02	Fountain Across from Room 101	Initial	25-AUG-20	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	07-FEB-23	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	07-FEB-23	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	07-FEB-23	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	07-FEB-23	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	25-MAY-16	1.000	ppb
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	25-MAY-16	1.000	ppb
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	25-MAY-16	1.000	ppb
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	25-MAY-16	1.000	ppb
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	25-MAY-16	1.000	ppb
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	11-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	11-DEC-19	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	11-DEC-19	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Flush180	11-DEC-19	1.360	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Initial	07-FEB-23	1.000	ug/L
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Initial	25-MAY-16	1.000	ppb
51378	51378-2-W-HAL-F01	Fountain Across from Upper Balcony	Initial	11-DEC-19	1.000	ug/L
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	21-JUL-16	2.550	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	21-JUL-16	1.350	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	21-JUL-16	1.200	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	21-JUL-16	1.240	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	01-SEP-16	1.000	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	01-SEP-16	1.000	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	01-SEP-16	1.000	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Flush180	01-SEP-16	1.000	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Initial	01-SEP-16	4.400	ppb
51378	51378-2-HAL-F30	Fountain Next To Janitor's Closet	Initial	21-JUL-16	30.800	ppb
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	25-MAY-16	2.990	ppb
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	25-MAY-16	3.170	ppb
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	25-MAY-16	3.100	ppb
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	25-MAY-16	2.760	ppb
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	11-DEC-19	2.010	ug/L
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	11-DEC-19	1.980	ug/L
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	11-DEC-19	2.010	ug/L
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Flush180	11-DEC-19	1.000	ug/L
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Initial	25-MAY-16	12.700	ppb
51378	51378-2-E-HAL-F02	Fountain Next to Room 203	Initial	11-DEC-19	2.100	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	25-MAY-16	1.550	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	25-MAY-16	1.640	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	25-MAY-16	3.110	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	25-MAY-16	1.570	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	21-JUL-16	2.190	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	21-JUL-16	2.330	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	21-JUL-16	2.710	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	21-JUL-16	5.240	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	01-SEP-16	1.000	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	01-SEP-16	1.000	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	01-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	01-SEP-16	1.000	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	11-DEC-19	1.000	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	11-DEC-19	1.000	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	11-DEC-19	1.000	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	11-DEC-19	1.000	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Flush180	25-AUG-20	1.050	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Initial	25-MAY-16	17.000	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Initial	01-SEP-16	2.400	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Initial	21-JUL-16	16.700	ppb
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Initial	11-DEC-19	1.000	ug/L
51378	51378-3-S-HAL-F01	Fountain Next to Room 303	Initial	25-AUG-20	1.910	ug/L
51378	51378-B-N-KIT-KS01	Kitchen Sink Left	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS01	Kitchen Sink Left	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS01	Kitchen Sink Left	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS01	Kitchen Sink Left	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS01	Kitchen Sink Left	Initial	07-FEB-23	1.660	ug/L
51378	51378-B-N-KIT-KS02	Kitchen Sink Right	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS02	Kitchen Sink Right	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS02	Kitchen Sink Right	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS02	Kitchen Sink Right	Flush180	07-FEB-23	1.000	ug/L
51378	51378-B-N-KIT-KS02	Kitchen Sink Right	Initial	07-FEB-23	1.800	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.388	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.381	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	11-DEC-19	1.000	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	11-DEC-19	1.000	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	11-DEC-19	1.000	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	11-DEC-19	1.000	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	05-JAN-21	1.000	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.376	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.388	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.376	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.441	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.381	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Flush180	25-MAY-16	0.441	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Initial	11-DEC-19	1.190	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Initial	05-JAN-21	1.000	ug/L
51378	51378-B-N-CAF-S01	Lunchroom Sink	Initial	25-MAY-16	0.410	ppb
51378	51378-B-N-CAF-S01	Lunchroom Sink	Initial	25-MAY-16	0.410	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	CAF-S01					
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Initial	11-DEC-19	1.180	ug/L
52463	52463-2-S-HAL-F04	2nd Floor, South End, Hallway	Initial	07-FEB-23	1.000	ug/L
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	11-DEC-19	1.740	ug/L
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	11-DEC-19	1.160	ug/L
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	11-DEC-19	1.440	ug/L
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.719	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.564	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.489	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.564	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.719	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.595	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.489	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Flush180	25-MAY-16	0.595	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Initial	11-DEC-19	1.510	ug/L
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Initial	25-MAY-16	1.600	ppb
52463	52463-1-E-HAL-F03	Annex - Fountain Across from Room 105	Initial	25-MAY-16	1.600	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.000	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.180	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.320	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.350	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.000	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.180	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.350	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	02-FEB-21	3.320	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	02-FEB-21	2.480	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	02-FEB-21	1.700	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	02-FEB-21	1.520	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	05-JAN-21	10.500	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Room 205				
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	05-JAN-21	2.340	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	05-JAN-21	1.800	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	05-JAN-21	1.980	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-FEB-21	6.470	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-FEB-21	1.650	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-FEB-21	1.330	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-FEB-21	1.340	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	15-DEC-20	8.720	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	15-DEC-20	4.540	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	15-DEC-20	3.770	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	15-DEC-20	3.100	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-AUG-20	1.950	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	13-OCT-20	3.520	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	13-OCT-20	5.580	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	13-OCT-20	2.910	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	13-OCT-20	2.720	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Flush180	25-MAY-16	1.320	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	02-FEB-21	13.000	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	05-JAN-21	14.900	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	25-FEB-21	12.400	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	15-DEC-20	4.210	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	25-AUG-20	5.370	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	13-OCT-20	1.670	ug/L
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	25-MAY-16	1.170	ppb
52463	52463-2-HAL-F03	Annex - Fountain Across from Room 205	Initial	25-MAY-16	1.170	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	11-DEC-19	1.040	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.726	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.717	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.717	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.726	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.726	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.726	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.716	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Flush180	25-MAY-16	0.716	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Initial	11-DEC-19	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Initial	07-FEB-23	1.000	ug/L
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Initial	25-MAY-16	0.606	ppb
52463	52463-1-E-105-F05	Annex - Fountain Inside Room 105	Initial	25-MAY-16	0.606	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.840	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.840	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.668	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.668	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.587	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.587	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.678	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-MAY-16	0.678	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	11-DEC-19	2.020	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	11-DEC-19	2.610	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	11-DEC-19	2.680	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	11-DEC-19	2.810	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	22-APR-20	3.520	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	22-APR-20	3.250	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	22-APR-20	3.080	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	22-APR-20	3.140	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	02-FEB-21	1.290	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	02-FEB-21	1.110	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	02-FEB-21	1.000	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	02-FEB-21	1.000	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	05-JAN-21	5.930	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-FEB-21	14.000	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-FEB-21	11.700	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-FEB-21	9.190	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-FEB-21	6.120	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	05-JAN-21	6.220	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	05-JAN-21	5.300	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	05-JAN-21	7.440	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	15-DEC-20	9.290	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	15-DEC-20	7.950	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	15-DEC-20	4.440	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	15-DEC-20	3.310	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	25-AUG-20	4.880	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	13-OCT-20	5.980	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	13-OCT-20	4.540	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	13-OCT-20	4.060	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Flush180	13-OCT-20	3.810	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	25-MAY-16	2.980	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	25-MAY-16	2.980	ppb
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	11-DEC-19	14.400	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	22-APR-20	4.340	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	02-FEB-21	19.800	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	05-JAN-21	7.210	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	25-FEB-21	29.900	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	15-DEC-20	35.100	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	25-AUG-20	19.700	ug/L
52463	52463-1-S-HAL-F01	Annex - Fountain Next to Room 111	Initial	13-OCT-20	11.600	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.722	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.965	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.999	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.999	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.610	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.722	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.610	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Flush180	25-MAY-16	0.965	ppb
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Initial	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Initial	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F01	Annex - Fountain Next to Room 213	Initial	25-MAY-16	0.787	ppb
52463	52463-2-S-	Annex - Fountain Next to Room	Initial	25-MAY-16	0.787	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	213				
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	0.496	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	0.414	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	0.496	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	0.414	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	1.210	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	1.210	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	0.381	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Flush180	25-MAY-16	0.381	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Initial	11-DEC-19	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Initial	07-FEB-23	1.000	ug/L
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Initial	25-MAY-16	0.163	ppb
52463	52463-2-S-HAL-F02	Annex - Fountain Outside Girls Toilet	Initial	25-MAY-16	0.163	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	11-DEC-19	1.100	ug/L
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	11-DEC-19	1.630	ug/L
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	11-DEC-19	2.180	ug/L
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	11-DEC-19	1.660	ug/L
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	1.030	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	1.030	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	0.903	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	0.905	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	1.130	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	0.903	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	0.905	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Flush180	25-MAY-16	1.130	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Initial	11-DEC-19	2.200	ug/L
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Initial	25-MAY-16	1.300	ppb
52463	52463-1-N-105-S04	Annex - Sink Inside Room 105	Initial	25-MAY-16	1.300	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.479	ppb
52463	52463-1-S-	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.423	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02					
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.456	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.423	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.456	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.797	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.479	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	11-DEC-19	1.000	ug/L
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Flush180	25-MAY-16	0.797	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Initial	11-DEC-19	1.000	ug/L
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Initial	25-MAY-16	0.278	ppb
52463	52463-1-S-HAL-F02	Annex - Sink Next to Room 108	Initial	25-MAY-16	0.278	ppb
52463	52463-1-HAL-F02	Annex- Fountain Next to 113, left	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-HAL-F02	Annex- Fountain Next to 113, left	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-HAL-F02	Annex- Fountain Next to 113, left	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-HAL-F02	Annex- Fountain Next to 113, left	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-HAL-F02	Annex- Fountain Next to 113, left	Initial	07-FEB-23	3.360	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	07-FEB-23	3.030	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	07-FEB-23	3.780	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	07-FEB-23	3.650	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	07-FEB-23	3.040	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	28-FEB-23	1.000	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	28-FEB-23	1.000	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Flush180	28-FEB-23	1.000	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Initial	07-FEB-23	10.500	ug/L
52463	52463-1-HAL-F03	Annex- Fountain Next to 113, right	Initial	28-FEB-23	3.130	ug/L
52463	52463-1-105-F01	Annex- Fountain in Room 105	Flush180	07-FEB-23	1.040	ug/L
52463	52463-1-105-F01	Annex- Fountain in Room 105	Flush180	07-FEB-23	1.070	ug/L
52463	52463-1-105-F01	Annex- Fountain in Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-105-F01	Annex- Fountain in Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-105-F01	Annex- Fountain in Room 105	Initial	07-FEB-23	1.220	ug/L
52463	52463-1-HAL-RBF01	Annex- Retrofit Bottle Filler by Room 105	Flush180	07-FEB-23	1.130	ug/L
52463	52463-1-HAL-RBF01	Annex- Retrofit Bottle Filler by Room 105	Flush180	07-FEB-23	1.170	ug/L
52463	52463-1-HAL-RBF01	Annex- Retrofit Bottle Filler by Room 105	Flush180	07-FEB-23	1.120	ug/L
52463	52463-1-HAL-RBF01	Annex- Retrofit Bottle Filler by Room 105	Flush180	07-FEB-23	1.180	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52463	52463-1-HAL-RBF01	Annex- Retrofit Bottle Filler by Room 105	Initial	07-FEB-23	1.170	ug/L
52463	52463-1-105-S01	Annex- Sink in Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-105-S01	Annex- Sink in Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-105-S01	Annex- Sink in Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-105-S01	Annex- Sink in Room 105	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-105-S01	Annex- Sink in Room 105	Initial	07-FEB-23	1.000	ug/L
52463	52463-1-108-S01	Annex- Sink in Room 108	Flush180	07-FEB-23	1.020	ug/L
52463	52463-1-108-S01	Annex- Sink in Room 108	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-108-S01	Annex- Sink in Room 108	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-108-S01	Annex- Sink in Room 108	Flush180	07-FEB-23	1.000	ug/L
52463	52463-1-108-S01	Annex- Sink in Room 108	Initial	07-FEB-23	1.000	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	02-FEB-21	31.200	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	02-FEB-21	23.700	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	02-FEB-21	15.700	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	02-FEB-21	14.900	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	25-FEB-21	19.200	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	25-FEB-21	10.100	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	25-FEB-21	8.510	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	25-FEB-21	8.420	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Flush180	05-JAN-21	17.300	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Initial	02-FEB-21	25.100	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Initial	25-FEB-21	25.200	ug/L
52463	52463-1-HAL-BF01	By room 105, Annex	Initial	05-JAN-21	49.700	ug/L