



Sep 10, 2024

HAY

1018 N LARAMIE AVE, Chicago IL 60651.

Dear **HAY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HAY

1018 N LARAMIE AVE, Chicago IL 60651.

Estimadas familias de **HAY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	03-JUN-16	0.407	ppb
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	03-JUN-16	0.615	ppb
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	03-JUN-16	0.197	ppb
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Initial	03-JUN-16	0.682	ppb
51091	51091-1-HAL-F04	Across From Room 107, Left Fountain	Initial	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	03-JUN-16	0.136	ppb
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Initial	03-JUN-16	0.326	ppb
51091	51091-1-KIT-KS02	Kitchen, Center Sink	Initial	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	03-JUN-16	0.565	ppb
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	03-JUN-16	0.132	ppb
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Initial	03-JUN-16	0.278	ppb
51091	51091-1-KIT-KS01	Kitchen, Left Sink	Initial	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	03-JUN-16	0.259	ppb
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	03-JUN-16	0.124	ppb
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	03-JUN-16	0.137	ppb
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	03-JUN-16	0.125	ppb
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	05-APR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Initial	03-JUN-16	0.401	ppb
51091	51091-1-KIT-KS03	Kitchen, Right Sink	Initial	05-APR-22	1.000	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	17-SEP-21	1.280	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	17-SEP-21	1.820	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	17-SEP-21	1.710	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	17-SEP-21	1.470	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	05-APR-22	1.430	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	05-APR-22	1.370	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	05-APR-22	2.670	ug/L
51091	51091-1-110-S01	Left Sink in 110	Flush180	05-APR-22	1.420	ug/L
51091	51091-1-110-S01	Left Sink in 110	Initial	17-SEP-21	3.130	ug/L
51091	51091-1-110-S01	Left Sink in 110	Initial	05-APR-22	1.940	ug/L
51091	51091-3-HAL-F02	Main building, Fountain Next to Room 310 (Hallway)	Flush180	04-NOV-16	0.204	ppb
51091	51091-3-HAL-F02	Main building, Fountain Next to Room 310 (Hallway)	Flush180	04-NOV-16	0.152	ppb
51091	51091-3-HAL-F02	Main building, Fountain Next to Room 310 (Hallway)	Flush180	04-NOV-16	0.181	ppb
51091	51091-3-HAL-F02	Main building, Fountain Next to Room 310 (Hallway)	Flush180	04-NOV-16	0.157	ppb
51091	51091-3-HAL-F02	Main building, Fountain Next to Room 310 (Hallway)	Initial	04-NOV-16	0.724	ppb
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	03-JUN-16	0.995	ppb
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	03-JUN-16	0.802	ppb
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	03-JUN-16	0.899	ppb
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	03-JUN-16	0.864	ppb
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Initial	03-JUN-16	0.955	ppb
51091	51091-1-HAL-F12	Outside Room 102, Right Fountain	Initial	05-APR-22	1.000	ug/L
51091	51091-1-HAL-BF01	Outside Room 102, Bottle Filler	Flush180	05-APR-22	1.070	ug/L
51091	51091-1-HAL-BF01	Outside Room 102, Bottle Filler	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-BF01	Outside Room 102, Bottle Filler	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-BF01	Outside Room 102, Bottle Filler	Initial	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F11	Outside Room 102, Left Fountain	Flush180	03-JUN-16	13.600	ppb
51091	51091-1-HAL-F11	Outside Room 102, Left Fountain	Flush180	03-JUN-16	13.300	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51091	51091-1-HAL-F11	Outside Room 102, Left Fountain	Flush180	03-JUN-16	8.860	ppb
51091	51091-1-HAL-F11	Outside Room 102, Left Fountain	Flush180	03-JUN-16	6.760	ppb
51091	51091-1-HAL-F11	Outside Room 102, Left Fountain	Initial	03-JUN-16	8.040	ppb
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Initial	03-JUN-16	1.270	ppb
51091	51091-1-HAL-F05	Outside Room 107, Center Fountain	Initial	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	03-JUN-16	0.137	ppb
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	03-JUN-16	0.272	ppb
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	05-APR-22	2.730	ug/L
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Initial	03-JUN-16	0.399	ppb
51091	51091-1-HAL-F06	Outside Room 107, Right Fountain	Initial	05-APR-22	2.790	ug/L
51091	51091-2-HAL-F09	Outside Room 202, Fountain	Flush180	03-JUN-16	0.837	ppb
51091	51091-2-HAL-F09	Outside Room 202, Fountain	Flush180	03-JUN-16	0.760	ppb
51091	51091-2-HAL-F09	Outside Room 202, Fountain	Flush180	03-JUN-16	0.649	ppb
51091	51091-2-HAL-F09	Outside Room 202, Fountain	Flush180	03-JUN-16	0.935	ppb
51091	51091-2-HAL-F09	Outside Room 202, Fountain	Initial	03-JUN-16	0.716	ppb
51091	51091-2-HAL-BF02	Outside Room 207, Bottle Filler	Flush180	05-APR-22	1.130	ug/L
51091	51091-2-HAL-BF02	Outside Room 207, Bottle Filler	Flush180	05-APR-22	1.060	ug/L
51091	51091-2-HAL-BF02	Outside Room 207, Bottle Filler	Flush180	05-APR-22	1.000	ug/L
51091	51091-2-HAL-BF02	Outside Room 207, Bottle Filler	Flush180	05-APR-22	1.000	ug/L
51091	51091-2-HAL-BF02	Outside Room 207, Bottle Filler	Initial	05-APR-22	1.020	ug/L
51091	51091-2-HAL-F02	Outside Room 207, Fountain 2	Flush180	03-JUN-16	0.444	ppb
51091	51091-2-HAL-F02	Outside Room 207, Fountain 2	Flush180	03-JUN-16	0.607	ppb
51091	51091-2-HAL-F02	Outside Room 207, Fountain 2	Flush180	03-JUN-16	0.618	ppb
51091	51091-2-HAL-F02	Outside Room 207, Fountain 2	Flush180	03-JUN-16	0.833	ppb
51091	51091-2-HAL-F02	Outside Room 207, Fountain 2	Initial	03-JUN-16	2.070	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	03-JUN-16	0.959	ppb
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	03-JUN-16	1.110	ppb
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	03-JUN-16	1.180	ppb
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	05-APR-22	1.060	ug/L
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Initial	03-JUN-16	0.880	ppb
51091	51091-2-HAL-F01	Outside Room 207, Left Fountain	Initial	05-APR-22	3.070	ug/L
51091	51091-3-HAL-BF03	Outside Room 302, Bottle Filler	Flush180	05-APR-22	1.140	ug/L
51091	51091-3-HAL-BF03	Outside Room 302, Bottle Filler	Flush180	05-APR-22	1.030	ug/L
51091	51091-3-HAL-BF03	Outside Room 302, Bottle Filler	Flush180	05-APR-22	1.030	ug/L
51091	51091-3-HAL-BF03	Outside Room 302, Bottle Filler	Flush180	05-APR-22	1.200	ug/L
51091	51091-3-HAL-BF03	Outside Room 302, Bottle Filler	Initial	05-APR-22	1.000	ug/L
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Flush180	03-JUN-16	0.691	ppb
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Flush180	03-JUN-16	0.888	ppb
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Flush180	03-JUN-16	0.689	ppb
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Flush180	03-JUN-16	0.851	ppb
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Flush180	31-JUL-20	3.880	ug/L
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Initial	03-JUN-16	0.483	ppb
51091	51091-3-HAL-F03	Outside Room 302, Fountain	Initial	31-JUL-20	3.040	ug/L
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	03-JUN-16	0.962	ppb
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	03-JUN-16	0.866	ppb
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	03-JUN-16	1.130	ppb
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	03-JUN-16	0.979	ppb
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	05-APR-22	1.150	ug/L
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	05-APR-22	1.050	ug/L
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	05-APR-22	1.150	ug/L
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Flush180	05-APR-22	1.070	ug/L
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Initial	03-JUN-16	0.659	ppb
51091	51091-3-HAL-F04	Outside Room 302, Right Fountain	Initial	05-APR-22	1.240	ug/L
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	03-JUN-16	0.965	ppb
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	03-JUN-16	1.030	ppb
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	03-JUN-16	0.922	ppb
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	03-JUN-16	1.040	ppb
51091	51091-3-HAL-	Outside Room 308, Fountain	Flush180	05-APR-22	3.490	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	05-APR-22	3.790	ug/L
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	05-APR-22	3.890	ug/L
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Flush180	05-APR-22	3.870	ug/L
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Initial	03-JUN-16	1.160	ppb
51091	51091-3-HAL-F01	Outside Room 308, Fountain	Initial	05-APR-22	3.350	ug/L
51091	51091-1-104-F09	Room 104, Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-104-F09	Room 104, Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-104-F09	Room 104, Fountain	Flush180	03-JUN-16	1.000	ppb
51091	51091-1-104-F09	Room 104, Fountain	Flush180	03-JUN-16	0.152	ppb
51091	51091-1-104-F09	Room 104, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-F09	Room 104, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-F09	Room 104, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-F09	Room 104, Fountain	Initial	03-JUN-16	1.000	ppb
51091	51091-1-104-F09	Room 104, Fountain	Initial	05-APR-22	1.000	ug/L
51091	51091-1-104-S10	Room 104, Sink	Flush180	03-JUN-16	0.178	ppb
51091	51091-1-104-S10	Room 104, Sink	Flush180	03-JUN-16	0.225	ppb
51091	51091-1-104-S10	Room 104, Sink	Flush180	03-JUN-16	0.439	ppb
51091	51091-1-104-S10	Room 104, Sink	Flush180	03-JUN-16	5.270	ppb
51091	51091-1-104-S10	Room 104, Sink	Initial	03-JUN-16	5.750	ppb
51091	51091-1-107-F07	Room 107, Fountain	Flush180	03-JUN-16	0.134	ppb
51091	51091-1-107-F07	Room 107, Fountain	Flush180	03-JUN-16	0.145	ppb
51091	51091-1-107-F07	Room 107, Fountain	Flush180	03-JUN-16	0.198	ppb
51091	51091-1-107-F07	Room 107, Fountain	Flush180	03-JUN-16	0.132	ppb
51091	51091-1-107-F07	Room 107, Fountain	Initial	03-JUN-16	0.304	ppb
51091	51091-1-107-F02	Room 107, Fountain	Flush180	31-JUL-20	1.000	ug/L
51091	51091-1-107-F02	Room 107, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-F02	Room 107, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-F02	Room 107, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-F02	Room 107, Fountain	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-F02	Room 107, Fountain	Initial	31-JUL-20	1.000	ug/L
51091	51091-1-107-F02	Room 107, Fountain	Initial	05-APR-22	1.000	ug/L
51091	51091-1-107-S08	Room 107, Sink	Flush180	03-JUN-16	0.244	ppb
51091	51091-1-107-S08	Room 107, Sink	Flush180	03-JUN-16	0.122	ppb
51091	51091-1-107-S08	Room 107, Sink	Flush180	03-JUN-16	0.184	ppb
51091	51091-1-107-S08	Room 107, Sink	Flush180	03-JUN-16	0.376	ppb
51091	51091-1-107-S08	Room 107, Sink	Initial	03-JUN-16	0.341	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51091	51091-1-104-S01	Sink in 104	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Initial	17-SEP-21	1.000	ug/L
51091	51091-1-104-S01	Sink in 104	Initial	05-APR-22	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	17-SEP-21	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Flush180	05-APR-22	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Initial	17-SEP-21	1.000	ug/L
51091	51091-1-107-S01	Sink in 107	Initial	05-APR-22	1.000	ug/L