



Sep 10, 2024

HEALY

3010 S PARNELL AVE, Chicago IL 60616.

Dear **HEALY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HEALY

3010 S PARNELL AVE, Chicago IL 60616.

Estimadas familias de **HEALY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51237	51237-1-W-KIT-KS04		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-KIT-KS04		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-KIT-KS04		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-KIT-KS04		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-BF01		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-BF01		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-BF01		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-BF01		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS03		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS03		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS03		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS03		Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-KIT-KS04		Initial	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-BF01		Initial	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS03		Initial	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	12-MAY-17	25.000	ppb
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	12-MAY-17	14.000	ppb
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	12-MAY-17	16.000	ppb
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	12-MAY-17	12.700	ppb
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Initial	12-MAY-17	39.400	ppb
51237	51237-1-E-HAL-F04	1st Floor Outside Lunch Room Right Fountain	Initial	30-MAY-19	1.000	ug/L
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	03-JUN-16	0.435	ppb
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	03-JUN-16	0.478	ppb
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	03-JUN-16	0.427	ppb
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	03-JUN-16	0.419	ppb
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	30-MAY-19	1.010	ug/L
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Initial	03-JUN-16	0.482	ppb
51237	51237-1-S-HAL-F05	Main. 1st Floor Hallway Outside Room 101, Fountain	Initial	30-MAY-19	1.270	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	03-JUN-16	0.275	ppb
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	03-JUN-16	0.353	ppb
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	03-JUN-16	0.550	ppb
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	03-JUN-16	0.497	ppb
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Initial	03-JUN-16	0.434	ppb
51237	51237-1-N-KIT-KS01	Main. 1st Floor Kitchen, Sink 1 left dish wash	Initial	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	03-JUN-16	1.090	ppb
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	03-JUN-16	0.504	ppb
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	03-JUN-16	5.180	ppb
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	03-JUN-16	0.604	ppb
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Flush180	30-JUL-20	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Initial	03-JUN-16	2.050	ppb
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Initial	30-MAY-19	1.000	ug/L
51237	51237-1-N-KIT-KS02	Main. 1st Floor Kitchen, Sink 2	Initial	30-JUL-20	1.000	ug/L
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Initial	03-JUN-16	0.124	ppb
51237	51237-1-W-HAL-F01	Main. 1st Floor Outside Main Office, Fountain 1	Initial	30-MAY-19	1.000	ug/L
51237	51237-1-W-HAL-F02	Main. 1st Floor Outside Main Office, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F02	Main. 1st Floor Outside Main Office, Fountain 2	Flush180	03-JUN-16	0.335	ppb
51237	51237-1-W-HAL-F02	Main. 1st Floor Outside Main Office, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F02	Main. 1st Floor Outside Main Office, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51237	51237-1-W-HAL-F02	Main. 1st Floor Outside Main Office, Fountain 2	Flush180	30-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Washroom, Fountain 2				
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Flush180	30-JUL-20	1.390	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Flush180	02-OCT-20	1.000	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Flush180	02-OCT-20	1.000	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Flush180	02-OCT-20	1.000	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Flush180	02-OCT-20	1.000	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Initial	03-JUN-16	0.752	ppb
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Initial	30-MAY-19	1.000	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Initial	30-JUL-20	7.720	ug/L
51237	51237-2-W-HAL-F02	Main. 2nd Floor by Girls Washroom, Fountain 2	Initial	02-OCT-20	1.000	ug/L
51237	51237-2-HAL-BF01	Main. 2nd Floor by Girls Washroom, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-BF01	Main. 2nd Floor by Girls Washroom, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-BF01	Main. 2nd Floor by Girls Washroom, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-BF01	Main. 2nd Floor by Girls Washroom, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-BF01	Main. 2nd Floor by Girls Washroom, Left Bottle Filler	Initial	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F03	Main. 2nd Floor by Girls Washroom, Left Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F03	Main. 2nd Floor by Girls Washroom, Left Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F03	Main. 2nd Floor by Girls Washroom, Left Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F03	Main. 2nd Floor by Girls Washroom, Left Fountain	Initial	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F05	Main. 2nd Floor by Girls Washroom, Right Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F05	Main. 2nd Floor by Girls Washroom, Right Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F05	Main. 2nd Floor by Girls Washroom, Right Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-2-HAL-F05	Main. 2nd Floor by Girls Washroom, Right Fountain	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF03	Main. Outside 105 / across from library, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF03	Main. Outside 105 / across from library, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF03	Main. Outside 105 / across from library, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF03	Main. Outside 105 / across from library, Left Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF03	Main. Outside 105 / across from library, Left Bottle Filler	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F11	Main. Outside 105 / across from library, Left fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F11	Main. Outside 105 / across from library, Left fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F11	Main. Outside 105 / across from library, Left fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F11	Main. Outside 105 / across from library, Left fountain	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F12	Main. Outside 105 / across from library, right fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F12	Main. Outside 105 / across from library, right fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-	Main. Outside 105 / across from	Flush180	13-SEP-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12	library, right fountain				
51237	51237-1-HAL-F12	Main. Outside 105 / across from library, right fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F12	Main. Outside 105 / across from library, right fountain	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F09	Main. Outside auditorium/ across from 101, left Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F09	Main. Outside auditorium/ across from 101, left Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F09	Main. Outside auditorium/ across from 101, left Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F09	Main. Outside auditorium/ across from 101, left Fountain	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF02	Main. Outside auditorium/ across from 101, left bottle filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF02	Main. Outside auditorium/ across from 101, left bottle filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF02	Main. Outside auditorium/ across from 101, left bottle filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF02	Main. Outside auditorium/ across from 101, left bottle filler	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-BF02	Main. Outside auditorium/ across from 101, left bottle filler	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F10	Main. Outside auditorium/ across from 101, right Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F10	Main. Outside auditorium/ across from 101, right Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F10	Main. Outside auditorium/ across from 101, right Fountain	Flush180	13-SEP-22	1.000	ug/L
51237	51237-1-HAL-F10	Main. Outside auditorium/ across from 101, right Fountain	Initial	13-SEP-22	1.000	ug/L
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	03-JUN-16	42.000	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	03-JUN-16	38.700	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	03-JUN-16	38.500	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	03-JUN-16	55.400	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	27-JUL-16	2.100	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	27-JUL-16	1.000	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	27-JUL-16	1.000	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	12-MAY-17	14.600	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	12-MAY-17	14.600	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	12-MAY-17	22.400	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	12-MAY-17	11.700	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F03	Outside lunch room left	Flush180	30-MAY-19	1.000	ug/L
51237	51237-1-E-HAL-F03	Outside lunch room left	Initial	03-JUN-16	63.700	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Initial	27-JUL-16	1.000	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Initial	12-MAY-17	17.100	ppb
51237	51237-1-E-HAL-F03	Outside lunch room left	Initial	30-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51260	51260-1-KIT-KS03	Annex. 1st Floor Kitchen SW, Sink 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-KIT-KS03	Annex. 1st Floor Kitchen SW, Sink 1	Flush180	03-JUN-16	0.289	ppb
51260	51260-1-KIT-KS03	Annex. 1st Floor Kitchen SW, Sink 1	Flush180	03-JUN-16	0.140	ppb
51260	51260-1-KIT-KS03	Annex. 1st Floor Kitchen SW, Sink 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-KIT-KS03	Annex. 1st Floor Kitchen SW, Sink 1	Initial	03-JUN-16	0.124	ppb
51260	51260-1-KIT-KS04	Annex. 1st Floor Kitchen SW, Sink 2	Flush180	03-JUN-16	1.040	ppb
51260	51260-1-KIT-KS04	Annex. 1st Floor Kitchen SW, Sink 2	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-KIT-KS04	Annex. 1st Floor Kitchen SW, Sink 2	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-KIT-KS04	Annex. 1st Floor Kitchen SW, Sink 2	Flush180	03-JUN-16	0.125	ppb
51260	51260-1-KIT-KS04	Annex. 1st Floor Kitchen SW, Sink 2	Initial	03-JUN-16	0.406	ppb
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Initial	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F01	Annex. 1st Floor Outside Room 126, Fountain 1	Initial	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Flush180	03-JUN-16	1.000	ppb
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Initial	30-MAY-19	1.000	ug/L
51260	51260-1-E-HAL-F02	Annex. 1st Floor by Room 126, Fountain 2	Initial	03-JUN-16	1.000	ppb
51260	51260-2-S-HAL-F01	Annex. 2nd Floor Outside Library, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-2-S-HAL-F01	Annex. 2nd Floor Outside Library, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-2-S-HAL-F01	Annex. 2nd Floor Outside Library, Fountain 1	Flush180	30-MAY-19	1.000	ug/L
51260	51260-2-S-HAL-F01	Annex. 2nd Floor Outside Library, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-2-S-HAL-F01	Annex. 2nd Floor Outside Library, Fountain 1	Flush180	03-JUN-16	1.000	ppb
51260	51260-2-S-HAL-F01	Annex. 2nd Floor Outside Library, Fountain 1	Flush180	03-JUN-16	1.000	ppb

