



Sep 10, 2024

HEFFERAN

4409 W WILCOX ST, Chicago IL 60624.

Dear **HEFFERAN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HEFFERAN

4409 W WILCOX ST, Chicago IL 60624.

Estimadas familias de **HEFFERAN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	17-AUG-22	204.00 0	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	17-AUG-22	32.800	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	17-AUG-22	11.700	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	17-AUG-22	19.500	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	31-AUG-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	31-AUG-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	31-AUG-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	31-AUG-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	16-MAR-22	86.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Initial	17-AUG-22	108.00 0	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Initial	31-AUG-22	1.000	ug/L
51186	51186-1-HAL-BF01	Main 1st floor across from library right bottle filler	Initial	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-BF02	Main 2nd floor by room 211 left bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-BF02	Main 2nd floor by room 211 left bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-BF02	Main 2nd floor by room 211 left bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-BF02	Main 2nd floor by room 211 left bottle filler	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-BF02	Main 2nd floor by room 211 left bottle filler	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F12	Main- 1st Floor Across From Library Left, Fountain	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F13	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F13	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F13	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F13	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F13	Main- 1st Floor Across From Library Right, Fountai	Initial	13-SEP-16	2.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	19-AUG-20	1.000	ug/L
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Initial	19-AUG-20	1.070	ug/L
51186	51186-1-HAL-F15	Main- 1st Floor By Boiler Room Left, Fountain	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-1-HAL-F16	Main- 1st Floor By Boiler Room Right, Fountain	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Initial	13-SEP-16	2.400	ppb
51186	51186-1-MOF-S11	Main- 1st Floor Inside Main Office, Sink	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-100-BF01	Main- 1st Floor Inside Room 100 Bottle Filler	Flush180	26-AUG-22	1.280	ug/L
51186	51186-1-100-BF01	Main- 1st Floor Inside Room 100 Bottle Filler	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-BF01	Main- 1st Floor Inside Room 100 Bottle Filler	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-BF01	Main- 1st Floor Inside Room 100 Bottle Filler	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-BF01	Main- 1st Floor Inside Room 100 Bottle Filler	Initial	26-AUG-22	3.320	ug/L

Water Quality Assessment Helen M Hefferan Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51186	51186-1-100-F01	Main- 1st Floor Inside Room 100 Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-F01	Main- 1st Floor Inside Room 100 Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-F01	Main- 1st Floor Inside Room 100 Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-F01	Main- 1st Floor Inside Room 100 Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-F01	Main- 1st Floor Inside Room 100 Fountain	Initial	26-AUG-22	1.840	ug/L
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Initial	13-SEP-16	2.700	ppb
51186	51186-1-100-F05	Main- 1st Floor Inside Room 100 Left, Fountain	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-100-F06	Main- 1st Floor Inside Room 100 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F06	Main- 1st Floor Inside Room 100 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F06	Main- 1st Floor Inside Room 100 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F06	Main- 1st Floor Inside Room 100 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-F06	Main- 1st Floor Inside Room 100 Right, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-1-100-S01	Main- 1st Floor Inside Room 100 Sink 1	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S01	Main- 1st Floor Inside Room 100 Sink 1	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S01	Main- 1st Floor Inside Room 100 Sink 1	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S01	Main- 1st Floor Inside Room 100 Sink 1	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S01	Main- 1st Floor Inside Room 100 Sink 1	Initial	26-AUG-22	1.110	ug/L
51186	51186-1-100-S02	Main- 1st Floor Inside Room 100 Sink 2	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S02	Main- 1st Floor Inside Room 100 Sink 2	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S02	Main- 1st Floor Inside Room 100 Sink 2	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S02	Main- 1st Floor Inside Room 100 Sink 2	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-100-S02	Main- 1st Floor Inside Room 100 Sink 2	Initial	26-AUG-22	2.110	ug/L
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	13-SEP-16	11.000	ppb
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	16-MAR-22	1.290	ug/L
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	16-MAR-22	1.650	ug/L
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	16-MAR-22	1.180	ug/L
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Flush180	16-MAR-22	1.150	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S04	Sink				
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Initial	13-SEP-16	2.000	ppb
51186	51186-1-100-S04	Main- 1st Floor Inside Room 100, Sink	Initial	16-MAR-22	1.350	ug/L
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	16-MAR-22	1.190	ug/L
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-1-101-F09	Main- 1st Floor Inside Room 101 Left, Fountain	Initial	16-MAR-22	1.780	ug/L
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-1-101-F08	Main- 1st Floor Inside Room 101 Right, Fountain	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-101-S01	Main- 1st Floor Inside Room 101 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S01	Main- 1st Floor Inside Room 101 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S01	Main- 1st Floor Inside Room 101 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S01	Main- 1st Floor Inside Room 101 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S01	Main- 1st Floor Inside Room 101 Sink, Left	Initial	26-AUG-22	1.230	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	26-AUG-22	5.660	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	26-AUG-22	7.900	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	26-AUG-22	4.210	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Flush180	26-AUG-22	12.700	ug/L
51186	51186-1-101-BF01	Main- 1st Floor Inside Room 101, Bottle Filler	Initial	13-OCT-22	1.000	ug/L
51186	51186-1-101-	Main- 1st Floor Inside Room 101,	Initial	26-AUG-22	16.200	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	Bottle Filler				
51186	51186-1-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-F01	Main- 1st Floor Inside Room 101, Fountain	Initial	26-AUG-22	1.000	ug/L
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	13-SEP-16	2.400	ppb
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	13-SEP-16	2.400	ppb
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	13-SEP-16	2.500	ppb
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	16-MAR-22	1.310	ug/L
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	16-MAR-22	1.380	ug/L
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	16-MAR-22	1.280	ug/L
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Flush180	16-MAR-22	1.370	ug/L
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Initial	13-SEP-16	2.800	ppb
51186	51186-1-101-S07	Main- 1st Floor Inside Room 101, Sink	Initial	16-MAR-22	2.860	ug/L
51186	51186-1-101-S02	Main- 1st Floor Inside Room 101, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S02	Main- 1st Floor Inside Room 101, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S02	Main- 1st Floor Inside Room 101, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S02	Main- 1st Floor Inside Room 101, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-101-S02	Main- 1st Floor Inside Room 101, Sink, Right	Initial	26-AUG-22	1.000	ug/L
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	13-SEP-16	3.600	ppb
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	13-SEP-16	2.600	ppb
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Initial	13-SEP-16	6.500	ppb
51186	51186-1-103-S10	Main- 1st Floor Inside Room 103, Sink	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-109-S01	Main- 1st Floor Inside Room 109 Sink, Left	Flush180	26-AUG-22	1.330	ug/L
51186	51186-1-109-S01	Main- 1st Floor Inside Room 109 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S01	Main- 1st Floor Inside Room 109 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S01	Main- 1st Floor Inside Room 109 Sink, Left	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S01	Main- 1st Floor Inside Room 109 Sink, Left	Initial	26-AUG-22	2.160	ug/L
51186	51186-1-109-BF01	Main- 1st Floor Inside Room 109, Bottle Filler	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-BF01	Main- 1st Floor Inside Room 109, Bottle Filler	Flush180	26-AUG-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51186	51186-1-109-BF01	Main- 1st Floor Inside Room 109, Bottle Filler	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-BF01	Main- 1st Floor Inside Room 109, Bottle Filler	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-BF01	Main- 1st Floor Inside Room 109, Bottle Filler	Initial	26-AUG-22	1.000	ug/L
51186	51186-1-109-F01	Main- 1st Floor Inside Room 109, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-F01	Main- 1st Floor Inside Room 109, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-F01	Main- 1st Floor Inside Room 109, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-F01	Main- 1st Floor Inside Room 109, Fountain	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-F01	Main- 1st Floor Inside Room 109, Fountain	Initial	26-AUG-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	26-AUG-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	23-SEP-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	23-SEP-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	23-SEP-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Flush180	23-SEP-22	1.000	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Initial	26-AUG-22	6.100	ug/L
51186	51186-1-109-S02	Main- 1st Floor Inside Room 109, Sink, Right	Initial	23-SEP-22	3.200	ug/L
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	16-MAR-22	1.030	ug/L
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	16-MAR-22	1.690	ug/L
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	16-MAR-22	2.040	ug/L
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Flush180	16-MAR-22	2.730	ug/L
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Initial	13-SEP-16	2.000	ppb
51186	51186-1-TL-S14	Main- 1st Floor Inside Teacher's Lounge, Sink	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Initial	13-SEP-16	2.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51186	51186-1-KIT-KS02	Main- 1st Floor Kitchen Center Faucet, Sink	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Initial	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS03	Main- 1st Floor Kitchen North Faucet, Sink	Initial	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Flush180	16-MAR-22	1.000	ug/L
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Initial	13-SEP-16	2.000	ppb
51186	51186-1-KIT-KS01	Main- 1st Floor Kitchen South Faucet, Sink	Initial	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Flush180	19-AUG-20	2.120	ug/L
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F01	Main- 2nd Floor By Room 211 Left, Fountain	Initial	19-AUG-20	1.130	ug/L
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F02	Main- 2nd Floor By Room 211 Right, Fountain	Initial	16-MAR-22	1.130	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Right, Fountain				
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F03	Main- 2nd Floor By Room 223 Left, Fountain	Initial	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Flush180	16-MAR-22	1.000	ug/L
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Initial	13-SEP-16	2.000	ppb
51186	51186-2-HAL-F04	Main- 2nd Floor By Room 223 Right, Fountain	Initial	16-MAR-22	1.000	ug/L