



Sep 10, 2024

HERZL

3711 W DOUGLAS BLVD, Chicago IL 60623.

Dear **HERZL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HERZL

3711 W DOUGLAS BLVD, Chicago IL 60623.

Estimadas familias de **HERZL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51205	51205-1-HAL-F09	1st FI Hallway Across Rm 104, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F09	1st FI Hallway Across Rm 104, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F09	1st FI Hallway Across Rm 104, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F09	1st FI Hallway Across Rm 104, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F09	1st FI Hallway Across Rm 104, Left Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F10	1st FI Hallway Across Rm 104, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F10	1st FI Hallway Across Rm 104, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F10	1st FI Hallway Across Rm 104, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F10	1st FI Hallway Across Rm 104, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F10	1st FI Hallway Across Rm 104, Middle Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F11	1st FI Hallway Across Rm 104, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F11	1st FI Hallway Across Rm 104, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F11	1st FI Hallway Across Rm 104, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F11	1st FI Hallway Across Rm 104, Right Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F06	1st FI Hallway Across Rm 108, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F06	1st FI Hallway Across Rm 108, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F06	1st FI Hallway Across Rm 108, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F06	1st FI Hallway Across Rm 108, Left Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F07	1st FI Hallway Across Rm 108, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F07	1st FI Hallway Across Rm 108, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F07	1st FI Hallway Across Rm 108, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F07	1st FI Hallway Across Rm 108, Middle Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F08	1st FI Hallway Across Rm 108, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F08	1st FI Hallway Across Rm 108, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F08	1st FI Hallway Across Rm 108, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F08	1st FI Hallway Across Rm 108, Right Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F05	1st FI Hallway Near 121, Right Fountain	Flush	27-OCT-2023	1.260	ug/L
51205	51205-1-HAL-F05	1st FI Hallway Near 121, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F05	1st FI Hallway Near 121, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F05	1st FI Hallway Near 121, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-F05	1st FI Hallway Near 121, Right Fountain	Initial	27-OCT-2023	1.730	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51205	51205-1-HAL-RBF01	1st fL Hallway Near 121, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-RBF01	1st fL Hallway Near 121, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-HAL-RBF01	1st fL Hallway Near 121, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.800	ug/L
51205	51205-1-HAL-RBF01	1st fL Hallway Near 121, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	2.880	ug/L
51205	51205-1-HAL-RBF01	1st fL Hallway Near 121, Left Retrofitted Bottle Filler	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F01	2 FI Hallway, Near 224, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F01	2 FI Hallway, Near 224, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F01	2 FI Hallway, Near 224, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F01	2 FI Hallway, Near 224, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F01	2 FI Hallway, Near 224, Left Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F02	2 FI Hallway, Near 224, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F02	2 FI Hallway, Near 224, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F02	2 FI Hallway, Near 224, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F02	2 FI Hallway, Near 224, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F02	2 FI Hallway, Near 224, Middle Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F03	2 FI Hallway, Near 224, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F03	2 FI Hallway, Near 224, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F03	2 FI Hallway, Near 224, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F03	2 FI Hallway, Near 224, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F03	2 FI Hallway, Near 224, Right Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-RBF01	2nd FI Hallway, Near 244, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-RBF01	2nd FI Hallway, Near 244, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-RBF01	2nd FI Hallway, Near 244, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-RBF01	2nd FI Hallway, Near 244, Left Retrofitted Bottle Filler	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-RBF01	2nd FI Hallway, Near 244, Left Retrofitted Bottle Filler	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F07	2nd FI Hallway, Near 244, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F07	2nd FI Hallway, Near 244, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F07	2nd FI Hallway, Near 244, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F07	2nd FI Hallway, Near 244, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F07	2nd FI Hallway, Near 244, Right Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F04	2nd FI Hallway, Near Room 202, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F04	2nd FI Hallway, Near Room 202, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F04	2nd FI Hallway, Near Room 202, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F04	2nd FI Hallway, Near Room 202, Left Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F05	2nd FI Hallway, Near Room 202, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F05	2nd FI Hallway, Near Room 202, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51205	51205-2-HAL-F05	2nd FI Hallway, Near Room 202, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F05	2nd FI Hallway, Near Room 202, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F05	2nd FI Hallway, Near Room 202, Middle Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F06	2nd FI Hallway, Near Room 202, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F06	2nd FI Hallway, Near Room 202, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F06	2nd FI Hallway, Near Room 202, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F06	2nd FI Hallway, Near Room 202, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-2-HAL-F06	2nd FI Hallway, Near Room 202, Right Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-3-323B-F03	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F03	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F03	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F03	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F03	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F01	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F02	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F02	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F02	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F02	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-323B-F02	323B	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F04	3rd FI Near Room 321 Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F04	3rd FI Near Room 321 Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F04	3rd FI Near Room 321 Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F04	3rd FI Near Room 321 Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F04	3rd FI Near Room 321 Left Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F05	3rd FI Near Room 321 Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F05	3rd FI Near Room 321 Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F05	3rd FI Near Room 321 Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F05	3rd FI Near Room 321 Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F05	3rd FI Near Room 321 Middle Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F06	3rd FI Near Room 321 Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F06	3rd FI Near Room 321 Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F06	3rd FI Near Room 321 Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F06	3rd FI Near Room 321 Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F06	3rd FI Near Room 321 Right Fountain	Initial	27-OCT-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	Fountain				
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	27-OCT-2023	2.270	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	27-OCT-2023	2.670	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	27-OCT-2023	2.360	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	27-OCT-2023	10.900	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Initial	27-OCT-2023	2.830	ug/L
51205	51205-3-323B-F01	3rd FI Room 323B, Left Fountain	Initial	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F02	3rd FI Room 323B, Middle Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F02	3rd FI Room 323B, Middle Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F02	3rd FI Room 323B, Middle Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F02	3rd FI Room 323B, Middle Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F02	3rd FI Room 323B, Middle Fountain	Initial	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	27-OCT-2023	6.130	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	27-OCT-2023	9.560	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	27-OCT-2023	6.740	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	27-OCT-2023	4.370	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Flush	29-DEC-2023	1.000	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Initial	27-OCT-2023	4.030	ug/L
51205	51205-3-323B-F03	3rd FI Room 323B, Right Fountain	Initial	29-DEC-2023	1.000	ug/L
51205	51205-3-HAL-F01	3rd FI, Near Room 317, Left Fountain	Flush	27-OCT-2023	1.150	ug/L
51205	51205-3-HAL-F01	3rd FI, Near Room 317, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F01	3rd FI, Near Room 317, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F01	3rd FI, Near Room 317, Left Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F01	3rd FI, Near Room 317, Left Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F02	3rd FI, Near Room 317, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F02	3rd FI, Near Room 317, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F02	3rd FI, Near Room 317, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F02	3rd FI, Near Room 317, Middle Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F02	3rd FI, Near Room 317, Middle Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F03	3rd FI, Near Room 317, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F03	3rd FI, Near Room 317, Right Fountain	Flush	27-OCT-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
51205	51205-3-HAL-F03	3rd Fl, Near Room 317, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F03	3rd Fl, Near Room 317, Right Fountain	Flush	27-OCT-2023	1.000	ug/L
51205	51205-3-HAL-F03	3rd Fl, Near Room 317, Right Fountain	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	27-OCT-2023	4.170	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	27-OCT-2023	4.400	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	27-OCT-2023	3.860	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	27-OCT-2023	5.800	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	29-DEC-2023	17.700	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	29-DEC-2023	18.200	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	29-DEC-2023	14.200	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush	29-DEC-2023	17.800	ug/L
51205	51205-1-123-S01	Inside Room 123	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-123-S01	Inside Room 123	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-123-S01	Inside Room 123	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-123-S01	Inside Room 123	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-123-S01	Inside Room 123	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-123-S01	Inside Room 123	Initial	27-OCT-2023	7.040	ug/L
51205	51205-1-123-S01	Inside Room 123	Initial	29-DEC-2023	31.300	ug/L
51205	51205-1-KIT-KS01	Kitchen North Island Sink, Same Side as Freezers	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS01	Kitchen North Island Sink, Same Side as Freezers	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS01	Kitchen North Island Sink, Same Side as Freezers	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS01	Kitchen North Island Sink, Same Side as Freezers	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS01	Kitchen North Island Sink, Same Side as Freezers	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS02	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS02	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS02	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS02	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS02	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS01	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS01	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS01	Kitchen1/2	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS01	Kitchen1/2	Initial	26-MAY-16	1.000	ppb
51205	51205-1-LUN-S01	Lunchroom	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-LUN-S01	Lunchroom	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-LUN-S01	Lunchroom	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-LUN-S01	Lunchroom	Flush180	26-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51205	51205-1-LUN-S01	Lunchroom	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F03	Room 102 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F03	Room 102 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F03	Room 102 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F03	Room 102 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F03	Room 102 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F03	Room 102 (Hall)	Flush180	28-OCT-20	1.230	ug/L
51205	51205-1-HAL-F03	Room 102 (Hall)	Initial	28-OCT-20	1.750	ug/L
51205	51205-1-HAL-F04	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F04	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F04	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F04	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F04	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F05	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F05	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F05	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F05	Room 124A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F02	Room 149 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F02	Room 149 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F02	Room 149 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F02	Room 149 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-HAL-F02	Room 149 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F06	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F06	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F06	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F04	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F04	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F04	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F04	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F05	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F05	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F05	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F05	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F05	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F06	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51205	51205-2-HAL-F06	Room 202 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F01	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F01	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F01	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F01	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F01	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F02	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F03	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F03	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F03	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F03	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F03	Room 224A (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F07	Room 244 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F07	Room 244 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F07	Room 244 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F07	Room 244 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-2-HAL-F07	Room 244 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F01	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F01	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F01	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F01	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F01	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F03	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F02	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F02	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F02	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F02	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F02	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F03	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F03	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F03	Room 317 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F01	Room 317 (Hall)	Flush180	28-OCT-20	3.880	ug/L
51205	51205-3-HAL-	Room 317 (Hall)	Initial	28-OCT-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51205	51205-3-HAL-F06	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F06	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F06	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F06	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F06	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F04	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F04	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F04	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F04	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F04	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F05	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F05	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F05	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F05	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-3-HAL-F05	Room 321 (Hall)	Flush180	26-MAY-16	1.000	ppb
51205	51205-1-KIT-KS02	South Kitchen Island Sink, Same Side as Ovens	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS02	South Kitchen Island Sink, Same Side as Ovens	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS02	South Kitchen Island Sink, Same Side as Ovens	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS02	South Kitchen Island Sink, Same Side as Ovens	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS02	South Kitchen Island Sink, Same Side as Ovens	Initial	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS03	South Wall Sink	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS03	South Wall Sink	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS03	South Wall Sink	Flush	27-OCT-2023	1.000	ug/L
51205	51205-1-KIT-KS03	South Wall Sink	Initial	27-OCT-2023	1.000	ug/L
51224	51224-1-HAL-F01	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.670	ppb
51224	51224-1-HAL-F01	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.590	ppb
51224	51224-1-HAL-F02	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.320	ppb
51224	51224-1-HAL-F02	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.290	ppb
51224	51224-1-HAL-F02	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.310	ppb
51224	51224-1-HAL-F02	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.240	ppb
51224	51224-1-HAL-F02	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.370	ppb
51224	51224-1-HAL-F03	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	2.060	ppb
51224	51224-1-HAL-F03	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.610	ppb
51224	51224-1-HAL-F03	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.500	ppb
51224	51224-1-HAL-F03	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.470	ppb
51224	51224-1-HAL-F03	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.510	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
51224	51224-1-HAL-F01	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.640	ppb
51224	51224-1-HAL-F01	1st Floor Hallway Drinking Fountain	Flush180	27-MAY-16	1.440	ppb
51224	51224-1-HAL-F01	1st Floor Hallway Drinking Fountain	Initial	27-MAY-16	1.480	ppb
51224	51224-1-A-S01	Room A Sink	Flush180	27-MAY-16	6.680	ppb
51224	51224-1-A-S01	Room A Sink	Flush180	27-MAY-16	8.320	ppb
51224	51224-1-A-S01	Room A Sink	Flush180	27-MAY-16	6.820	ppb
51224	51224-1-A-S01	Room A Sink	Flush180	27-MAY-16	9.820	ppb
51224	51224-1-A-S01	Room A Sink	Flush180	27-MAY-16	5.810	ppb
51224	51224-1-B-S01	Room B Sink	Flush180	27-MAY-16	0.983	ppb
51224	51224-1-B-S01	Room B Sink	Flush180	27-MAY-16	1.110	ppb
51224	51224-1-B-S01	Room B Sink	Flush180	27-MAY-16	0.977	ppb
51224	51224-1-B-S01	Room B Sink	Flush180	27-MAY-16	1.620	ppb
51224	51224-1-B-S01	Room B Sink	Flush180	27-MAY-16	0.978	ppb
51224	51224-1-C-S01	Room C Sink	Flush180	27-MAY-16	0.989	ppb
51224	51224-1-C-S01	Room C Sink	Flush180	27-MAY-16	1.400	ppb
51224	51224-1-C-S01	Room C Sink	Flush180	27-MAY-16	0.916	ppb
51224	51224-1-C-S01	Room C Sink	Flush180	27-MAY-16	0.921	ppb
51224	51224-1-C-S01	Room C Sink	Flush180	27-MAY-16	1.210	ppb
51224	51224-1-D-S01	Room D Sink	Flush180	27-MAY-16	2.870	ppb
51224	51224-1-D-S01	Room D Sink	Flush180	27-MAY-16	1.990	ppb
51224	51224-1-D-S01	Room D Sink	Flush180	27-MAY-16	1.880	ppb
51224	51224-1-D-S01	Room D Sink	Flush180	27-MAY-16	2.220	ppb
51224	51224-1-D-S01	Room D Sink	Flush180	27-MAY-16	1.880	ppb
51224	51224-1-TL-S01	Teacher's Lounge Sink	Flush180	27-MAY-16	4.800	ppb
51224	51224-1-TL-S01	Teacher's Lounge Sink	Flush180	27-MAY-16	3.420	ppb
51224	51224-1-TL-S01	Teacher's Lounge Sink	Flush180	27-MAY-16	6.190	ppb
51224	51224-1-TL-S01	Teacher's Lounge Sink	Flush180	27-MAY-16	4.010	ppb
51224	51224-1-TL-S01	Teacher's Lounge Sink	Flush180	27-MAY-16	4.090	ppb