



Sep 10, 2024

HIGGINS

11710 S MORGAN ST, Chicago IL 60643.

Dear **HIGGINS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HIGGINS

11710 S MORGAN ST, Chicago IL 60643.

Estimadas familias de **HIGGINS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	18-JUN-16	0.487	ppb
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	18-JUN-16	0.907	ppb
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	18-JUN-16	1.080	ppb
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Flush180	18-JUN-16	0.624	ppb
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Initial	17-NOV-22	2.110	ug/L
51524	51524-1-HAL-F02	Across From Room 105, North Fountain 1	Initial	18-JUN-16	0.871	ppb
51524	51524-1-HAL-RBF01	Across From Room 105, Right Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-RBF01	Across From Room 105, Right Retrofit BF	Flush180	17-NOV-22	1.290	ug/L
51524	51524-1-HAL-RBF01	Across From Room 105, Right Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-RBF01	Across From Room 105, Right Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-HAL-RBF01	Across From Room 105, Right Retrofit BF	Initial	17-NOV-22	1.610	ug/L
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Flush180	18-JUN-16	0.482	ppb
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Flush180	18-JUN-16	0.488	ppb
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Flush180	18-JUN-16	0.487	ppb
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Flush180	18-JUN-16	0.550	ppb
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Flush180	21-AUG-20	8.020	ug/L
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Initial	18-JUN-16	0.688	ppb
51524	51524-1-HAL-F03	Across From Room 105, South Fountain 2	Initial	21-AUG-20	11.000	ug/L
51524	51524-1-HAL-F06	Across From Room 113, Fountain	Flush180	18-JUN-16	0.181	ppb
51524	51524-1-HAL-F06	Across From Room 113, Fountain	Flush180	18-JUN-16	1.000	ppb
51524	51524-1-HAL-F06	Across From Room 113, Fountain	Flush180	18-JUN-16	1.000	ppb
51524	51524-1-HAL-F06	Across From Room 113, Fountain	Flush180	18-JUN-16	1.000	ppb
51524	51524-1-HAL-F06	Across From Room 113, Fountain	Initial	18-JUN-16	1.000	ppb
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	18-JUN-16	1.440	ppb
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	18-JUN-16	0.995	ppb
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	18-JUN-16	0.573	ppb
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	18-JUN-16	1.190	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Flush180	21-AUG-20	1.000	ug/L
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Initial	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Initial	18-JUN-16	14.900	ppb
51524	51524-2-HAL-F01	Across From Room 205, Fountain	Initial	21-AUG-20	1.000	ug/L
51524	51524-2-HAL-RBF01	Across From Room 205, Left Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-RBF01	Across From Room 205, Left Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-RBF01	Across From Room 205, Left Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-RBF01	Across From Room 205, Left Retrofit BF	Flush180	17-NOV-22	1.000	ug/L
51524	51524-2-HAL-RBF01	Across From Room 205, Left Retrofit BF	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-101-S07	Inside Room 101, North Sink	Flush180	18-JUN-16	1.370	ppb
51524	51524-1-101-S07	Inside Room 101, North Sink	Flush180	18-JUN-16	1.970	ppb
51524	51524-1-101-S07	Inside Room 101, North Sink	Flush180	18-JUN-16	1.660	ppb
51524	51524-1-101-S07	Inside Room 101, North Sink	Flush180	18-JUN-16	2.070	ppb
51524	51524-1-101-S07	Inside Room 101, North Sink	Initial	18-JUN-16	2.460	ppb
51524	51524-1-101-F08	Inside Room 101, South Fountain	Flush180	18-JUN-16	2.710	ppb
51524	51524-1-101-F08	Inside Room 101, South Fountain	Flush180	18-JUN-16	3.050	ppb
51524	51524-1-101-F08	Inside Room 101, South Fountain	Flush180	18-JUN-16	2.460	ppb
51524	51524-1-101-F08	Inside Room 101, South Fountain	Flush180	18-JUN-16	1.770	ppb
51524	51524-1-101-F08	Inside Room 101, South Fountain	Initial	18-JUN-16	3.800	ppb
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	01-MAY-2024	8.890	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	22-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	22-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	22-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush	22-MAY-2024	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	18-JUN-16	3.780	ppb
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	18-JUN-16	2.460	ppb
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	18-JUN-16	2.580	ppb
51524	51524-1-105-S01	Inside Room 105, Sink	Flush180	18-JUN-16	2.320	ppb
51524	51524-1-105-S01	Inside Room 105, Sink	Initial	17-NOV-22	11.900	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Initial	18-JUN-16	8.350	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51524	51524-1-105-S01	Inside Room 105, Sink	Initial	01-MAY-2024	2.340	ug/L
51524	51524-1-105-S01	Inside Room 105, Sink	Initial	22-MAY-2024	1.000	ug/L
51524	51524-2-213-F03	Inside Room 213, Fountain	Flush180	18-JUN-16	0.221	ppb
51524	51524-2-213-F03	Inside Room 213, Fountain	Flush180	18-JUN-16	1.000	ppb
51524	51524-2-213-F03	Inside Room 213, Fountain	Flush180	18-JUN-16	1.000	ppb
51524	51524-2-213-F03	Inside Room 213, Fountain	Flush180	18-JUN-16	0.322	ppb
51524	51524-2-213-F03	Inside Room 213, Fountain	Initial	18-JUN-16	4.720	ppb
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	17-NOV-22	1.740	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	17-NOV-22	1.380	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	09-AUG-23	4.220	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	09-AUG-23	1.860	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	09-AUG-23	1.710	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Flush180	09-AUG-23	1.900	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Initial	17-NOV-22	1.830	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-100-BF01	Inside room 100, Bottle Filler	Initial	09-AUG-23	4.910	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	26-OCT-22	5.580	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	26-OCT-22	2.170	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	26-OCT-22	1.800	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	26-OCT-22	1.490	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	09-AUG-23	1.930	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	09-AUG-23	1.860	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	09-AUG-23	1.870	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Flush180	09-AUG-23	1.900	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51524	51524-1-100-F01	Inside room 100, Fountain	Initial	26-OCT-22	38.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Initial	05-OCT-22	6.800	ug/L
51524	51524-1-100-F01	Inside room 100, Fountain	Initial	09-AUG-23	2.040	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-100-S01	Inside room 100, Sink Left	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-100-S02	Inside room 100, Sink Right	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-101-BF01	Inside room 101, Bottle Filler	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	17-NOV-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-101-F01	Inside room 101, Fountain	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-101-S01	Inside room 101, Sink Left	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Flush180	05-OCT-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-101-S02	Inside room 101, Sink Right	Initial	05-OCT-22	1.000	ug/L
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	18-JUN-16	0.403	ppb
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	18-JUN-16	0.237	ppb
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	18-JUN-16	0.766	ppb
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	18-JUN-16	0.480	ppb
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Initial	18-JUN-16	0.975	ppb
51524	51524-1-KIT-KS04	Kitchen Addition, 2-basin sink, left	Initial	17-NOV-22	1.520	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	18-JUN-16	0.151	ppb
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	18-JUN-16	0.196	ppb
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	18-JUN-16	0.205	ppb
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	18-JUN-16	0.331	ppb
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Initial	18-JUN-16	0.371	ppb
51524	51524-1-KIT-KS05	Kitchen Addition, 2-basin sink, right	Initial	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush	01-MAY-2024	1.000	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush180	17-NOV-22	8.090	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush180	17-NOV-22	2.540	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush180	17-NOV-22	3.050	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Flush180	17-NOV-22	29.000	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Initial	17-NOV-22	2.930	ug/L
51524	51524-1-KIT-KS02	Kitchen Addition, Mixer Table	Initial	01-MAY-2024	1.000	ug/L
51524	51524-1-KIT-KS01	Kitchen Addition, Prep Table	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS01	Kitchen Addition, Prep Table	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS01	Kitchen Addition, Prep Table	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS01	Kitchen Addition, Prep Table	Flush180	17-NOV-22	1.000	ug/L
51524	51524-1-KIT-KS01	Kitchen Addition, Prep Table	Initial	17-NOV-22	1.000	ug/L