



Sep 10, 2024

HOLMES

955 W GARFIELD BLVD, Chicago IL 60621.

Dear **HOLMES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

HOLMES

955 W GARFIELD BLVD, Chicago IL 60621.

Estimadas familias de **HOLMES**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51354	51354-1-CAF-WC01		Flush180	07-OCT-20	1.000	ug/L
51354	51354-1-CAF-WC01		Initial	07-OCT-20	1.000	ug/L
51354	51354-1-HAL-BF06.	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-BF06.	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-BF06.	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-BF06.	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-BF06	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.300	ug/L
51354	51354-2-HAL-BF06	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-BF06	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-BF06	1st Flr across from stairwell, Left Bottle Filler	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-BF06.	1st Flr across from stairwell, Left Bottle Filler	Initial	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-BF06	1st Flr across from stairwell, Left Bottle Filler	Initial	12-OCT-22	2.380	ug/L
51354	51354-1-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F17	1st Flr across from stairwell, Left Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F17	1st Flr across from stairwell, Left Fountain	Initial	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F17	1st Flr across from stairwell, Left Fountain	Initial	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F18	1st Flr across from stairwell, Middle Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F18	1st Flr across from stairwell, Middle Fountain	Initial	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F18	1st Flr across from stairwell, Middle Fountain	Initial	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51354	51354-1-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F19	1st Flr across from stairwell, Right Fountain	Flush180	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F19	1st Flr across from stairwell, Right Fountain	Initial	12-OCT-22	1.000	ug/L
51354	51354-2-HAL-F19	1st Flr across from stairwell, Right Fountain	Initial	12-OCT-22	1.000	ug/L
51354	51354-1-HAL-F12	Across from 118 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F12	Across from 118 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F12	Across from 118 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F12	Across from 118 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F12	Across from 118 b/t restrooms (2-set), left fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF05	Across from 118 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF05	Across from 118 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF05	Across from 118 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF05	Across from 118 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF05	Across from 118 b/t restrooms (2-set), right Bottle Filler	Initial	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F13	Across from 118 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F13	Across from 118 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F13	Across from 118 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F13	Across from 118 b/t restrooms (2-set), right fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF06	Across from 118 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF06	Across from 118 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF06	Across from 118 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-BF06	Across from 118 b/t restrooms (3-set), left Bottle Filler	Initial	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F14	Across from 118 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F14	Across from 118 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F14	Across from 118 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F14	Across from 118 b/t restrooms (3-set), left fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F15	Across from 118 b/t restrooms (3-set), middle fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F15	Across from 118 b/t restrooms (3-set), middle fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F15	Across from 118 b/t restrooms (3-set), middle fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F15	Across from 118 b/t restrooms (3-set), middle fountain	Initial	16-SEP-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51354	51354-1-HAL-F16	Across from 118 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F16	Across from 118 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F16	Across from 118 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F16	Across from 118 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-F16	Across from 118 b/t restrooms (3-set), right fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F12	Across from 218 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F12	Across from 218 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F12	Across from 218 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F12	Across from 218 b/t restrooms (2-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F12	Across from 218 b/t restrooms (2-set), left fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF02	Across from 218 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF02	Across from 218 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF02	Across from 218 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF02	Across from 218 b/t restrooms (2-set), right Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF02	Across from 218 b/t restrooms (2-set), right Bottle Filler	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F13	Across from 218 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F13	Across from 218 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F13	Across from 218 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F13	Across from 218 b/t restrooms (2-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F13	Across from 218 b/t restrooms (2-set), right fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF03	Across from 218 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF03	Across from 218 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF03	Across from 218 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF03	Across from 218 b/t restrooms (3-set), left Bottle Filler	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-BF03	Across from 218 b/t restrooms (3-set), left Bottle Filler	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F14	Across from 218 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F14	Across from 218 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F14	Across from 218 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F14	Across from 218 b/t restrooms (3-set), left fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F14	Across from 218 b/t restrooms (3-set), left fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F15	Across from 218 b/t restrooms (3-set), middle fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F15	Across from 218 b/t restrooms (3-set), middle fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F15	Across from 218 b/t restrooms (3-set), middle fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F15	Across from 218 b/t restrooms (3-set), middle fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F16	Across from 218 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F16	Across from 218 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F16	Across from 218 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F16	set), right fountain				
51354	51354-2-HAL-F16	Across from 218 b/t restrooms (3-set), right fountain	Flush180	16-SEP-22	1.000	ug/L
51354	51354-2-HAL-F16	Across from 218 b/t restrooms (3-set), right fountain	Initial	16-SEP-22	1.000	ug/L
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F03	Gym - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F03	Gym - Hall	Flush180	16-JUN-16	7.340	ppb
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	07-OCT-20	1.350	ug/L
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-WC03	Gym - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-F03	Gym - Hall	Flush180	13-MAY-22	8.520	ug/L
51354	51354-1-HAL-F03	Gym - Hall	Flush180	13-MAY-22	9.360	ug/L
51354	51354-1-HAL-F03	Gym - Hall	Flush180	13-MAY-22	5.750	ug/L
51354	51354-1-HAL-F03	Gym - Hall	Flush180	13-MAY-22	7.890	ug/L
51354	51354-1-HAL-WC03	Gym - Hall	Initial	07-OCT-20	1.000	ug/L
51354	51354-1-HAL-WC03	Gym - Hall	Initial	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-F03	Gym - Hall	Initial	13-MAY-22	17.300	ug/L
51354	51354-1-KIT-KS01	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS01	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS01	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS01	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS01	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS02	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS02	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS02	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS02	Kitchen	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-KIT-KS01	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS01	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-	Kitchen	Flush180	13-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02					
51354	51354-1-KIT-KS02	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS02	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS02	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS01	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS01	Kitchen	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS02	Kitchen	Initial	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS01	Kitchen	Initial	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS03	Kitchen, outside janitors office	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS03	Kitchen, outside janitors office	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS03	Kitchen, outside janitors office	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS03	Kitchen, outside janitors office	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-KIT-KS03	Kitchen, outside janitors office	Initial	13-MAY-22	1.000	ug/L
51354	51354-2-HAL-F07	N Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F07	N Stairs - Hall	Flush180	16-JUN-16	10.100	ppb
51354	51354-2-HAL-F07	N Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F07	N Stairs - Hall	Flush180	16-JUN-16	7.340	ppb
51354	51354-2-HAL-F07	N Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-RBF02	N Stairs - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-2-HAL-RBF02	N Stairs - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-2-HAL-RBF02	N Stairs - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-2-HAL-RBF02	N Stairs - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-2-HAL-RBF02	N Stairs - Hall	Initial	13-MAY-22	1.000	ug/L
51354	51354-1-101-S01	Room 101	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-101-S01	Room 101	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-101-S01	Room 101	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-101-S01	Room 101	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-101-S01	Room 101	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-101-S01	Room 101	Flush180	13-MAY-22	7.070	ug/L
51354	51354-1-101-S01	Room 101	Flush180	13-MAY-22	3.240	ug/L
51354	51354-1-101-S01	Room 101	Flush180	13-MAY-22	2.280	ug/L
51354	51354-1-101-S01	Room 101	Flush180	13-MAY-22	2.000	ug/L
51354	51354-1-101-S01	Room 101	Initial	13-MAY-22	5.910	ug/L
51354	51354-1-103-S01	Room 103	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-103-S01	Room 103	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-103-S01	Room 103	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-103-S01	Room 103	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-103-S01	Room 103	Flush180	16-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51354	51354-1-103-S01	Room 103	Flush180	13-MAY-22	1.870	ug/L
51354	51354-1-103-S01	Room 103	Flush180	13-MAY-22	1.100	ug/L
51354	51354-1-103-S01	Room 103	Flush180	13-MAY-22	1.930	ug/L
51354	51354-1-103-S01	Room 103	Flush180	13-MAY-22	1.890	ug/L
51354	51354-1-103-S01	Room 103	Initial	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	13-MAY-22	7.240	ug/L
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	13-MAY-22	9.790	ug/L
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	13-MAY-22	27.000	ug/L
51354	51354-1-HAL-F01	Room 103 - Hall	Flush180	13-MAY-22	12.700	ug/L
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	13-MAY-22	3.760	ug/L
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	13-MAY-22	3.750	ug/L
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	13-MAY-22	5.100	ug/L
51354	51354-1-HAL-WC01	Room 103 - Hall	Flush180	13-MAY-22	4.300	ug/L
51354	51354-1-HAL-F01	Room 103 - Hall	Initial	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F01	Room 103 - Hall	Initial	13-MAY-22	4.600	ug/L
51354	51354-1-HAL-WC01	Room 103 - Hall	Initial	13-MAY-22	5.610	ug/L
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC02-51354-1-HAL-WC02	Room 107 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	13-MAY-22	5.640	ug/L
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	13-MAY-22	1.960	ug/L
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	13-MAY-22	4.870	ug/L
51354	51354-1-HAL-WC02	Room 107 - Hall	Flush180	13-MAY-22	2.930	ug/L
51354	51354-1-HAL-WC02	Room 107 - Hall	Initial	13-MAY-22	7.890	ug/L
51354	51354-1-HAL-RBF01	Room 107 - Hall	Flush180	13-MAY-22	1.080	ug/L
51354	51354-1-HAL-	Room 107 - Hall	Flush180	13-MAY-22	1.070	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01					
51354	51354-1-HAL-RBF01	Room 107 - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-RBF01	Room 107 - Hall	Flush180	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-RBF01	Room 107 - Hall	Initial	13-MAY-22	1.000	ug/L
51354	51354-1-HAL-WC04	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC04	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC04	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC04	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC05	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC05	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC05	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC05	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC05	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-WC04	Room 116 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F05	Room 118 - Hall	Flush180	16-JUN-16	5.750	ppb
51354	51354-1-HAL-F05	Room 118 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F05	Room 118 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F05	Room 118 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F05	Room 118 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F04	Room 118 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F04	Room 118 - Hall	Flush180	16-JUN-16	5.080	ppb
51354	51354-1-HAL-F04	Room 118 - Hall	Flush180	16-JUN-16	6.270	ppb
51354	51354-1-HAL-F04	Room 118 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-1-HAL-F04	Room 118 - Hall	Flush180	16-JUN-16	6.000	ppb
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	16-JUN-16	5.090	ppb
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	13-MAY-22	1.740	ug/L
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	13-MAY-22	1.340	ug/L
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	13-MAY-22	1.460	ug/L
51354	51354-2-HAL-F05	Room 201 - Hall	Flush180	13-MAY-22	1.330	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	13-MAY-22	2.370	ug/L
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	13-MAY-22	1.640	ug/L
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	13-MAY-22	1.430	ug/L
51354	51354-2-HAL-F06	Room 201 - Hall	Flush180	13-MAY-22	1.230	ug/L
51354	51354-2-HAL-F05	Room 201 - Hall	Initial	13-MAY-22	14.600	ug/L
51354	51354-2-HAL-F06	Room 201 - Hall	Initial	13-MAY-22	5.890	ug/L
51354	51354-2-HAL-F01	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F02	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F02	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F02	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F02	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F01	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F01	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F01	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F02	Room 215 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC01	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC01	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC02	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC02	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC02	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC02	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC02	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC01	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC01	Room 218 - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	13-MAY-22	14.500	ug/L
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	13-MAY-22	8.680	ug/L
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	13-MAY-22	8.170	ug/L
51354	51354-2-HAL-F03	S Stairs - Hall	Flush180	13-MAY-22	9.880	ug/L
51354	51354-2-HAL-F03	S Stairs - Hall	Initial	13-MAY-22	4.040	ug/L
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	16-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	13-MAY-22	4.230	ug/L
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	13-MAY-22	12.500	ug/L
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	13-MAY-22	6.030	ug/L
51354	51354-2-HAL-F04	Stairs - Hall	Flush180	13-MAY-22	9.900	ug/L
51354	51354-2-HAL-F04	Stairs - Hall	Initial	13-MAY-22	23.200	ug/L
51354	51354-2-HAL-WC03	W Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC03	W Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC03	W Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC03	W Stairs - Hall	Flush180	16-JUN-16	1.000	ppb
51354	51354-2-HAL-WC03	W Stairs - Hall	Flush180	16-JUN-16	1.000	ppb