



**Sep 10, 2024**

**HYDE PARK HS**

**6220 S STONY ISLAND AVE, Chicago IL 60637.**

Dear **HYDE PARK HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**HYDE PARK HS**

**6220 S STONY ISLAND AVE, Chicago IL 60637.**

Estimadas familias de **HYDE PARK HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-1-E-H122-WC	1st Floor, East End, Room H122	Flush180	03-SEP-19	1.130	ug/L
51612	51612-1-E-H122-WC	1st Floor, East End, Room H122	Flush180	03-SEP-19	1.260	ug/L
51612	51612-1-E-H122-WC	1st Floor, East End, Room H122	Flush180	03-SEP-19	1.430	ug/L
51612	51612-1-E-H122-WC	1st Floor, East End, Room H122	Flush180	03-SEP-19	1.600	ug/L
51612	51612-1-E-H122-WC	1st Floor, East End, Room H122	Initial	03-SEP-19	2.530	ug/L
51612	51612-1-E-H145-WC	1st Floor, East End, Room H145	Flush180	03-SEP-19	1.490	ug/L
51612	51612-1-E-H145-WC	1st Floor, East End, Room H145	Flush180	03-SEP-19	1.390	ug/L
51612	51612-1-E-H145-WC	1st Floor, East End, Room H145	Flush180	03-SEP-19	1.450	ug/L
51612	51612-1-E-H145-WC	1st Floor, East End, Room H145	Flush180	03-SEP-19	1.590	ug/L
51612	51612-1-E-H145-WC	1st Floor, East End, Room H145	Initial	03-SEP-19	1.000	ug/L
51612	51612-1-N-141-WC	1st Floor, North End, Room 141	Flush180	03-SEP-19	1.040	ug/L
51612	51612-1-N-141-WC	1st Floor, North End, Room 141	Flush180	03-SEP-19	1.770	ug/L
51612	51612-1-N-141-WC	1st Floor, North End, Room 141	Flush180	03-SEP-19	1.060	ug/L
51612	51612-1-N-141-WC	1st Floor, North End, Room 141	Flush180	03-SEP-19	1.000	ug/L
51612	51612-1-N-141-WC	1st Floor, North End, Room 141	Initial	03-SEP-19	1.570	ug/L
51612	51612-1-W-H113-WC	1st Floor, West End, Room H113	Flush180	03-SEP-19	1.000	ug/L
51612	51612-1-W-H113-WC	1st Floor, West End, Room H113	Flush180	03-SEP-19	1.000	ug/L
51612	51612-1-W-H113-WC	1st Floor, West End, Room H113	Flush180	03-SEP-19	1.000	ug/L
51612	51612-1-W-H113-WC	1st Floor, West End, Room H113	Flush180	03-SEP-19	1.000	ug/L
51612	51612-1-W-H113-WC	1st Floor, West End, Room H113	Initial	03-SEP-19	3.690	ug/L
51612	51612-2-W-HAL-BF1	Across Room 214	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-BF1	Across Room 214	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-BF1	Across Room 214	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-BF1	Across Room 214	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-BF1	Across Room 214	Initial	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F01	Across Room 214 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F01	Across Room 214 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F01	Across Room 214 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F01	Across Room 214 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F01	Across Room 214 (Left Fountain)	Initial	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F02	Across Room 214 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F02	Across Room 214 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F02	Across Room 214 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F02	Across Room 214 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-2-W-HAL-F02	Across Room 214 (Right Fountain)	Initial	20-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-2-E-HAL-BF2	Across Room 228	Flush180	20-FEB-20	1.250	ug/L
51612	51612-2-E-HAL-BF2	Across Room 228	Flush180	20-FEB-20	1.190	ug/L
51612	51612-2-E-HAL-BF2	Across Room 228	Flush180	20-FEB-20	1.180	ug/L
51612	51612-2-E-HAL-BF2	Across Room 228	Flush180	20-FEB-20	1.250	ug/L
51612	51612-2-E-HAL-BF2	Across Room 228	Initial	20-FEB-20	1.160	ug/L
51612	51612-2-E-HAL-F03	Across Room 228 (Left Fountain)	Flush180	20-FEB-20	1.490	ug/L
51612	51612-2-E-HAL-F03	Across Room 228 (Left Fountain)	Flush180	20-FEB-20	1.810	ug/L
51612	51612-2-E-HAL-F03	Across Room 228 (Left Fountain)	Flush180	20-FEB-20	1.770	ug/L
51612	51612-2-E-HAL-F03	Across Room 228 (Left Fountain)	Flush180	20-FEB-20	1.740	ug/L
51612	51612-2-E-HAL-F03	Across Room 228 (Left Fountain)	Initial	20-FEB-20	1.000	ug/L
51612	51612-2-E-HAL-F04	Across Room 228 (Right Fountain)	Flush180	20-FEB-20	1.530	ug/L
51612	51612-2-E-HAL-F04	Across Room 228 (Right Fountain)	Flush180	20-FEB-20	1.270	ug/L
51612	51612-2-E-HAL-F04	Across Room 228 (Right Fountain)	Flush180	20-FEB-20	1.150	ug/L
51612	51612-2-E-HAL-F04	Across Room 228 (Right Fountain)	Flush180	20-FEB-20	1.070	ug/L
51612	51612-2-E-HAL-F04	Across Room 228 (Right Fountain)	Initial	20-FEB-20	1.570	ug/L
51612	51612-3-W-HAL-BF1	Across Room 316	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-BF1	Across Room 316	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-BF1	Across Room 316	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-BF1	Across Room 316	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-BF1	Across Room 316	Initial	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F01	Across Room 316 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F01	Across Room 316 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F01	Across Room 316 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F01	Across Room 316 (Left Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F01	Across Room 316 (Left Fountain)	Initial	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F02	Across Room 316 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F02	Across Room 316 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F02	Across Room 316 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F02	Across Room 316 (Right Fountain)	Flush180	20-FEB-20	1.000	ug/L
51612	51612-3-W-HAL-F02	Across Room 316 (Right Fountain)	Initial	20-FEB-20	1.000	ug/L
51612	51612-3-E-HAL-BF2	Across Room 328	Flush180	20-FEB-20	1.600	ug/L
51612	51612-3-E-HAL-BF2	Across Room 328	Flush180	20-FEB-20	1.560	ug/L
51612	51612-3-E-HAL-BF2	Across Room 328	Flush180	20-FEB-20	1.570	ug/L
51612	51612-3-E-HAL-BF2	Across Room 328	Flush180	20-FEB-20	1.570	ug/L
51612	51612-3-E-HAL-BF2	Across Room 328	Initial	20-FEB-20	1.630	ug/L
51612	51612-3-E-HAL-F03	Across Room 328 (Left Fountain)	Flush180	20-FEB-20	2.070	ug/L
51612	51612-3-E-HAL-F03	Across Room 328 (Left Fountain)	Flush180	20-FEB-20	2.160	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-3-E-HAL-F03	Across Room 328 (Left Fountain)	Flush180	20-FEB-20	2.100	ug/L
51612	51612-3-E-HAL-F03	Across Room 328 (Left Fountain)	Flush180	20-FEB-20	2.010	ug/L
51612	51612-3-E-HAL-F03	Across Room 328 (Left Fountain)	Initial	20-FEB-20	1.100	ug/L
51612	51612-3-E-HAL-F04	Across Room 328 (Right Fountain)	Flush180	20-FEB-20	1.980	ug/L
51612	51612-3-E-HAL-F04	Across Room 328 (Right Fountain)	Flush180	20-FEB-20	1.890	ug/L
51612	51612-3-E-HAL-F04	Across Room 328 (Right Fountain)	Flush180	20-FEB-20	1.740	ug/L
51612	51612-3-E-HAL-F04	Across Room 328 (Right Fountain)	Flush180	20-FEB-20	1.480	ug/L
51612	51612-3-E-HAL-F04	Across Room 328 (Right Fountain)	Initial	20-FEB-20	1.840	ug/L
51612	51612-4-406-F02	Inside Room 406, Right Fountain	Flush	29-FEB-2024	3.260	ug/L
51612	51612-4-406-F02	Inside Room 406, Right Fountain	Flush	29-FEB-2024	3.730	ug/L
51612	51612-4-406-F02	Inside Room 406, Right Fountain	Flush	29-FEB-2024	2.930	ug/L
51612	51612-4-406-F02	Inside Room 406, Right Fountain	Flush	29-FEB-2024	2.140	ug/L
51612	51612-4-406-F02	Inside Room 406, Right Fountain	Initial	29-FEB-2024	1.000	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	29-FEB-2024	13.100	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	29-FEB-2024	13.800	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	29-FEB-2024	12.900	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	01-MAY-2024	1.150	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	01-MAY-2024	1.780	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	01-MAY-2024	1.970	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	01-MAY-2024	2.440	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	16-APR-2024	15.000	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	29-FEB-2024	9.340	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	16-APR-2024	19.600	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	16-APR-2024	39.400	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Flush	16-APR-2024	29.400	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Initial	01-MAY-2024	1.700	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Initial	16-APR-2024	9.340	ug/L
51612	51612-1-HAL-BF01	Main- 1st Floor Fountain Across 144 Bottle Filler	Initial	29-FEB-2024	10.100	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	16-APR-2024	6.180	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	01-MAY-2024	1.760	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	01-MAY-2024	1.800	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	01-MAY-2024	1.810	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	01-MAY-2024	1.970	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	16-APR-2024	4.500	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	16-APR-2024	4.270	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	16-APR-2024	4.110	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	29-FEB-2024	10.900	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	29-FEB-2024	10.400	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	144 Fountain				
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	29-FEB-2024	9.340	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Flush	29-FEB-2024	10.000	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Initial	16-APR-2024	5.700	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Initial	01-MAY-2024	1.740	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across 144 Fountain	Initial	29-FEB-2024	10.800	ug/L
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across From Room 129	Flush180	21-OCT-16	8.730	ppb
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across From Room 129	Flush180	21-OCT-16	8.110	ppb
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across From Room 129	Flush180	21-OCT-16	9.590	ppb
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across From Room 129	Flush180	21-OCT-16	8.420	ppb
51612	51612-1-HAL-F01	Main- 1st Floor Fountain Across From Room 129	Initial	21-OCT-16	8.220	ppb
51612	51612-1-HAL-F17	Main- 1st Floor Fountain By Room 133D	Flush180	21-OCT-16	4.870	ppb
51612	51612-1-HAL-F17	Main- 1st Floor Fountain By Room 133D	Flush180	21-OCT-16	4.050	ppb
51612	51612-1-HAL-F17	Main- 1st Floor Fountain By Room 133D	Flush180	21-OCT-16	4.530	ppb
51612	51612-1-HAL-F17	Main- 1st Floor Fountain By Room 133D	Flush180	21-OCT-16	4.470	ppb
51612	51612-1-HAL-F17	Main- 1st Floor Fountain By Room 133D	Initial	21-OCT-16	3.630	ppb
51612	51612-1-HAL-F06	Main- 1st Floor Fountain Cafeteria	Flush180	21-OCT-16	1.500	ppb
51612	51612-1-HAL-F06	Main- 1st Floor Fountain Cafeteria	Flush180	21-OCT-16	1.550	ppb
51612	51612-1-HAL-F06	Main- 1st Floor Fountain Cafeteria	Flush180	21-OCT-16	1.580	ppb
51612	51612-1-HAL-F06	Main- 1st Floor Fountain Cafeteria	Flush180	21-OCT-16	1.620	ppb
51612	51612-1-HAL-F06	Main- 1st Floor Fountain Cafeteria	Initial	21-OCT-16	1.580	ppb
51612	51612-1-HAL-F02	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.030	ppb
51612	51612-1-HAL-F02	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.768	ppb
51612	51612-1-HAL-F02	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.915	ppb
51612	51612-1-HAL-F02	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.100	ppb
51612	51612-1-HAL-F19	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.420	ppb
51612	51612-1-HAL-F19	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.380	ppb
51612	51612-1-HAL-F19	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.600	ppb
51612	51612-1-HAL-F19	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.570	ppb
51612	51612-1-HAL-F20	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.688	ppb
51612	51612-1-HAL-F20	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.493	ppb
51612	51612-1-HAL-F20	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.240	ppb
51612	51612-1-HAL-F20	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.070	ppb
51612	51612-1-HAL-F22	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	3.670	ppb
51612	51612-1-HAL-F22	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	3.570	ppb
51612	51612-1-HAL-F22	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	3.680	ppb
51612	51612-1-HAL-F22	Main- 1st Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	3.840	ppb
51612	51612-1-HAL-	Main- 1st Floor Fountain Left Side	Initial	21-OCT-16	1.420	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Across From Roo				
51612	51612-1-HAL-F19	Main- 1st Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	1.290	ppb
51612	51612-1-HAL-F20	Main- 1st Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	0.791	ppb
51612	51612-1-HAL-F22	Main- 1st Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	4.410	ppb
51612	51612-1-POOL-F26	Main- 1st Floor Fountain Left Side Boys Pool Locke	Flush180	21-OCT-16	6.230	ppb
51612	51612-1-POOL-F26	Main- 1st Floor Fountain Left Side Boys Pool Locke	Flush180	21-OCT-16	5.670	ppb
51612	51612-1-POOL-F26	Main- 1st Floor Fountain Left Side Boys Pool Locke	Flush180	21-OCT-16	6.310	ppb
51612	51612-1-POOL-F26	Main- 1st Floor Fountain Left Side Boys Pool Locke	Flush180	21-OCT-16	4.760	ppb
51612	51612-1-POOL-F26	Main- 1st Floor Fountain Left Side Boys Pool Locke	Initial	21-OCT-16	12.200	ppb
51612	51612-1-POOL-F28	Main- 1st Floor Fountain Left Side Girls Pool Lock	Flush180	21-OCT-16	2.640	ppb
51612	51612-1-POOL-F28	Main- 1st Floor Fountain Left Side Girls Pool Lock	Flush180	21-OCT-16	3.430	ppb
51612	51612-1-POOL-F28	Main- 1st Floor Fountain Left Side Girls Pool Lock	Flush180	21-OCT-16	3.860	ppb
51612	51612-1-POOL-F28	Main- 1st Floor Fountain Left Side Girls Pool Lock	Flush180	21-OCT-16	2.100	ppb
51612	51612-1-POOL-F28	Main- 1st Floor Fountain Left Side Girls Pool Lock	Initial	21-OCT-16	4.870	ppb
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Flush180	21-OCT-16	4.420	ppb
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Flush180	21-OCT-16	2.110	ppb
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Flush180	21-OCT-16	2.040	ppb
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Flush180	21-OCT-16	2.840	ppb
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Flush180	23-DEC-20	1.000	ug/L
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Initial	21-OCT-16	4.040	ppb
51612	51612-1-HAL-F04	Main- 1st Floor Fountain Left Side Next To Room 14	Initial	23-DEC-20	1.220	ug/L
51612	51612-1-POOL-F25	Main- 1st Floor Fountain Left Side Pool	Flush180	21-OCT-16	1.720	ppb
51612	51612-1-POOL-F25	Main- 1st Floor Fountain Left Side Pool	Flush180	21-OCT-16	1.260	ppb
51612	51612-1-POOL-F25	Main- 1st Floor Fountain Left Side Pool	Flush180	21-OCT-16	1.310	ppb
51612	51612-1-POOL-F25	Main- 1st Floor Fountain Left Side Pool	Flush180	21-OCT-16	1.450	ppb
51612	51612-1-POOL-F25	Main- 1st Floor Fountain Left Side Pool	Initial	21-OCT-16	5.730	ppb
51612	51612-1-HAL-F18	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	1.540	ppb
51612	51612-1-HAL-F18	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	1.570	ppb
51612	51612-1-HAL-F18	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	1.360	ppb
51612	51612-1-HAL-F18	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	1.420	ppb
51612	51612-1-HAL-F23	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	3.610	ppb
51612	51612-1-HAL-F23	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	3.220	ppb
51612	51612-1-HAL-F03	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.567	ppb
51612	51612-1-HAL-F03	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.518	ppb
51612	51612-1-HAL-F03	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.562	ppb
51612	51612-1-HAL-F03	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.597	ppb
51612	51612-1-HAL-F23	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	3.000	ppb
51612	51612-1-HAL-F21	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.395	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-1-HAL-F21	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.499	ppb
51612	51612-1-HAL-F21	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.373	ppb
51612	51612-1-HAL-F21	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.414	ppb
51612	51612-1-HAL-F23	Main- 1st Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.870	ppb
51612	51612-1-HAL-F18	Main- 1st Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	1.370	ppb
51612	51612-1-HAL-F03	Main- 1st Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	0.789	ppb
51612	51612-1-HAL-F21	Main- 1st Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	0.562	ppb
51612	51612-1-HAL-F23	Main- 1st Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	4.520	ppb
51612	51612-1-POOL-F27	Main- 1st Floor Fountain Right Side Boys Pool Lock	Flush180	21-OCT-16	1.740	ppb
51612	51612-1-POOL-F27	Main- 1st Floor Fountain Right Side Boys Pool Lock	Flush180	21-OCT-16	2.160	ppb
51612	51612-1-POOL-F27	Main- 1st Floor Fountain Right Side Boys Pool Lock	Flush180	21-OCT-16	2.870	ppb
51612	51612-1-POOL-F27	Main- 1st Floor Fountain Right Side Boys Pool Lock	Flush180	21-OCT-16	1.880	ppb
51612	51612-1-POOL-F27	Main- 1st Floor Fountain Right Side Boys Pool Lock	Initial	21-OCT-16	5.840	ppb
51612	51612-1-POOL-F29	Main- 1st Floor Fountain Right Side Girls PooMain-	Flush180	21-OCT-16	5.610	ppb
51612	51612-1-POOL-F29	Main- 1st Floor Fountain Right Side Girls PooMain-	Flush180	21-OCT-16	6.000	ppb
51612	51612-1-POOL-F29	Main- 1st Floor Fountain Right Side Girls PooMain-	Flush180	21-OCT-16	4.800	ppb
51612	51612-1-POOL-F29	Main- 1st Floor Fountain Right Side Girls PooMain-	Flush180	21-OCT-16	5.680	ppb
51612	51612-1-POOL-F29	Main- 1st Floor Fountain Right Side Girls PooMain-	Initial	21-OCT-16	6.450	ppb
51612	51612-1-HAL-F05	Main- 1st Floor Fountain Right Side Next To Room 1	Flush180	21-OCT-16	2.570	ppb
51612	51612-1-HAL-F05	Main- 1st Floor Fountain Right Side Next To Room 1	Flush180	21-OCT-16	3.400	ppb
51612	51612-1-HAL-F05	Main- 1st Floor Fountain Right Side Next To Room 1	Flush180	21-OCT-16	3.670	ppb
51612	51612-1-HAL-F05	Main- 1st Floor Fountain Right Side Next To Room 1	Flush180	21-OCT-16	2.080	ppb
51612	51612-1-HAL-F05	Main- 1st Floor Fountain Right Side Next To Room 1	Initial	21-OCT-16	3.140	ppb
51612	51612-1-KIT-KS12	Main- 1st Floor Kitchen Kettle	Flush180	21-OCT-16	0.951	ppb
51612	51612-1-KIT-KS12	Main- 1st Floor Kitchen Kettle	Flush180	21-OCT-16	0.488	ppb
51612	51612-1-KIT-KS12	Main- 1st Floor Kitchen Kettle	Flush180	21-OCT-16	0.487	ppb
51612	51612-1-KIT-KS12	Main- 1st Floor Kitchen Kettle	Flush180	21-OCT-16	0.678	ppb
51612	51612-1-KIT-KS12	Main- 1st Floor Kitchen Kettle	Initial	21-OCT-16	0.604	ppb
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	29-FEB-2024	15.600	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	29-FEB-2024	11.900	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	29-FEB-2024	10.300	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	29-FEB-2024	13.400	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush180	21-OCT-16	1.620	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush180	21-OCT-16	1.560	ppb
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush180	21-OCT-16	1.360	ppb
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Flush180	21-OCT-16	1.520	ppb
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Initial	21-OCT-16	0.915	ppb
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Initial	29-FEB-2024	10.700	ug/L
51612	51612-1-KIT-KS11	Main- 1st Floor Kitchen Sink Center North Sink	Initial	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS14	Main- 1st Floor Kitchen Sink Center North Wall Tri	Flush180	21-OCT-16	1.140	ppb
51612	51612-1-KIT-KS14	Main- 1st Floor Kitchen Sink Center North Wall Tri	Flush180	21-OCT-16	0.454	ppb
51612	51612-1-KIT-KS14	Main- 1st Floor Kitchen Sink Center North Wall Tri	Flush180	21-OCT-16	0.284	ppb
51612	51612-1-KIT-KS14	Main- 1st Floor Kitchen Sink Center North Wall Tri	Flush180	21-OCT-16	0.319	ppb
51612	51612-1-KIT-KS14	Main- 1st Floor Kitchen Sink Center North Wall Tri	Initial	21-OCT-16	0.283	ppb
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush	29-FEB-2024	10.200	ug/L
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush	29-FEB-2024	13.100	ug/L
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush	29-FEB-2024	18.100	ug/L
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush	29-FEB-2024	46.400	ug/L
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush180	21-OCT-16	2.090	ppb
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush180	21-OCT-16	2.360	ppb
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush180	21-OCT-16	4.210	ppb
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Flush180	21-OCT-16	2.300	ppb
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Initial	21-OCT-16	11.700	ppb
51612	51612-1-KIT-KS10	Main- 1st Floor Kitchen Sink Center South Meat Sin	Initial	29-FEB-2024	24.500	ug/L
51612	51612-1-KIT-KS08	Main- 1st Floor Kitchen Sink Center West Wall Trip	Flush180	21-OCT-16	0.248	ppb
51612	51612-1-KIT-KS08	Main- 1st Floor Kitchen Sink Center West Wall Trip	Flush180	21-OCT-16	0.159	ppb
51612	51612-1-KIT-KS08	Main- 1st Floor Kitchen Sink Center West Wall Trip	Flush180	21-OCT-16	0.272	ppb
51612	51612-1-KIT-KS08	Main- 1st Floor Kitchen Sink Center West Wall Trip	Flush180	21-OCT-16	0.244	ppb
51612	51612-1-KIT-KS08	Main- 1st Floor Kitchen Sink Center West Wall Trip	Initial	21-OCT-16	0.318	ppb
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	29-FEB-2024	4.430	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	29-FEB-2024	3.170	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	29-FEB-2024	6.600	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	29-FEB-2024	2.270	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush180	21-OCT-16	1.460	ppb
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush180	21-OCT-16	0.933	ppb
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Flush180	21-OCT-16	0.838	ppb
51612	51612-1-KIT-	Main- 1st Floor Kitchen Sink East	Flush180	21-OCT-16	0.814	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS16	Wall				
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Initial	21-OCT-16	0.832	ppb
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Initial	29-FEB-2024	3.910	ug/L
51612	51612-1-KIT-KS16	Main- 1st Floor Kitchen Sink East Wall	Initial	16-APR-2024	1.000	ug/L
51612	51612-1-KIT-KS13	Main- 1st Floor Kitchen Sink Left Side North Wall	Flush180	21-OCT-16	0.707	ppb
51612	51612-1-KIT-KS13	Main- 1st Floor Kitchen Sink Left Side North Wall	Flush180	21-OCT-16	0.420	ppb
51612	51612-1-KIT-KS13	Main- 1st Floor Kitchen Sink Left Side North Wall	Flush180	21-OCT-16	0.336	ppb
51612	51612-1-KIT-KS13	Main- 1st Floor Kitchen Sink Left Side North Wall	Flush180	21-OCT-16	0.256	ppb
51612	51612-1-KIT-KS13	Main- 1st Floor Kitchen Sink Left Side North Wall	Initial	21-OCT-16	0.500	ppb
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush	08-MAR-2024	1.000	ug/L
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush	08-MAR-2024	1.000	ug/L
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush	08-MAR-2024	1.000	ug/L
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush	08-MAR-2024	1.000	ug/L
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush180	21-OCT-16	0.349	ppb
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush180	21-OCT-16	0.299	ppb
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush180	21-OCT-16	0.277	ppb
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Flush180	21-OCT-16	0.244	ppb
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Initial	21-OCT-16	0.407	ppb
51612	51612-1-KIT-KS07	Main- 1st Floor Kitchen Sink Left Side West Wall T	Initial	08-MAR-2024	1.000	ug/L
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush	29-FEB-2024	1.190	ug/L
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush	29-FEB-2024	1.000	ug/L
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush	29-FEB-2024	1.000	ug/L
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush	29-FEB-2024	1.000	ug/L
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush180	21-OCT-16	0.286	ppb
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush180	21-OCT-16	0.960	ppb
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush180	21-OCT-16	1.110	ppb
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Flush180	21-OCT-16	0.334	ppb
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Initial	21-OCT-16	2.040	ppb
51612	51612-1-KIT-KS15	Main- 1st Floor Kitchen Sink Right Side North Wall	Initial	29-FEB-2024	3.860	ug/L
51612	51612-1-KIT-KS09	Main- 1st Floor Kitchen Sink Right Side West Wall	Flush180	21-OCT-16	0.127	ppb
51612	51612-1-KIT-KS09	Main- 1st Floor Kitchen Sink Right Side West Wall	Flush180	21-OCT-16	0.214	ppb
51612	51612-1-KIT-KS09	Main- 1st Floor Kitchen Sink Right Side West Wall	Flush180	21-OCT-16	0.193	ppb
51612	51612-1-KIT-KS09	Main- 1st Floor Kitchen Sink Right Side West Wall	Flush180	21-OCT-16	0.124	ppb
51612	51612-1-KIT-KS09	Main- 1st Floor Kitchen Sink Right Side West Wall	Initial	21-OCT-16	0.353	ppb
51612	51612-2-GYM-F08	Main- 2nd Floor Fountain Gym North Side	Flush180	21-OCT-16	0.306	ppb
51612	51612-2-GYM-F08	Main- 2nd Floor Fountain Gym North Side	Flush180	21-OCT-16	0.220	ppb
51612	51612-2-GYM-F08	Main- 2nd Floor Fountain Gym North Side	Flush180	21-OCT-16	0.315	ppb
51612	51612-2-	Main- 2nd Floor Fountain Gym	Flush180	21-OCT-16	0.254	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	GYM-F08	North Side				
51612	51612-2-GYM-F08	Main- 2nd Floor Fountain Gym North Side	Initial	21-OCT-16	0.177	ppb
51612	51612-2-GYM-F07	Main- 2nd Floor Fountain Gym South Side	Flush180	21-OCT-16	0.227	ppb
51612	51612-2-GYM-F07	Main- 2nd Floor Fountain Gym South Side	Flush180	21-OCT-16	0.140	ppb
51612	51612-2-GYM-F07	Main- 2nd Floor Fountain Gym South Side	Flush180	21-OCT-16	0.238	ppb
51612	51612-2-GYM-F07	Main- 2nd Floor Fountain Gym South Side	Flush180	21-OCT-16	0.174	ppb
51612	51612-2-GYM-F07	Main- 2nd Floor Fountain Gym South Side	Initial	21-OCT-16	1.000	ppb
51612	51612-2-HAL-F12	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.360	ppb
51612	51612-2-HAL-F12	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.730	ppb
51612	51612-2-HAL-F12	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.450	ppb
51612	51612-2-HAL-F12	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.010	ppb
51612	51612-2-HAL-F03	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.823	ppb
51612	51612-2-HAL-F03	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.659	ppb
51612	51612-2-HAL-F03	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.671	ppb
51612	51612-2-HAL-F03	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.733	ppb
51612	51612-2-HAL-F09	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.379	ppb
51612	51612-2-HAL-F09	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.361	ppb
51612	51612-2-HAL-F01	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.430	ppb
51612	51612-2-HAL-F01	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.440	ppb
51612	51612-2-HAL-F01	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.360	ppb
51612	51612-2-HAL-F09	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.250	ppb
51612	51612-2-HAL-F09	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	0.225	ppb
51612	51612-2-HAL-F01	Main- 2nd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.410	ppb
51612	51612-2-HAL-F12	Main- 2nd Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	3.960	ppb
51612	51612-2-HAL-F03	Main- 2nd Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	2.320	ppb
51612	51612-2-HAL-F01	Main- 2nd Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	3.050	ppb
51612	51612-2-HAL-F09	Main- 2nd Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	0.372	ppb
51612	51612-2-HAL-F02	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.220	ppb
51612	51612-2-HAL-F04	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.484	ppb
51612	51612-2-HAL-F04	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.440	ppb
51612	51612-2-HAL-F04	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.460	ppb
51612	51612-2-HAL-F04	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.448	ppb
51612	51612-2-HAL-F02	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.250	ppb
51612	51612-2-HAL-F11	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.170	ppb
51612	51612-2-HAL-F11	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.256	ppb
51612	51612-2-HAL-F11	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.166	ppb
51612	51612-2-HAL-F11	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.174	ppb
51612	51612-2-HAL-F13	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.638	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-2-HAL-F13	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.635	ppb
51612	51612-2-HAL-F13	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.625	ppb
51612	51612-2-HAL-F13	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.630	ppb
51612	51612-2-HAL-F02	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.220	ppb
51612	51612-2-HAL-F02	Main- 2nd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	1.980	ppb
51612	51612-2-HAL-F04	Main- 2nd Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	0.608	ppb
51612	51612-2-HAL-F11	Main- 2nd Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	0.251	ppb
51612	51612-2-HAL-F13	Main- 2nd Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	1.180	ppb
51612	51612-2-HAL-F02	Main- 2nd Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	2.370	ppb
51612	51612-2-HAL-F10	Main- 2nd Floor Left Side Bottle Filler Across Fro	Flush180	21-OCT-16	0.279	ppb
51612	51612-2-HAL-F10	Main- 2nd Floor Left Side Bottle Filler Across Fro	Flush180	21-OCT-16	0.248	ppb
51612	51612-2-HAL-F10	Main- 2nd Floor Left Side Bottle Filler Across Fro	Flush180	21-OCT-16	0.297	ppb
51612	51612-2-HAL-F10	Main- 2nd Floor Left Side Bottle Filler Across Fro	Flush180	21-OCT-16	0.223	ppb
51612	51612-2-HAL-F10	Main- 2nd Floor Left Side Bottle Filler Across Fro	Initial	21-OCT-16	0.245	ppb
51612	51612-3-HAL-F09	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	1.010	ppb
51612	51612-3-HAL-F09	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	0.209	ppb
51612	51612-3-HAL-F09	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	0.975	ppb
51612	51612-3-HAL-F09	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	1.370	ppb
51612	51612-3-HAL-F11	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	0.310	ppb
51612	51612-3-HAL-F11	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	0.360	ppb
51612	51612-3-HAL-F11	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	0.328	ppb
51612	51612-3-HAL-F11	Main- 3rd Floor Bottle Filler Left Side Across Fro	Flush180	21-OCT-16	0.350	ppb
51612	51612-3-HAL-F09	Main- 3rd Floor Bottle Filler Left Side Across Fro	Initial	21-OCT-16	1.870	ppb
51612	51612-3-HAL-F11	Main- 3rd Floor Bottle Filler Left Side Across Fro	Initial	21-OCT-16	0.347	ppb
51612	51612-3-HAL-F08	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.450	ppb
51612	51612-3-HAL-F08	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.940	ppb
51612	51612-3-HAL-F08	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.880	ppb
51612	51612-3-HAL-F08	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	1.830	ppb
51612	51612-3-HAL-F01	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.930	ppb
51612	51612-3-HAL-F01	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	3.590	ppb
51612	51612-3-HAL-F01	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	3.030	ppb
51612	51612-3-HAL-F01	Main- 3rd Floor Fountain Left Side Across From Roo	Flush180	21-OCT-16	2.990	ppb
51612	51612-3-HAL-F08	Main- 3rd Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	2.430	ppb
51612	51612-3-HAL-F01	Main- 3rd Floor Fountain Left Side Across From Roo	Initial	21-OCT-16	4.110	ppb
51612	51612-3-HAL-F03	Main- 3rd Floor Fountain Left Side South Of Womens	Flush180	21-OCT-16	0.744	ppb
51612	51612-3-HAL-F03	Main- 3rd Floor Fountain Left Side South Of Womens	Flush180	21-OCT-16	0.769	ppb
51612	51612-3-HAL-F03	Main- 3rd Floor Fountain Left Side South Of Womens	Flush180	21-OCT-16	0.900	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51612	51612-3-HAL-F03	Main- 3rd Floor Fountain Left Side South Of Womens	Flush180	21-OCT-16	0.868	ppb
51612	51612-3-HAL-F03	Main- 3rd Floor Fountain Left Side South Of Womens	Initial	21-OCT-16	1.300	ppb
51612	51612-3-HAL-F04	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.592	ppb
51612	51612-3-HAL-F04	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.575	ppb
51612	51612-3-HAL-F04	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.592	ppb
51612	51612-3-HAL-F04	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	0.616	ppb
51612	51612-3-HAL-F02	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	3.190	ppb
51612	51612-3-HAL-F02	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.800	ppb
51612	51612-3-HAL-F02	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.980	ppb
51612	51612-3-HAL-F02	Main- 3rd Floor Fountain Right Side Across From Ro	Flush180	21-OCT-16	2.650	ppb
51612	51612-3-HAL-F04	Main- 3rd Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	0.581	ppb
51612	51612-3-HAL-F02	Main- 3rd Floor Fountain Right Side Across From Ro	Initial	21-OCT-16	4.230	ppb
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Flush180	21-OCT-16	0.761	ppb
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Flush180	21-OCT-16	0.414	ppb
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Flush180	21-OCT-16	0.634	ppb
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Flush180	21-OCT-16	0.559	ppb
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Flush180	23-DEC-20	2.890	ug/L
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Initial	21-OCT-16	0.259	ppb
51612	51612-3-HAL-F12	Main- 3rd Floor Fountain Right Side Across From R	Initial	23-DEC-20	2.800	ug/L
51612	51612-3-HAL-F10	Main- 3rd Floor Fountain Right Side Next to Room 3	Flush180	21-OCT-16	0.677	ppb
51612	51612-3-HAL-F10	Main- 3rd Floor Fountain Right Side Next to Room 3	Flush180	21-OCT-16	0.385	ppb
51612	51612-3-HAL-F10	Main- 3rd Floor Fountain Right Side Next to Room 3	Flush180	21-OCT-16	0.577	ppb
51612	51612-3-HAL-F10	Main- 3rd Floor Fountain Right Side Next to Room 3	Flush180	21-OCT-16	0.468	ppb
51612	51612-3-HAL-F10	Main- 3rd Floor Fountain Right Side Next to Room 3	Initial	21-OCT-16	0.814	ppb
51612	51612-4-402-F03	Main- 4th Floor Bottle Filler Room 402 Left Side	Flush180	21-OCT-16	1.630	ppb
51612	51612-4-402-F03	Main- 4th Floor Bottle Filler Room 402 Left Side	Flush180	21-OCT-16	1.380	ppb
51612	51612-4-402-F03	Main- 4th Floor Bottle Filler Room 402 Left Side	Flush180	21-OCT-16	1.500	ppb
51612	51612-4-402-F03	Main- 4th Floor Bottle Filler Room 402 Left Side	Flush180	21-OCT-16	1.410	ppb
51612	51612-4-402-F03	Main- 4th Floor Bottle Filler Room 402 Left Side	Initial	21-OCT-16	1.810	ppb
51612	51612-4-402-F02	Main- 4th Floor Fountain Room 402 Left Side	Flush180	21-OCT-16	1.960	ppb
51612	51612-4-402-F02	Main- 4th Floor Fountain Room 402 Left Side	Flush180	21-OCT-16	2.000	ppb
51612	51612-4-402-F02	Main- 4th Floor Fountain Room 402 Left Side	Flush180	21-OCT-16	1.800	ppb
51612	51612-4-402-F02	Main- 4th Floor Fountain Room 402 Left Side	Flush180	21-OCT-16	1.550	ppb
51612	51612-4-402-F02	Main- 4th Floor Fountain Room 402 Left Side	Initial	21-OCT-16	2.150	ppb
51612	51612-4-402-F04	Main- 4th Floor Fountain Room 402 Right Side	Flush180	21-OCT-16	1.450	ppb
51612	51612-4-402-F04	Main- 4th Floor Fountain Room 402 Right Side	Flush180	21-OCT-16	1.360	ppb
51612	51612-4-402-F04	Main- 4th Floor Fountain Room 402 Right Side	Flush180	21-OCT-16	1.440	ppb
51612	51612-4-402-	Main- 4th Floor Fountain Room	Flush180	21-OCT-16	1.310	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	402 Right Side				
51612	51612-4-402-F04	Main- 4th Floor Fountain Room 402 Right Side	Initial	21-OCT-16	1.850	ppb