



Sep 10, 2024

JAMIESON

5650 N MOZART ST, Chicago IL 60659.

Dear **JAMIESON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

JAMIESON

5650 N MOZART ST, Chicago IL 60659.

Estimadas familias de **JAMIESON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51063	51063-2-S-HAL-F09		Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F09		Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-E-HAL-F06		Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-E-HAL-F06		Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-E-HAL-F06		Flush180	14-JUN-19	1.080	ug/L
51063	51063-3-E-HAL-F06		Flush180	14-JUN-19	1.400	ug/L
51063	51063-3-E-HAL-F06		Flush180	18-AUG-20	3.900	ug/L
51063	51063-2-S-HAL-F09		Initial	13-SEP-23	1.000	ug/L
51063	51063-2-S-HAL-F09		Initial	14-JUN-19	1.000	ug/L
51063	51063-3-E-HAL-F06		Initial	14-JUN-19	1.000	ug/L
51063	51063-3-E-HAL-F06		Initial	18-AUG-20	3.720	ug/L
51063	51063-3-HAL-WC01	3rd FL Across Girls Bathroom Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC01	3rd FL Across Girls Bathroom Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC01	3rd FL Across Girls Bathroom Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC01	3rd FL Across Girls Bathroom Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC01	3rd FL Across Girls Bathroom Left	Initial	14-SEP-16	1.000	ppb
51063	51063-3-HAL-F01	3rd FL Across Girls Bathroom Right	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-F01	3rd FL Across Girls Bathroom Right	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-F01	3rd FL Across Girls Bathroom Right	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-F01	3rd FL Across Girls Bathroom Right	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-F01	3rd FL Across Girls Bathroom Right	Initial	14-SEP-16	1.000	ppb
51063	51063-2-S-HAL-F08	Across from 210	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F08	Across from 210	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F08	Across from 210	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F08	Across from 210	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-S-HAL-F08	Across from 210	Initial	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.310	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.310	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	13-SEP-23	1.940	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Initial	13-SEP-23	3.470	ug/L
51063	51063-2-HAL-F01	Boy's BR Left Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F01	Boy's BR Left Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F01	Boy's BR Left Fountain	Initial	14-JUN-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	from 316				
51063	51063-3-W-HAL-F02	Boy's BR Middle Fountain across from 316	Initial	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F02	Boy's BR Middle Fountain across from 316	Initial	14-JUN-19	1.000	ug/L
51063	51063-2-HAL-BF02	Boy's BR Right Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF02	Boy's BR Right Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF02	Boy's BR Right Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF02	Boy's BR Right Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF02	Boy's BR Right Bottle Filler	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-W-	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03					
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.310	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F03	Boy's BR Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F03	Boy's BR Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-W-HAL-F03	Boy's BR Right Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-3-W-HAL-F03	Boy's BR Right Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-2-W-HAL-F03	Boy's BR Right Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Flush180	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Initial	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F04	By 302	Initial	14-JUN-19	1.000	ug/L
51063	51063-2-HAL-BF01	By room 202, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF01	By room 202, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF01	By room 202, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF01	By room 202, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-BF01	By room 202, Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-S-F08	By room 210, Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-F08	By room 210, Left Fountain	Flush180	13-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51063	51063-2-S-F08	By room 210, Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-F08	By room 210, Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-S-F08	By room 210, Left Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-RB01	By room 302, Left Fountain	Flush180	13-SEP-23	1.060	ug/L
51063	51063-3-HAL-RB01	By room 302, Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-RB01	By room 302, Left Fountain	Flush180	13-SEP-23	1.110	ug/L
51063	51063-3-HAL-RB01	By room 302, Left Fountain	Flush180	13-SEP-23	1.550	ug/L
51063	51063-3-HAL-RB01	By room 302, Left Fountain	Initial	13-SEP-23	2.380	ug/L
51063	51063-3-W-HAL-RB01	By room 316, Middle Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-RB01	By room 316, Middle Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-RB01	By room 316, Middle Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-RB01	By room 316, Middle Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-RB01	By room 316, Middle Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-BF01	By room 316, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-BF01	By room 316, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-BF01	By room 316, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-BF01	By room 316, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-W-HAL-BF01	By room 316, Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS03	Center island kitchen sink	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS04	East wall, sink	Initial	13-SEP-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51063	51063-1-KIT-KS04	East wall, sink	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Initial	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS02	Kitchen Dish washing sink, right	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Initial	14-SEP-16	1.000	ppb
51063	51063-1-KIT-KS01	Kitchen, dish washing sink, left	Initial	14-JUN-19	1.000	ug/L
51063	51063-3-HAL-F06	Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F06	Left Fountain	Flush180	13-SEP-23	1.050	ug/L
51063	51063-3-HAL-F06	Left Fountain	Flush180	13-SEP-23	1.040	ug/L
51063	51063-3-HAL-F06	Left Fountain	Flush180	13-SEP-23	1.030	ug/L
51063	51063-3-HAL-F06	Left Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-	Lunchroom 128	Flush180	14-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	128-F01					
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-W-128-F01	Lunchroom 128	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-W-128-F01	Lunchroom 128	Initial	14-SEP-16	1.000	ppb
51063	51063-1-W-128-F01	Lunchroom 128	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-128-BF01	Lunchroom 128, Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-BF01	Lunchroom 128, Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-BF01	Lunchroom 128, Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-BF01	Lunchroom 128, Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-BF01	Lunchroom 128, Bottle Filler	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-128-F01	Lunchroom 128, Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-F01	Lunchroom 128, Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-F01	Lunchroom 128, Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-F01	Lunchroom 128, Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-128-F01	Lunchroom 128, Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F04	Outside Girls BR Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-BF05	Outside Main Office Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF05	Outside Main Office Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF05	Outside Main Office Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF05	Outside Main Office Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF05	Outside Main Office Bottle Filler	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	13-SEP-23	1.650	ug/L
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	13-SEP-23	1.000	ug/L

Water Quality Assessment Minnie Mars Jamieson Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06					
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Flush180	18-AUG-20	1.000	ug/L
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Initial	13-SEP-23	2.110	ug/L
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F06	Outside Main Office Left Fountain	Initial	18-AUG-20	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F07	Outside Main Office Right Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-BF03	Outside RM 102 Left Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF03	Outside RM 102 Left Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF03	Outside RM 102 Left Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-BF03	Outside RM 102 Left Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.020	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F04	Outside RM 102 Left Fountain	Initial	14-JUN-19	1.160	ug/L
51063	51063-1-HAL-RBF01	Outside RM 102 Retrofitted Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-RBF01	Outside RM 102 Retrofitted Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-RBF01	Outside RM 102 Retrofitted Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-RBF01	Outside RM 102 Retrofitted Bottle Filler	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-RBF01	Outside RM 102 Retrofitted Bottle Filler	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-E-HAL-F05	Outside RM 102 Right Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-HAL-F05	Outside RM 202 RIGHTFountain	Initial	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F04	Outside RM 202 left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-E-HAL-F04	Outside RM 202 left Fountain	Flush180	14-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51063	51063-2-E-HAL-F04	Outside RM 202 left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-E-HAL-F04	Outside RM 202 left Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-E-HAL-F04	Outside RM 202 left Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-JUN-19	2.310	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-JUN-19	2.350	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-JUN-19	1.910	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Flush180	14-JUN-19	1.710	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Initial	13-SEP-23	1.010	ug/L
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F06	Outside RM 208 Left Fountain	Initial	14-JUN-19	1.740	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	13-SEP-23	1.410	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	13-SEP-23	1.090	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-JUN-19	2.240	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-JUN-19	1.970	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-JUN-19	1.120	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Initial	13-SEP-23	3.150	ug/L
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-2-E-HAL-F07	Outside RM 208 Right Fountain	Initial	14-JUN-19	1.710	ug/L
51063	51063-3-HAL-WC02	Outside RM 302 Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC02	Outside RM 302 Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC02	Outside RM 302 Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-WC02	Outside RM 302 Left	Flush180	14-SEP-16	1.000	ppb
51063	51063-3-HAL-	Outside RM 302 Left	Initial	14-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02					
51063	51063-3-HAL-F07	Outside Room 105, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F07	Outside Room 105, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F07	Outside Room 105, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F07	Outside Room 105, Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-F07	Outside Room 105, Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F08	Outside Staff RM Left Fountain across 110	Initial	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Flush180	14-JUN-19	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Initial	14-SEP-16	1.000	ppb
51063	51063-1-HAL-F09	Outside Staff RM Right Fountain	Initial	14-JUN-19	1.000	ug/L
51063	51063-3-E-HAL-BF01	Right Bottle Filler Next to 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-E-	Right Bottle Filler Next to 302	Flush180	13-SEP-23	1.000	ug/L

**Water Quality Assessment
Minnie Mars Jamieson Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-BF01					
51063	51063-3-E-HAL-BF01	Right Bottle Filler Next to 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-E-HAL-BF01	Right Bottle Filler Next to 302	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-E-HAL-BF01	Right Bottle Filler Next to 302	Initial	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-BF01	Right Bottle Filler outside RM 305	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-BF01	Right Bottle Filler outside RM 305	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-BF01	Right Bottle Filler outside RM 305	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-BF01	Right Bottle Filler outside RM 305	Flush180	13-SEP-23	1.000	ug/L
51063	51063-3-HAL-BF01	Right Bottle Filler outside RM 305	Initial	13-SEP-23	1.000	ug/L
51063	51063-1-104-S01	Sink in RM 104/ Nurses Office	Flush180	13-SEP-23	1.050	ug/L
51063	51063-1-104-S01	Sink in RM 104/ Nurses Office	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-104-S01	Sink in RM 104/ Nurses Office	Flush180	13-SEP-23	1.000	ug/L
51063	51063-1-104-S01	Sink in RM 104/ Nurses Office	Initial	13-SEP-23	1.840	ug/L
51063	51063-2-211-S01	Teacher's Lounge	Flush180	13-SEP-23	2.290	ug/L
51063	51063-2-211-S01	Teacher's Lounge	Flush180	13-SEP-23	2.150	ug/L
51063	51063-2-211-S01	Teacher's Lounge	Flush180	13-SEP-23	1.040	ug/L
51063	51063-2-211-S01	Teacher's Lounge	Flush180	13-SEP-23	1.450	ug/L
51063	51063-2-211-S01	Teacher's Lounge	Flush180	14-SEP-16	11.800	ppb
51063	51063-2-211-S01	Teacher's Lounge	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-211-S01	Teacher's Lounge	Flush180	14-SEP-16	1.000	ppb
51063	51063-2-211-S01	Teacher's Lounge	Flush180	14-SEP-16	10.900	ppb
51063	51063-2-211-S01	Teacher's Lounge	Initial	13-SEP-23	1.000	ug/L
51063	51063-2-211-S01	Teacher's Lounge	Initial	14-SEP-16	1.000	ppb