



Sep 10, 2024

JENSEN

3030 W HARRISON ST, Chicago IL 60612.

Dear **JENSEN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

JENSEN

3030 W HARRISON ST, Chicago IL 60612.

Estimadas familias de **JENSEN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51219	51219-1-HAL-WC01	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC01	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC02	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC02	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC02	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC02	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC02	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC01	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC01	Between Boys Restroom and Room 104	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC07	Between Girls Restroom and Janitors	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC07	Between Girls Restroom and Janitors	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC07	Between Girls Restroom and Janitors	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC07	Between Girls Restroom and Janitors	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-BF03	Between Girls Restroom and Room 104	Flush	01-MAY-2024	1.000	ug/L
51219	51219-1-HAL-BF03	Between Girls Restroom and Room 104	Flush	01-MAY-2024	2.350	ug/L
51219	51219-1-HAL-BF03	Between Girls Restroom and Room 104	Flush	01-MAY-2024	2.890	ug/L
51219	51219-1-HAL-BF03	Between Girls Restroom and Room 104	Flush	01-MAY-2024	3.570	ug/L
51219	51219-1-HAL-BF03	Between Girls Restroom and Room 104	Initial	01-MAY-2024	1.990	ug/L
51219	51219-1-HAL-WC04	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC05	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC04	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC04	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC04	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC05	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC05	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-WC04	Between Girls Restroom and Room 106	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-BF02	Between Girls Restroom and Room 106	Flush	01-MAY-2024	1.270	ug/L
51219	51219-1-HAL-BF02	Between Girls Restroom and Room 106	Flush	01-MAY-2024	1.710	ug/L
51219	51219-1-HAL-BF02	Between Girls Restroom and Room 106	Flush	01-MAY-2024	2.190	ug/L
51219	51219-1-HAL-BF02	Between Girls Restroom and Room 106	Flush	01-MAY-2024	2.890	ug/L
51219	51219-1-HAL-BF02	Between Girls Restroom and Room 106	Initial	01-MAY-2024	1.310	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Flush180	19-AUG-20	1.390	ug/L
51219	51219-1-HAL-F01	Between Gym and Mens Restroom	Initial	19-AUG-20	1.000	ug/L
51219	51219-1-HAL-BF01	Between Gym and Mens Restroom	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-HAL-BF01	Between Gym and Mens Restroom	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-HAL-BF01	Between Gym and Mens Restroom	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-HAL-BF01	Between Gym and Mens Restroom	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-HAL-BF01	Between Gym and Mens Restroom	Initial	25-MAY-22	1.000	ug/L
51219	51219-1-HAL-F03	HALLWAY	Flush180	03-DEC-20	1.000	ug/L
51219	51219-1-HAL-F03	HALLWAY	Flush180	03-DEC-20	1.000	ug/L
51219	51219-1-HAL-F03	HALLWAY	Flush180	03-DEC-20	1.000	ug/L
51219	51219-1-HAL-F03	HALLWAY	Flush180	03-DEC-20	1.690	ug/L
51219	51219-1-HAL-F03	HALLWAY	Initial	03-DEC-20	1.000	ug/L
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	25-MAY-22	3.680	ug/L
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS03	Kitchen Left Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS03	Kitchen Left Sink	Initial	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS02	Kitchen Middle Sink	Initial	25-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS01	Kitchen Right Sink	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-KIT-KS01	Kitchen Right Sink	Initial	08-JUN-16	1.000	ppb
51219	51219-1-KIT-KS01	Kitchen Right Sink	Initial	25-MAY-22	1.000	ug/L
51219	51219-2-HAL-WC06	Near Janitor's Room and Room 204 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC06	Near Janitor's Room and Room 204 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC06	Near Janitor's Room and Room 204 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC06	Near Janitor's Room and Room 204 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC06	Near Janitor's Room and Room 204 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-RBF02	Near Janitor's Room and Room 204 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-2-HAL-RBF02	Near Janitor's Room and Room 204 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-2-HAL-RBF02	Near Janitor's Room and Room 204 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-2-HAL-RBF02	Near Janitor's Room and Room 204 Right	Initial	25-MAY-22	1.000	ug/L
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	25-MAY-22	54.000	ug/L
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	25-MAY-22	80.000	ug/L
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	25-MAY-22	74.000	ug/L
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Flush180	25-MAY-22	75.000	ug/L
51219	51219-2-HAL-WC04	Near Janitor's Room and Room 206 Left	Initial	25-MAY-22	33.000	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	14-SEP-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC05					
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	25-MAY-22	27.700	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	25-MAY-22	23.400	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	25-MAY-22	16.700	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Flush180	25-MAY-22	25.600	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Initial	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC05	Near Room 404 Middle	Initial	25-MAY-22	13.600	ug/L
51219	51219-4-HAL-WC06	Near Room 404 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC06	Near Room 404 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC06	Near Room 404 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC06	Near Room 404 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC06	Near Room 404 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-RBF04	Near Room 404 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-4-HAL-RBF04	Near Room 404 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-4-HAL-RBF04	Near Room 404 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-4-HAL-RBF04	Near Room 404 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-4-HAL-RBF04	Near Room 404 Right	Initial	25-MAY-22	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	01-OCT-20	2.220	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	01-OCT-20	2.530	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	01-OCT-20	1.320	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	01-OCT-20	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	19-AUG-20	9.110	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	25-MAY-22	4.960	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	25-MAY-22	7.650	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	25-MAY-22	11.200	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Flush180	25-MAY-22	11.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Initial	01-OCT-20	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Initial	19-AUG-20	14.900	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02					
51219	51219-4-HAL-WC02	Near Room 406 Middle	Initial	14-SEP-22	1.000	ug/L
51219	51219-4-HAL-WC02	Near Room 406 Middle	Initial	25-MAY-22	3.140	ug/L
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	25-MAY-22	8.610	ug/L
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	25-MAY-22	5.120	ug/L
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	25-MAY-22	4.320	ug/L
51219	51219-4-HAL-WC03	Near Room 406 Right	Flush180	25-MAY-22	3.530	ug/L
51219	51219-4-HAL-WC03	Near Room 406 Right	Initial	25-MAY-22	6.420	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	14-SEP-22	1.020	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	14-SEP-22	1.000	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	14-SEP-22	1.000	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	14-SEP-22	1.290	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	25-MAY-22	5.310	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	25-MAY-22	3.930	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	25-MAY-22	2.280	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Flush180	25-MAY-22	2.990	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Initial	14-SEP-22	1.810	ug/L
51219	51219-3-HAL-WC04	Near Science Lab 304 Left	Initial	25-MAY-22	7.240	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	14-SEP-22	1.270	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	14-SEP-22	3.720	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	14-SEP-22	4.270	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	14-SEP-22	3.160	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	25-MAY-22	4.190	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	25-MAY-22	8.660	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	25-MAY-22	9.530	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Flush180	25-MAY-22	8.890	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Initial	14-SEP-22	1.000	ug/L
51219	51219-3-HAL-WC05	Near Science Lab 304 Middle	Initial	25-MAY-22	1.110	ug/L
51219	51219-3-HAL-BF01	Near Science Lab 304 Middle	Flush	01-MAY-2024	1.000	ug/L
51219	51219-3-HAL-BF01	Near Science Lab 304 Middle	Flush	01-MAY-2024	1.000	ug/L
51219	51219-3-HAL-BF01	Near Science Lab 304 Middle	Flush	01-MAY-2024	1.000	ug/L
51219	51219-3-HAL-BF01	Near Science Lab 304 Middle	Flush	01-MAY-2024	1.000	ug/L
51219	51219-3-HAL-BF01	Near Science Lab 304 Middle	Initial	01-MAY-2024	1.000	ug/L
51219	51219-3-HAL-WC06	Near Science Lab 304 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC06	Near Science Lab 304 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC06	Near Science Lab 304 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC06	Near Science Lab 304 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-WC06	Near Science Lab 304 Right	Flush180	08-JUN-16	1.000	ppb
51219	51219-3-HAL-RBF03	Near Science Lab 304 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-3-HAL-RBF03	Near Science Lab 304 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-3-HAL-RBF03	Near Science Lab 304 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-3-HAL-RBF03	Near Science Lab 304 Right	Flush180	25-MAY-22	1.000	ug/L
51219	51219-3-HAL-RBF03	Near Science Lab 304 Right	Initial	25-MAY-22	1.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush	01-MAY-2024	1.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush	01-MAY-2024	1.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush	01-MAY-2024	1.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush	01-MAY-2024	1.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	25-MAY-22	93.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	25-MAY-22	65.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	25-MAY-22	66.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Flush180	25-MAY-22	52.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Initial	25-MAY-22	280.000	ug/L
51219	51219-2-HAL-WC01	Near Womens Restroom and Room 206 Left	Initial	01-MAY-2024	1.000	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.480	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.500	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.180	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.110	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	08-JUN-16	1.000	ppb
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	25-MAY-22	31.000	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	25-MAY-22	71.000	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	25-MAY-22	130.000	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Flush180	25-MAY-22	110.000	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Initial	25-MAY-22	8.910	ug/L
51219	51219-2-HAL-WC02	Near Womens Restroom and Room 206 Middle	Initial	01-MAY-2024	1.410	ug/L
51219	51219-2-HAL-BF01	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.000	ug/L
51219	51219-2-HAL-BF01	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.270	ug/L
51219	51219-2-HAL-BF01	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.430	ug/L
51219	51219-2-HAL-BF01	Near Womens Restroom and Room 206 Middle	Flush	01-MAY-2024	1.340	ug/L
51219	51219-2-HAL-BF01	Near Womens Restroom and Room 206 Middle	Initial	01-MAY-2024	1.160	ug/L
51219	51219-1-103-S01	Room 103	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-103-S01	Room 103	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-103-S01	Room 103	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-103-S01	Room 103	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-103-S01	Room 103	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-103-S01	Room 103	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-103-S01	Room 103	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-103-S01	Room 103	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-103-S01	Room 103	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-103-S01	Room 103	Initial	25-MAY-22	1.000	ug/L
51219	51219-1-105-S01	Room 105	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-105-S01	Room 105	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-105-S01	Room 105	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-105-S01	Room 105	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-105-S01	Room 105	Flush180	08-JUN-16	1.000	ppb
51219	51219-1-105-S01	Room 105	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-105-S01	Room 105	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-105-S01	Room 105	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-105-S01	Room 105	Flush180	25-MAY-22	1.000	ug/L
51219	51219-1-105-S01	Room 105	Initial	25-MAY-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51219	51219-1-107-S01	Room 107	Flush180	08-JUN-16	5.670	ppb
51219	51219-1-107-S01	Room 107	Flush180	08-JUN-16	6.150	ppb
51219	51219-1-107-S01	Room 107	Flush180	08-JUN-16	11.200	ppb
51219	51219-1-107-S01	Room 107	Flush180	08-JUN-16	7.330	ppb
51219	51219-1-107-S01	Room 107	Flush180	08-JUN-16	7.460	ppb
51219	51219-1-107-S01	Room 107	Flush180	14-SEP-22	6.840	ug/L
51219	51219-1-107-S01	Room 107	Flush180	14-SEP-22	7.400	ug/L
51219	51219-1-107-S01	Room 107	Flush180	14-SEP-22	7.120	ug/L
51219	51219-1-107-S01	Room 107	Flush180	14-SEP-22	4.130	ug/L
51219	51219-1-107-S01	Room 107	Flush180	25-MAY-22	6.340	ug/L
51219	51219-1-107-S01	Room 107	Flush180	25-MAY-22	4.750	ug/L
51219	51219-1-107-S01	Room 107	Flush180	25-MAY-22	4.590	ug/L
51219	51219-1-107-S01	Room 107	Flush180	25-MAY-22	5.470	ug/L
51219	51219-1-107-S01	Room 107	Flush180	30-SEP-22	1.270	ug/L
51219	51219-1-107-S01	Room 107	Flush180	30-SEP-22	3.330	ug/L
51219	51219-1-107-S01	Room 107	Flush180	30-SEP-22	6.310	ug/L
51219	51219-1-107-S01	Room 107	Flush180	30-SEP-22	6.860	ug/L
51219	51219-1-107-S01	Room 107	Initial	14-SEP-22	12.200	ug/L
51219	51219-1-107-S01	Room 107	Initial	25-MAY-22	17.700	ug/L
51219	51219-1-107-S01	Room 107	Initial	30-SEP-22	4.230	ug/L