



**Sep 10, 2024**

**JONES HS**

**700 S STATE ST, Chicago IL 60605.**

Dear **JONES HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**JONES HS**

**700 S STATE ST, Chicago IL 60605.**

Estimadas familias de **JONES HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51563	51563-1-CAF-F08	Annex - Cafeteria South Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F08	Annex - Cafeteria South Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F08	Annex - Cafeteria South Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F08	Annex - Cafeteria South Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F08	Annex - Cafeteria South Water Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-1-KIT-KS04	Annex - Kitchen Central Sink	Flush180	12-OCT-16	0.735	ppb
51563	51563-1-KIT-KS04	Annex - Kitchen Central Sink	Flush180	12-OCT-16	0.628	ppb
51563	51563-1-KIT-KS04	Annex - Kitchen Central Sink	Flush180	12-OCT-16	0.604	ppb
51563	51563-1-KIT-KS04	Annex - Kitchen Central Sink	Flush180	12-OCT-16	1.650	ppb
51563	51563-1-KIT-KS04	Annex - Kitchen Central Sink	Initial	12-OCT-16	1.970	ppb
51563	51563-1-KIT-KS02	Annex - Kitchen Central Sink Basin	Flush180	12-OCT-16	1.930	ppb
51563	51563-1-KIT-KS02	Annex - Kitchen Central Sink Basin	Flush180	12-OCT-16	0.637	ppb
51563	51563-1-KIT-KS02	Annex - Kitchen Central Sink Basin	Flush180	12-OCT-16	0.174	ppb
51563	51563-1-KIT-KS02	Annex - Kitchen Central Sink Basin	Flush180	12-OCT-16	0.210	ppb
51563	51563-1-KIT-KS02	Annex - Kitchen Central Sink Basin	Initial	12-OCT-16	1.290	ppb
51563	51563-1-KIT-KS03	Annex - Kitchen North Sink Basin	Flush180	12-OCT-16	0.142	ppb
51563	51563-1-KIT-KS03	Annex - Kitchen North Sink Basin	Flush180	12-OCT-16	0.498	ppb
51563	51563-1-KIT-KS03	Annex - Kitchen North Sink Basin	Flush180	12-OCT-16	0.141	ppb
51563	51563-1-KIT-KS03	Annex - Kitchen North Sink Basin	Flush180	12-OCT-16	0.212	ppb
51563	51563-1-KIT-KS03	Annex - Kitchen North Sink Basin	Initial	12-OCT-16	0.243	ppb
51563	51563-1-KIT-KS06	Annex - Kitchen North Sinks - Left	Flush180	12-OCT-16	0.495	ppb
51563	51563-1-KIT-KS06	Annex - Kitchen North Sinks - Left	Flush180	12-OCT-16	0.246	ppb
51563	51563-1-KIT-KS06	Annex - Kitchen North Sinks - Left	Flush180	12-OCT-16	0.181	ppb
51563	51563-1-KIT-KS06	Annex - Kitchen North Sinks - Left	Flush180	12-OCT-16	0.163	ppb
51563	51563-1-KIT-KS06	Annex - Kitchen North Sinks - Left	Initial	12-OCT-16	1.180	ppb
51563	51563-1-KIT-KS05	Annex - Kitchen North Sinks - Right	Flush180	12-OCT-16	0.334	ppb
51563	51563-1-KIT-KS05	Annex - Kitchen North Sinks - Right	Flush180	12-OCT-16	0.235	ppb
51563	51563-1-KIT-KS05	Annex - Kitchen North Sinks - Right	Flush180	12-OCT-16	0.170	ppb
51563	51563-1-KIT-KS05	Annex - Kitchen North Sinks - Right	Flush180	12-OCT-16	0.306	ppb
51563	51563-1-KIT-KS05	Annex - Kitchen North Sinks - Right	Initial	12-OCT-16	2.410	ppb
51563	51563-1-KIT-KS01	Annex - Kitchen South Sink Basin	Flush180	12-OCT-16	0.167	ppb
51563	51563-1-KIT-KS01	Annex - Kitchen South Sink Basin	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-KIT-KS01	Annex - Kitchen South Sink Basin	Flush180	12-OCT-16	0.127	ppb
51563	51563-1-KIT-KS01	Annex - Kitchen South Sink Basin	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-KIT-KS01	Annex - Kitchen South Sink Basin	Initial	12-OCT-16	0.189	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51563	51563-1-CAF-F07	Annex - North Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F07	Annex - North Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F07	Annex - North Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F07	Annex - North Water Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-CAF-F07	Annex - North Water Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	08-JAN-21	4.380	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	18-FEB-21	25.600	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	18-FEB-21	15.700	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	18-FEB-21	13.700	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	18-FEB-21	18.500	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Initial	25-JUL-23	1.000	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Initial	08-JAN-21	7.130	ug/L
51563	51563-1-HAL-F09	Annex - Outside Freight Elevator - Left Fountain	Initial	18-FEB-21	36.100	ug/L
51563	51563-1-HAL-F10	Annex - Outside Freight Elevator - Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F10	Annex - Outside Freight Elevator - Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-1-HAL-F10	Annex - Outside Freight Elevator - Right Fountain	Flush180	12-OCT-16	0.157	ppb
51563	51563-1-HAL-F10	Annex - Outside Freight Elevator - Right Fountain	Flush180	12-OCT-16	0.120	ppb
51563	51563-1-HAL-F10	Annex - Outside Freight Elevator - Right Fountain	Initial	12-OCT-16	0.766	ppb
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Flush180	08-JAN-21	1.000	ug/L
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F01	Annex - Outside Girl's Resroom - Left Fountain	Initial	08-JAN-21	1.000	ug/L
51563	51563-6-HAL-F02	Annex - Outside Girl's Resroom - Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F02	Annex - Outside Girl's Resroom - Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-6-HAL-F02	Annex - Outside Girl's Resroom - Right Fountain	Flush180	12-OCT-16	1.000	ppb





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Right Fountain				
51563	51563-2-HAL-F01	Annex - Outside Girl's Restroom - Right Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-3-HAL-F01	Annex - Outside Girl's Restroom - Right Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-4-HAL-F01	Annex - Outside Girl's Restroom - Right Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-5-HAL-F01	Annex - Outside Girl's Restroom - Right Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F04	Annex- Next to Freight Elevator, Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F04	Annex- Next to Freight Elevator, Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F04	Annex- Next to Freight Elevator, Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F04	Annex- Next to Freight Elevator, Left Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F04	Annex- Next to Freight Elevator, Left Fountain	Initial	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F03	Annex- Next to Freight Elevator, Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F03	Annex- Next to Freight Elevator, Right Fountain	Flush180	12-OCT-16	0.130	ppb
51563	51563-2-HAL-F03	Annex- Next to Freight Elevator, Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F03	Annex- Next to Freight Elevator, Right Fountain	Flush180	12-OCT-16	1.000	ppb
51563	51563-2-HAL-F03	Annex- Next to Freight Elevator, Right Fountain	Initial	12-OCT-16	0.147	ppb
59884	59884-6-HAL-F01	Main - Area 6000 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F01	Main - Area 6000 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F01	Main - Area 6000 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F01	Main - Area 6000 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F01	Main - Area 6000 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F02	Main - Area 6000 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F02	Main - Area 6000 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F02	Main - Area 6000 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F02	Main - Area 6000 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F02	Main - Area 6000 - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F03	Main - Gym Room 7001 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F03	Main - Gym Room 7001 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F03	Main - Gym Room 7001 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F03	Main - Gym Room 7001 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F03	Main - Gym Room 7001 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F04	Main - Gym Room 7001 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F04	Main - Gym Room 7001 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F04	Main - Gym Room 7001 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F04	Main - Gym Room 7001 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-GYM-F04	Main - Gym Room 7001 - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-5-HAL-F01	Main - Outside Room 5009 - Left Fountain	Flush180	12-OCT-16	0.134	ppb
59884	59884-5-HAL-F01	Main - Outside Room 5009 - Left Fountain	Flush180	12-OCT-16	0.129	ppb
59884	59884-5-HAL-	Main - Outside Room 5009 - Left	Flush180	12-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
59884	59884-5-HAL-F01	Main - Outside Room 5009 - Left Fountain	Flush180	12-OCT-16	0.120	ppb
59884	59884-5-HAL-F01	Main - Outside Room 5009 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-5-HAL-F02	Main - Outside Room 5009 - Right Fountain	Flush180	12-OCT-16	0.136	ppb
59884	59884-5-HAL-F02	Main - Outside Room 5009 - Right Fountain	Flush180	12-OCT-16	0.136	ppb
59884	59884-5-HAL-F02	Main - Outside Room 5009 - Right Fountain	Flush180	12-OCT-16	0.143	ppb
59884	59884-5-HAL-F02	Main - Outside Room 5009 - Right Fountain	Flush180	12-OCT-16	0.149	ppb
59884	59884-5-HAL-F02	Main - Outside Room 5009 - Right Fountain	Initial	12-OCT-16	0.132	ppb
59884	59884-6-HAL-F06	Main - Outside Room 6003 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F06	Main - Outside Room 6003 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F06	Main - Outside Room 6003 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F06	Main - Outside Room 6003 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F06	Main - Outside Room 6003 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F05	Main - Outside Room 6003 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F05	Main - Outside Room 6003 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F05	Main - Outside Room 6003 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F05	Main - Outside Room 6003 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F05	Main - Outside Room 6003 - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F03	Main - Outside Room 6004 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F03	Main - Outside Room 6004 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F03	Main - Outside Room 6004 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F03	Main - Outside Room 6004 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F03	Main - Outside Room 6004 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F04	Main - Outside Room 6004 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F04	Main - Outside Room 6004 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F04	Main - Outside Room 6004 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-6-HAL-F04	Main - Outside Room 6004 - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F01	Main - Outside Room 7028 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F01	Main - Outside Room 7028 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F01	Main - Outside Room 7028 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F01	Main - Outside Room 7028 - Left Fountain	Flush180	08-JAN-21	1.000	ug/L
59884	59884-7-HAL-F01	Main - Outside Room 7028 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F01	Main - Outside Room 7028 - Left Fountain	Initial	08-JAN-21	1.000	ug/L
59884	59884-7-HAL-F02	Main - Outside Room 7028 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F02	Main - Outside Room 7028 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F02	Main - Outside Room 7028 - Right Fountain	Flush180	12-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
59884	59884-7-HAL-F02	Main - Outside Room 7028 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-7-HAL-F02	Main - Outside Room 7028 - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-1-HAL-F03	Main- Across Room 1030H	Flush180	12-OCT-16	0.153	ppb
59884	59884-1-HAL-F03	Main- Across Room 1030H	Flush180	12-OCT-16	0.183	ppb
59884	59884-1-HAL-F03	Main- Across Room 1030H	Flush180	12-OCT-16	0.133	ppb
59884	59884-1-HAL-F03	Main- Across Room 1030H	Flush180	12-OCT-16	0.142	ppb
59884	59884-1-HAL-F03	Main- Across Room 1030H	Initial	12-OCT-16	0.148	ppb
59884	59884-2-KIT-KS03	Main- Kitchen East, Left Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS03	Main- Kitchen East, Left Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS03	Main- Kitchen East, Left Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS03	Main- Kitchen East, Left Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS03	Main- Kitchen East, Left Sink	Initial	12-OCT-16	0.138	ppb
59884	59884-2-KIT-KS04	Main- Kitchen East, Right Sink	Flush180	12-OCT-16	0.126	ppb
59884	59884-2-KIT-KS04	Main- Kitchen East, Right Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS04	Main- Kitchen East, Right Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS04	Main- Kitchen East, Right Sink	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS04	Main- Kitchen East, Right Sink	Initial	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS02	Main- Kitchen Prep Sink - Center Island	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS02	Main- Kitchen Prep Sink - Center Island	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS02	Main- Kitchen Prep Sink - Center Island	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS02	Main- Kitchen Prep Sink - Center Island	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS02	Main- Kitchen Prep Sink - Center Island	Initial	12-OCT-16	0.328	ppb
59884	59884-2-KIT-KS01	Main- Kitchen Prep-Sink West	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS01	Main- Kitchen Prep-Sink West	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS01	Main- Kitchen Prep-Sink West	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS01	Main- Kitchen Prep-Sink West	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-KIT-KS01	Main- Kitchen Prep-Sink West	Initial	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F01	Main- Next to Room 3011 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F01	Main- Next to Room 3011 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F01	Main- Next to Room 3011 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F01	Main- Next to Room 3011 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F01	Main- Next to Room 3011 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F02	Main- Next to Room 3011 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F02	Main- Next to Room 3011 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F02	Main- Next to Room 3011 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F02	Main- Next to Room 3011 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F02	Main- Next to Room 3011 - Right Fountain	Initial	12-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
59884	59884-2-HAL-F05	Main- Next to Stair B - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F05	Main- Next to Stair B - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F05	Main- Next to Stair B - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F05	Main- Next to Stair B - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F05	Main- Next to Stair B - Left Fountain	Initial	12-OCT-16	0.122	ppb
59884	59884-2-HAL-F06	Main- Next to Stair B - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F06	Main- Next to Stair B - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F06	Main- Next to Stair B - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F06	Main- Next to Stair B - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-2-HAL-F06	Main- Next to Stair B - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-1-H59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Flush180	12-OCT-16	1.000	ppb
59884	59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Flush180	12-OCT-16	1.000	ppb
59884	59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Flush180	12-OCT-16	1.000	ppb
59884	59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Flush180	12-OCT-16	1.000	ppb
59884	59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Flush180	08-JAN-21	1.000	ug/L
59884	59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Initial	12-OCT-16	1.000	ppb
59884	59884-1-HAL-F01	Main- Outside Loading Dock Lobby (1039) Left Fount	Initial	08-JAN-21	1.000	ug/L
59884	59884-3-HAL-F04	Main- Outside Room 3014 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F04	Main- Outside Room 3014 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F04	Main- Outside Room 3014 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F04	Main- Outside Room 3014 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F04	Main- Outside Room 3014 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F03	Main- Outside Room 3014 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F03	Main- Outside Room 3014 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F03	Main- Outside Room 3014 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-3-HAL-F03	Main- Outside Room 3014 - Right Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F01	Main- Outside Room 4009 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F01	Main- Outside Room 4009 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F01	Main- Outside Room 4009 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F01	Main- Outside Room 4009 - Left Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F01	Main- Outside Room 4009 - Left Fountain	Initial	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F02	Main- Outside Room 4009 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F02	Main- Outside Room 4009 - Right Fountain	Flush180	12-OCT-16	0.130	ppb
59884	59884-4-HAL-F02	Main- Outside Room 4009 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F02	Main- Outside Room 4009 - Right Fountain	Flush180	12-OCT-16	1.000	ppb
59884	59884-4-HAL-F02	Main- Outside Room 4009 - Right Fountain	Initial	12-OCT-16	1.000	ppb

