



Sep 10, 2024

JULIAN HS

10330 S ELIZABETH ST, Chicago IL 60643.

Dear **JULIAN HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

JULIAN HS

10330 S ELIZABETH ST, Chicago IL 60643.

Estimadas familias de **JULIAN HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51637	51637-3-S-LUN-F01		Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-S-LUN-F01		Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-S-LUN-F01		Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-S-LUN-F01		Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-S-KIT-KS04		Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-S-KIT-KS04		Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS05		Flush180	06-JUN-19	1.100	ug/L
51637	51637-B-N-KIT-KS05		Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS05		Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS05		Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-S-KIT-KS04		Flush180	06-JUN-19	1.190	ug/L
51637	51637-B-S-KIT-KS04		Flush180	06-JUN-19	1.060	ug/L
51637	51637-3-S-LUN-F01		Initial	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS05		Initial	06-JUN-19	1.000	ug/L
51637	51637-B-S-KIT-KS04		Initial	06-JUN-19	1.000	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	08-AUG-23	1.090	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	08-AUG-23	1.020	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	08-AUG-23	1.290	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-JUL-23	4.830	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-JUL-23	5.450	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-JUL-23	5.890	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-JUL-23	6.090	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	22-SEP-17	1.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	22-SEP-17	1.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-OCT-16	4.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-OCT-16	4.900	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-OCT-16	7.700	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	14-OCT-16	16.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	22-SEP-17	1.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	22-SEP-17	1.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	06-JUN-19	38.100	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	06-JUN-19	52.200	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	06-JUN-19	50.400	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	06-JUN-19	53.200	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Flush180	08-AUG-23	1.510	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Initial	08-AUG-23	1.440	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Initial	14-JUL-23	4.000	ug/L
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Initial	22-SEP-17	1.000	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Initial	14-OCT-16	4.200	ppb
51637	51637-1-W-HAL-F07	Across Room 104A Right Fountain	Initial	06-JUN-19	14.100	ug/L
51637	51637-3-W-HAL-F06	By beta commons room 304	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F06	By beta commons room 304	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F06	By beta commons room 304	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F06	By beta commons room 304	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F06	By beta commons room 304	Initial	06-JUN-19	1.000	ug/L
51637	51637-3-E-HAL-F02	By room 325	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-E-HAL-F02	By room 325	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-E-HAL-F02	By room 325	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-E-HAL-F02	By room 325	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-E-HAL-F02	By room 325	Initial	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	24-APR-20	3.450	ug/L
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	24-APR-20	3.050	ug/L
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	24-APR-20	2.750	ug/L
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Flush180	24-APR-20	2.480	ug/L
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Initial	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F05	Main-Fountain (Left) Across Rm. 207	Initial	24-APR-20	3.840	ug/L
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Initial	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Initial	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F01	Main-Fountain (Left) Across Rm. 216	Initial	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F03	Main-Fountain (Left) Across Rm. 216	Initial	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Initial	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F03	Main-Fountain (Left) By 112B (Toilets)	Initial	06-JUN-19	1.000	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-JUL-23	2.510	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-JUL-23	2.390	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-JUL-23	2.580	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-JUL-23	3.220	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-OCT-16	4.200	ppb
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-OCT-16	3.700	ppb
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-OCT-16	3.700	ppb
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	14-OCT-16	8.300	ppb
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	06-JUN-19	6.750	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	06-JUN-19	8.190	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	06-JUN-19	5.830	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Flush180	06-JUN-19	5.770	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Initial	14-JUL-23	1.980	ug/L
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Initial	14-OCT-16	2.600	ppb
51637	51637-1-W-HAL-F06	Main-Fountain (Left) W. Wall Across Rm. 104A by 110	Initial	06-JUN-19	4.760	ug/L
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-	Main-Fountain (Right) Across Rm.	Flush180	24-APR-20	3.950	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F06	207				
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	24-APR-20	3.350	ug/L
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	24-APR-20	3.960	ug/L
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Flush180	24-APR-20	4.190	ug/L
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Initial	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F06	Main-Fountain (Right) Across Rm. 207	Initial	24-APR-20	3.180	ug/L
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Initial	14-OCT-16	1.000	ppb
51637	51637-2-W-HAL-F02	Main-Fountain (Right) Across Rm. 216	Initial	06-JUN-19	1.000	ug/L
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Flush180	06-JUN-19	1.000	ug/L
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Initial	14-OCT-16	1.000	ppb
51637	51637-2-N-HAL-F04	Main-Fountain (Right) Across Rm. 218	Initial	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Initial	14-OCT-16	1.000	ppb
51637	51637-1-E-HAL-F04	Main-Fountain (Right) By 112B (Toilets)	Initial	06-JUN-19	1.000	ug/L
51637	51637-3-HAL-F05	Main-Fountain Across Rm. 307	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-HAL-	Main-Fountain Across Rm. 307	Flush180	14-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51637	51637-3-HAL-F05	Main-Fountain Across Rm. 307	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-HAL-F05	Main-Fountain Across Rm. 307	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-HAL-F05	Main-Fountain Across Rm. 307	Initial	14-OCT-16	1.000	ppb
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Initial	14-OCT-16	1.000	ppb
51637	51637-3-N-HAL-F03	Main-Fountain Across Rm. 317	Initial	06-JUN-19	1.000	ug/L
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	11-JAN-17	7.400	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	11-JAN-17	9.100	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	11-JAN-17	10.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	11-JAN-17	10.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	14-OCT-16	44.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	14-OCT-16	42.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	14-OCT-16	51.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	14-OCT-16	48.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	06-JUN-19	4.730	ug/L
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	06-JUN-19	4.980	ug/L
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	06-JUN-19	4.390	ug/L
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Flush180	06-JUN-19	3.710	ug/L
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Initial	11-JAN-17	2.700	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Initial	14-OCT-16	18.000	ppb
51637	51637-B-N-HAL-F01	Main-Fountain Across from Engineers Office	Initial	06-JUN-19	4.940	ug/L
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	14-OCT-16	1.000	ppb
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Initial	14-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51637	51637-3-W-HAL-F04	Main-Fountain Between Boys & Girls Bath	Initial	06-JUN-19	1.000	ug/L
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	14-OCT-16	1.000	ppb
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	24-APR-20	1.000	ug/L
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	24-APR-20	1.000	ug/L
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	24-APR-20	1.000	ug/L
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Flush180	24-APR-20	1.000	ug/L
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Initial	14-OCT-16	1.000	ppb
51637	51637-2-N-235-F07	Main-Fountain Inside of Rm. 235 (Library)240	Initial	24-APR-20	1.000	ug/L
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	14-OCT-16	1.000	ppb
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Flush180	06-JUN-19	1.000	ug/L
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Initial	14-OCT-16	1.000	ppb
51637	51637-1-W-HAL-F05	Main-Fountain W. Wall Next to Girls Bath	Initial	06-JUN-19	1.000	ug/L
51637	51637-B-KIT-WC04	Main-Kitchen Fountain S. Wall	Flush180	14-OCT-16	3.700	ppb
51637	51637-B-KIT-WC04	Main-Kitchen Fountain S. Wall	Flush180	14-OCT-16	3.200	ppb
51637	51637-B-KIT-WC04	Main-Kitchen Fountain S. Wall	Flush180	14-OCT-16	2.700	ppb
51637	51637-B-KIT-WC04	Main-Kitchen Fountain S. Wall	Flush180	14-OCT-16	3.700	ppb
51637	51637-B-KIT-WC04	Main-Kitchen Fountain S. Wall	Initial	14-OCT-16	2.500	ppb
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Initial	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS02	Main-Kitchen N. Side Island Sink	Initial	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	14-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Initial	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS03	Main-Kitchen S. Side Island Sink	Initial	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Flush180	06-JUN-19	1.000	ug/L
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Initial	14-OCT-16	1.000	ppb
51637	51637-B-N-KIT-KS01	Main-Kitchen Sink N. Wall	Initial	06-JUN-19	1.000	ug/L
52380	52380-1-HAL-WC04	Art Bldg.-Fountain (Left) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-HAL-WC04	Art Bldg.-Fountain (Left) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-HAL-WC04	Art Bldg.-Fountain (Left) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-HAL-WC04	Art Bldg.-Fountain (Left) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-HAL-WC04	Art Bldg.-Fountain (Left) Across Rm 151 S. Wall	Initial	14-OCT-16	1.000	ppb
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	14-OCT-16	2.900	ppb
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	14-OCT-16	2.500	ppb
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	14-OCT-16	2.200	ppb
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.060	ug/L
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.180	ug/L
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.190	ug/L
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.220	ug/L
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Initial	14-OCT-16	2.200	ppb
52380	52380-1-N-HAL-F01	Art Bldg.-Fountain (Left) Across Rm 153B N. Wall	Initial	06-JUN-19	1.000	ug/L
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	14-OCT-16	1.000	ppb
52380	52380-1-N-	Art Bldg.-Fountain (Right) Across	Flush180	14-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03	Rm 151 S. Wall				
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	06-JUN-19	2.840	ug/L
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	06-JUN-19	2.900	ug/L
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	06-JUN-19	2.900	ug/L
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	06-JUN-19	2.840	ug/L
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Flush180	06-JUN-19	2.800	ug/L
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Initial	14-OCT-16	1.000	ppb
52380	52380-1-N-HAL-F03	Art Bldg.-Fountain (Right) Across Rm 151 S. Wall	Initial	06-JUN-19	1.990	ug/L
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	14-OCT-16	4.100	ppb
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	14-OCT-16	3.800	ppb
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	14-OCT-16	3.600	ppb
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	14-OCT-16	4.000	ppb
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.340	ug/L
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.400	ug/L
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.590	ug/L
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Flush180	06-JUN-19	1.620	ug/L
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Initial	14-OCT-16	3.300	ppb
52380	52380-1-N-HAL-F02	Art Bldg.-Fountain (Right) Across Rm 153B N. Wall	Initial	06-JUN-19	1.290	ug/L
52381	52381-1-N-HAL-F05		Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F05		Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F05		Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F05		Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F05		Initial	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Initial	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F01	Athletic Bldg.-Fountain (Left) By Entrance 17 S. W	Initial	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-S-	Athletic Bldg.-Fountain (Right) By	Flush180	06-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Entrance 17 S.				
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Initial	14-OCT-16	1.000	ppb
52381	52381-1-S-HAL-F02	Athletic Bldg.-Fountain (Right) By Entrance 17 S.	Initial	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	14-OCT-16	2.400	ppb
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	06-JUN-19	1.000	ug/L
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	06-JUN-19	1.970	ug/L
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Flush180	06-JUN-19	1.220	ug/L
52381	52381-1-N-HAL-F03	Athletic Bldg.-Fountain Outside of Stairs Leading	Initial	14-OCT-16	2.600	ppb
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-JUL-23	4.180	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-JUL-23	5.090	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-JUL-23	3.890	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-JUL-23	3.230	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-OCT-16	14.000	ppb
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-OCT-16	13.000	ppb
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-OCT-16	7.200	ppb
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	14-OCT-16	5.800	ppb
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	06-JUN-19	6.190	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	06-JUN-19	6.140	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	06-JUN-19	9.260	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	06-JUN-19	5.780	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	08-AUG-23	3.450	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	08-AUG-23	3.560	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	08-AUG-23	3.120	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Flush180	08-AUG-23	2.910	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Initial	14-JUL-23	9.450	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Initial	14-OCT-16	8.800	ppb
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Initial	06-JUN-19	6.810	ug/L
52381	52381-1-N-POOL-F01	Athletic Bldg.-Pool Fountain (Left)	Initial	08-AUG-23	4.760	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	14-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	14-OCT-16	1.000	ppb
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	06-JUN-19	1.750	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	06-JUN-19	1.370	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	06-JUN-19	1.250	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	06-JUN-19	1.230	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	24-APR-20	2.760	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	24-APR-20	3.500	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	24-APR-20	3.290	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Flush180	24-APR-20	4.430	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Initial	14-OCT-16	1.000	ppb
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Initial	06-JUN-19	2.210	ug/L
52381	52381-1-N-POOL-F02	Athletic Bldg.-Pool Fountain (Right)	Initial	24-APR-20	1.600	ug/L