



Sep 10, 2024

JUNGMAN

1746 S MILLER ST, Chicago IL 60608.

Dear **JUNGMAN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

JUNGMAN

1746 S MILLER ST, Chicago IL 60608.

Estimadas familias de **JUNGMAN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F06	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F06	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F06	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F06	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105	Initial	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F06	1ST FL Hall outside RM 105	Initial	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F05	1ST FL Hall outside RM 105 Left Fountain	Initial	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F02	1st FL Hall outside RM 101	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F02	1st FL Hall outside RM 101	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F02	1st FL Hall outside RM 101	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F02	1st FL Hall outside RM 101	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F02	1st FL Hall outside RM 101	Initial	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F01	1st FL Hall outside RM 101 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F01	1st FL Hall outside RM 101 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F01	1st FL Hall outside RM 101 Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F01	1st FL Hall outside RM 101 Left Fountain	Initial	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F02	1st FL Hall outside RM 101 Right Fountain	Flush	09-FEB-2024	1.090	ug/L
51242	51242-1-HAL-F02	1st FL Hall outside RM 101 Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F02	1st FL Hall outside RM 101 Right Fountain	Flush	09-FEB-2024	1.360	ug/L
51242	51242-1-HAL-F02	1st FL Hall outside RM 101 Right Fountain	Flush	09-FEB-2024	1.120	ug/L
51242	51242-1-HAL-F02	1st FL Hall outside RM 101 Right Fountain	Initial	09-FEB-2024	2.140	ug/L
51242	51242-1-HAL-F06	1st FL Hall outside RM 105 Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F06	1st FL Hall outside RM 105 Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-HAL-F06	1st FL Hall outside RM 105 Right Fountain	Flush	09-FEB-2024	2.460	ug/L
51242	51242-1-HAL-F06	1st FL Hall outside RM 105 Right Fountain	Flush	09-FEB-2024	1.810	ug/L
51242	51242-1-HAL-F06	1st FL Hall outside RM 105 Right Fountain	Initial	09-FEB-2024	1.300	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51242	51242-2-HAL-F03	2nd FL Hall outside Bathrooms 210 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F03	2nd FL Hall outside Bathrooms 210 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F03	2nd FL Hall outside Bathrooms 210 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F03	2nd FL Hall outside Bathrooms 210 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F03	2nd FL Hall outside Bathrooms 210 Left Fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Initial	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-RBF02	2nd FL Hall outside Bathrooms 210 Left Retrofit Bottle Filler	Initial	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	11-MAY-22	2.000	ug/L
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F04	2nd FL Hall outside Bathrooms 210 Right Fountain	Initial	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	02-OCT-20	1.630	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	11-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Initial	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Initial	02-OCT-20	2.250	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Initial	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F01	Basement Hall by Door #5 left	Initial	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush	09-FEB-2024	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Initial	15-SEP-16	1.000	ppb
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Initial	11-MAY-22	1.000	ug/L
51242	51242-B-HAL-F02	Basement Hall by Door #5 right	Initial	09-FEB-2024	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush	09-FEB-2024	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Initial	15-SEP-16	1.000	ppb
51242	51242-1-100-S01	Kindergarten RM 100	Initial	11-MAY-22	1.000	ug/L
51242	51242-1-100-S01	Kindergarten RM 100	Initial	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F02	Left Fountain on East Wall outside 201	Flush	09-FEB-2024	1.010	ug/L
51242	51242-2-HAL-F02	Left Fountain on East Wall outside 201	Flush	09-FEB-2024	1.980	ug/L
51242	51242-2-HAL-F02	Left Fountain on East Wall outside	Flush	09-FEB-2024	1.290	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	201				
51242	51242-2-HAL-F02	Left Fountain on East Wall outside 201	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F02	Left Fountain on East Wall outside 201	Initial	09-FEB-2024	2.900	ug/L
51242	51242-1-HAL-F03	Left Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F03	Left Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F03	Left Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F03	Left Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F03	Left Fountain on West Wall	Initial	15-SEP-16	1.000	ppb
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush	12-MAR-2024	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush	12-MAR-2024	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush	12-MAR-2024	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush	12-MAR-2024	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Initial	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-RBF01	Left Retrofit Bottle Filler on West Wall	Initial	12-MAR-2024	1.000	ug/L
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	11-MAY-22	1.020	ug/L
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Initial	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS02	Middle Sink on East Wall	Initial	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS01	North Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS01	North Sink on East Wall	Initial	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS01	North Sink on East Wall	Initial	11-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01					
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	17-MAY-23	3.990	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	17-MAY-23	3.060	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	17-MAY-23	6.270	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	17-MAY-23	3.130	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	29-JUN-23	5.450	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	29-JUN-23	4.050	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	29-JUN-23	3.430	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	29-JUN-23	4.470	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	09-AUG-23	6.120	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	09-AUG-23	3.990	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	09-AUG-23	3.270	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	09-AUG-23	2.970	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Initial	17-MAY-23	7.390	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Initial	29-JUN-23	9.440	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Initial	09-AUG-23	6.420	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Initial	15-SEP-16	6.150	ppb
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush	09-FEB-2024	1.670	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Flush	09-FEB-2024	1.070	ug/L
51242	51242-2-HAL-F05	Outside 205, Left Fountain	Initial	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	17-MAY-23	1.700	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	17-MAY-23	1.940	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	17-MAY-23	3.150	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	17-MAY-23	1.790	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	29-JUN-23	16.600	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	29-JUN-23	9.170	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	29-JUN-23	6.650	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	29-JUN-23	5.370	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	09-AUG-23	4.210	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	09-AUG-23	1.820	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	09-AUG-23	1.130	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	09-AUG-23	1.000	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Initial	17-MAY-23	5.050	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Initial	29-JUN-23	54.700	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Initial	09-AUG-23	9.640	ug/L
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F06	Outside 205, Right Fountain	Initial	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush	09-FEB-2024	2.960	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush	09-FEB-2024	2.670	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush	09-FEB-2024	2.450	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush	09-FEB-2024	1.210	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F01	Outside RM 301	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F01	Outside RM 301	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F01	Outside RM 301	Flush180	02-OCT-20	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	18-AUG-22	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	18-AUG-22	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	18-AUG-22	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	18-AUG-22	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	11-MAY-22	11.800	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	11-MAY-22	5.850	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	11-MAY-22	5.850	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Flush180	11-MAY-22	5.880	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Initial	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F01	Outside RM 301	Initial	02-OCT-20	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Initial	18-AUG-22	1.000	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Initial	11-MAY-22	30.400	ug/L
51242	51242-3-HAL-F01	Outside RM 301	Initial	09-FEB-2024	4.920	ug/L
51242	51242-3-HAL-F02	Outside RM 302 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F02	Outside RM 302 Left Fountain	Flush180	15-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51242	51242-3-HAL-F02	Outside RM 302 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F02	Outside RM 302 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F02	Outside RM 302 Left Fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Initial	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-RBF03	Outside RM 302 Left Retrofit Bottle Filler	Initial	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F03	Outside RM 302 Right Fountain	Initial	11-MAY-22	1.000	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	29-MAR-2024	5.400	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	29-MAR-2024	1.900	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	29-MAR-2024	3.550	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	29-MAR-2024	3.020	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	12-MAR-2024	6.590	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	12-MAR-2024	3.500	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	12-MAR-2024	3.880	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	12-MAR-2024	5.140	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	09-FEB-2024	2.600	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	09-FEB-2024	5.180	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush	09-FEB-2024	2.690	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	09-AUG-23	2.730	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	17-MAY-23	6.090	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	17-MAY-23	6.040	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	17-MAY-23	5.670	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	17-MAY-23	5.960	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	29-JUN-23	4.190	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	29-JUN-23	5.490	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	29-JUN-23	3.130	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	29-JUN-23	2.690	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	09-AUG-23	2.820	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	09-AUG-23	3.820	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	09-AUG-23	2.910	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	15-SEP-16	5.080	ppb
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	09-AUG-23	5.740	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	17-MAY-23	5.910	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	29-JUN-23	5.330	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	29-MAR-2024	1.840	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	12-MAR-2024	3.080	ug/L
51242	51242-3-HAL-F04	Outside RM 305, left fountain	Initial	09-FEB-2024	2.260	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush	09-FEB-2024	1.310	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush	09-FEB-2024	1.000	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	17-MAY-23	4.450	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	17-MAY-23	2.330	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	17-MAY-23	1.950	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	17-MAY-23	1.290	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	29-JUN-23	1.610	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	29-JUN-23	2.070	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	29-JUN-23	1.180	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	29-JUN-23	1.600	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	15-SEP-16	6.650	ppb
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Initial	17-MAY-23	32.600	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Initial	29-JUN-23	3.950	ug/L
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Initial	15-SEP-16	6.780	ppb
51242	51242-3-HAL-F05	Outside RM 305, right fountain	Initial	09-FEB-2024	4.380	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Initial	15-SEP-16	5.130	ppb
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Initial	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush	09-FEB-2024	1.230	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush	09-FEB-2024	2.590	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush	09-FEB-2024	1.620	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Flush	09-FEB-2024	1.720	ug/L
51242	51242-2-HAL-F01	Right Fountain on East Wall outside 201	Initial	09-FEB-2024	4.820	ug/L
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-F04	Right Fountain on West Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-1-HAL-F04	Right Fountain on West Wall	Initial	15-SEP-16	1.000	ppb
51242	51242-1-HAL-F04	Right Fountain on West Wall	Initial	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	15-SEP-16	1.000	ppb
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Flush180	11-MAY-22	1.000	ug/L
51242	51242-B-KIT-KS03	South Sink on East Wall	Initial	15-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51242	51242-B-KIT-KS03	South Sink on East Wall	Initial	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F02	outside 201 Left Fountain	Flush180	11-MAY-22	1.000	ug/L
51242	51242-2-HAL-F02	outside 201 Left Fountain	Initial	15-SEP-16	1.000	ppb
51242	51242-2-HAL-F02	outside 201 Left Fountain	Initial	11-MAY-22	1.000	ug/L