



Sep 10, 2024

KANOON

2233 S KEDZIE AVE, Chicago IL 60623.

Dear **KANOON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

KANOON

2233 S KEDZIE AVE, Chicago IL 60623.

Estimadas familias de **KANOON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F06	Across 112 right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F06	Across 112 right	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F05	Across fro. 112 left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F05	Across fro. 112 left	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Flush180	05-AUG-20	1.970	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F02	Across kitchen by girls bathroom right	Initial	05-AUG-20	1.880	ug/L
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	17-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-HAL-F01	Across kitchen next to girls restroom .	Initial	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	04-JUN-19	1.100	ug/L
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F02	Between Room 220 & 222	Initial	04-JUN-19	1.090	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F01	By Room 201	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F01	By Room 201	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F01	By Room 201	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F01	By Room 201	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F01	By Room 201	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-F01	By Room 201	Flush180	04-JUN-19	1.770	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Flush180	05-AUG-20	1.000	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Initial	04-JUN-19	1.480	ug/L
51268	51268-2-N-HAL-F01	By Room 201	Initial	05-AUG-20	1.320	ug/L
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	04-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51268	51268-2-E-HAL-WC02	By Room 205	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-E-HAL-WC02	By Room 205	Initial	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	17-JUN-16	1.000	ppb
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-WC01	By Room 242	Flush180	04-JUN-19	1.000	ug/L
51268	51268-2-N-HAL-WC01	By Room 242	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-W-118-F01	Classroom 118	Flush180	30-AUG-19	1.000	ug/L
51268	51268-1-W-118-F01	Classroom 118	Flush180	30-AUG-19	1.000	ug/L
51268	51268-1-W-118-F01	Classroom 118	Flush180	30-AUG-19	1.000	ug/L
51268	51268-1-W-118-F01	Classroom 118	Flush180	30-AUG-19	1.500	ug/L
51268	51268-1-W-118-F01	Classroom 118	Initial	30-AUG-19	1.000	ug/L
51268	51268-1-W-120-F01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-F01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-F01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	17-JUN-16	13.200	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	17-JUN-16	68.900	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	17-JUN-16	8.640	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-AUG-16	3.220	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-AUG-16	3.900	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-AUG-16	4.620	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-AUG-16	3.180	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-NOV-16	5.000	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-NOV-16	2.700	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-NOV-16	4.300	ppb
51268	51268-1-W-120-S01	Classroom 120	Flush180	10-NOV-16	5.400	ppb
51268	51268-1-W-120-F01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-F01	Classroom 120	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-120-F01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-F01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-F01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	120-F01					
51268	51268-1-W-120-F01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-S01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-S01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-S01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-S01	Classroom 120	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-S01	Classroom 120	Initial	10-AUG-16	6.020	ppb
51268	51268-1-W-120-S01	Classroom 120	Initial	10-NOV-16	5.600	ppb
51268	51268-1-W-120-F01	Classroom 120	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-W-120-S01	Classroom 120	Initial	04-JUN-19	1.240	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-S01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-S01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-S01	Classroom 122	Flush180	17-JUN-16	8.240	ppb
51268	51268-1-E-122-F01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-F01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-F01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-F01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-F01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-S01	Classroom 122	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-E-122-F01	Classroom 122	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-E-122-F01	Classroom 122	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-E-122-F01	Classroom 122	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	04-JUN-19	10.500	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	04-JUN-19	2.800	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	04-JUN-19	2.240	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	04-JUN-19	2.660	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	22-APR-20	1.260	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	22-APR-20	1.000	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	22-APR-20	1.000	ug/L
51268	51268-1-E-122-S01	Classroom 122	Flush180	22-APR-20	1.000	ug/L
51268	51268-1-E-122-F01	Classroom 122	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-E-122-S01	Classroom 122	Initial	04-JUN-19	11.700	ug/L
51268	51268-1-E-122-S01	Classroom 122	Initial	22-APR-20	1.890	ug/L
51268	51268-1-HAL-F03	Gym	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-HAL-F03	Gym	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-HAL-	Gym	Flush180	17-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51268	51268-1-HAL-F03	Gym	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-HAL-F03	Gym	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS02	Kitchen Left Sink	Initial	04-JUN-19	2.040	ug/L
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Initial	17-JUN-16	1.000	ppb
51268	51268-1-S-KIT-KS01	Kitchen Right Sink	Initial	04-JUN-19	1.000	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-W-118-S01	Room 118	Flush180	17-JUN-16	7.880	ppb
51268	51268-1-W-118-S01	Room 118	Flush180	17-JUN-16	13.900	ppb
51268	51268-1-W-118-S01	Room 118	Flush180	17-JUN-16	6.450	ppb
51268	51268-1-W-118-S01	Room 118	Flush180	17-JUN-16	5.530	ppb
51268	51268-1-W-118-S01	Room 118	Flush180	04-JUN-19	18.400	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	04-JUN-19	4.050	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	04-JUN-19	6.360	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	04-JUN-19	11.700	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	30-AUG-19	1.510	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	30-AUG-19	1.000	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	30-AUG-19	1.000	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	30-AUG-19	2.430	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	03-OCT-19	1.000	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	03-OCT-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51268	51268-1-W-118-S01	Room 118	Flush180	03-OCT-19	1.000	ug/L
51268	51268-1-W-118-S01	Room 118	Flush180	03-OCT-19	1.000	ug/L
51268	51268-1-W-118-S01	Room 118	Initial	04-JUN-19	13.800	ug/L
51268	51268-1-W-118-S01	Room 118	Initial	30-AUG-19	6.140	ug/L
51268	51268-1-W-118-S01	Room 118	Initial	03-OCT-19	1.000	ug/L
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F04	W Corridor Across Caf? Left	Initial	04-JUN-19	1.170	ug/L
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	17-JUN-16	1.000	ppb
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Flush180	04-JUN-19	1.000	ug/L
51268	51268-1-S-HAL-F03	W Corridor Across dining room ? Left	Initial	04-JUN-19	1.000	ug/L