



Sep 10, 2024

KENNEDY HS

6325 W 56TH ST, Chicago IL 60638.

Dear **KENNEDY HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

KENNEDY HS

6325 W 56TH ST, Chicago IL 60638.

Estimadas familias de **KENNEDY HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	05-OCT-16	0.380	ppb
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	05-OCT-16	0.320	ppb
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	05-OCT-16	0.240	ppb
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	05-OCT-16	0.220	ppb
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Initial	05-OCT-16	0.230	ppb
51677	51677-3-HAL-F03	Across RM 308 Left Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	05-OCT-16	0.350	ppb
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	05-OCT-16	0.320	ppb
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	05-OCT-16	0.420	ppb
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	05-OCT-16	0.250	ppb
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Initial	05-OCT-16	0.310	ppb
51677	51677-3-HAL-F04	Across RM 308 Right Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F01	Bottle Filler Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F01	Bottle Filler Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F01	Bottle Filler Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	05-OCT-16	0.160	ppb
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	13-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Initial	05-OCT-16	0.230	ppb
51677	51677-1-BLR-F02	Boy's Locker RM Left Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	05-OCT-16	0.200	ppb
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Initial	05-OCT-16	0.290	ppb
51677	51677-1-BLR-F01	Boys locker RM Right Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-CAF-F01	Cafeteria Bottle Filler, West Wall	Flush180	18-DEC-20	1.000	ug/L
51677	51677-1-CAF-F01	Cafeteria Bottle Filler, West Wall	Initial	18-DEC-20	1.000	ug/L
51677	51677-1-LR-F04	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F04	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F04	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F03	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F03	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F03	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F03	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F04	Girls Locker RM	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-LR-F03	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F03	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F03	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F03	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F04	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F04	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F04	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F04	Girls Locker RM	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F03	Girls Locker RM	Initial	05-OCT-16	1.000	ppb
51677	51677-1-LR-F04	Girls Locker RM	Initial	05-OCT-16	1.000	ppb
51677	51677-1-LR-F03	Girls Locker RM	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-LR-F04	Girls Locker RM	Initial	13-MAR-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F02	Kitchen Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F02	Kitchen Left Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F02	Kitchen Left Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	05-OCT-16	0.210	ppb
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	05-OCT-16	0.810	ppb
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	05-OCT-16	0.610	ppb
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Initial	05-OCT-16	0.520	ppb
51677	51677-1-KIT-S06	Kitchen North Wall Left Sink	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Initial	05-OCT-16	0.430	ppb
51677	51677-1-KIT-S07	Kitchen North Wall Right Sink	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-F03	Kitchen Right Fountain	Flush180	13-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51677	51677-1-KIT-F03	Kitchen Right Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-KIT-F03	Kitchen Right Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	05-OCT-16	0.540	ppb
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	05-OCT-16	0.710	ppb
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	05-OCT-16	0.840	ppb
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	05-OCT-16	0.780	ppb
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	13-MAR-20	1.090	ug/L
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	13-MAR-20	1.060	ug/L
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Initial	05-OCT-16	2.100	ppb
51677	51677-1-KIT-S08	Kitchen Sink East Wall	Initial	13-MAR-20	1.370	ug/L
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Initial	05-OCT-16	2.000	ppb
51677	51677-1-KIT-S01	Kitchen South Wall Left Sink	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Initial	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S02	Kitchen South Wall Middle Sink	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	05-OCT-16	0.220	ppb
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	05-OCT-16	0.230	ppb
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	05-OCT-16	0.400	ppb
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	05-OCT-16	0.310	ppb
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S03					
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Initial	05-OCT-16	1.800	ppb
51677	51677-1-KIT-S03	Kitchen South Wall Right Sink	Initial	13-MAR-20	1.300	ug/L
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Initial	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S04	Kitchen West Wall Left Sink	Initial	13-MAR-20	1.040	ug/L
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Initial	05-OCT-16	1.000	ppb
51677	51677-1-KIT-S05	Kitchen West Wall Right Sink	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F03	Left Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F03	Left Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F03	Left Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F03	Left Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F03	Left Fountain East end of hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	22-NOV-2023	2.130	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	22-NOV-2023	2.320	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	22-NOV-2023	2.450	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	22-NOV-2023	2.510	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	24-OCT-2023	2.630	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	24-OCT-2023	1.770	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	24-OCT-2023	1.100	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	24-OCT-2023	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	26-APR-2024	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	26-APR-2024	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	26-APR-2024	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush	26-APR-2024	1.000	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	0.540	ppb
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	0.590	ppb
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	0.440	ppb
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	0.430	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	0.900	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	2.500	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	1.200	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	05-OCT-16	2.700	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.050	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.470	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.320	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	03-MAR-21	2.620	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	03-MAR-21	4.190	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	03-MAR-21	6.840	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	03-MAR-21	4.140	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	18-DEC-20	3.010	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	24-AUG-23	3.260	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	24-AUG-23	2.270	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	24-AUG-23	2.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Flush180	24-AUG-23	1.730	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Initial	05-OCT-16	0.350	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	05-OCT-16	0.760	ppb
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	03-MAR-21	4.260	ug/L
51677	51677-2-HAL-F01	Left Fountain West End of Hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	18-DEC-20	6.020	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	24-AUG-23	12.600	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	22-NOV-2023	5.140	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	24-OCT-2023	5.720	ug/L
51677	51677-3-HAL-F01	Left Fountain West End of Hall	Initial	26-APR-2024	1.000	ug/L
51677	51677-2-HAL-F04	Middle Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F04	Middle Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F04	Middle Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F04	Middle Fountain East end of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F04	Middle Fountain East end of hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F05	Near 104	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F05	Near 104	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F05	Near 104	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F05	Near 104	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F05	Near 104	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F05	Near 104	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F05	Near 104	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F05	Near 104	Initial	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F05	Near 104	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F03	Near 104 Bottle Filler	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F03	Near 104 Bottle Filler	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F03	Near 104 Bottle Filler	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F03	Near 104 Bottle Filler	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F03	Near 104 Bottle Filler	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F04	Near 104 Middle Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-	Next to RM 112 Left Fountain	Flush180	13-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F01	Next to RM 112 Left Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	05-OCT-16	0.180	ppb
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	05-OCT-16	0.170	ppb
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-HAL-F02	Next to RM 112 Right Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	05-OCT-16	0.630	ppb
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	05-OCT-16	0.460	ppb
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	05-OCT-16	0.550	ppb
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	05-OCT-16	0.520	ppb
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	05-OCT-16	0.430	ppb
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	05-OCT-16	0.360	ppb
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	05-OCT-16	0.580	ppb
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	05-OCT-16	0.370	ppb
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F08	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F09	Outside Boys Gym	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F08	Outside Boys Gym	Initial	05-OCT-16	0.720	ppb
51677	51677-2-HAL-F09	Outside Boys Gym	Initial	05-OCT-16	0.520	ppb
51677	51677-2-HAL-F08	Outside Boys Gym	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F09	Outside Boys Gym	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	05-OCT-16	0.440	ppb
51677	51677-2-HAL-	Outside of Gym Left Fountain	Flush180	05-OCT-16	0.740	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06					
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	05-OCT-16	0.570	ppb
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	05-OCT-16	0.610	ppb
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Initial	05-OCT-16	0.750	ppb
51677	51677-2-HAL-F06	Outside of Gym Left Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	05-OCT-16	0.460	ppb
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	05-OCT-16	0.620	ppb
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	05-OCT-16	0.570	ppb
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	05-OCT-16	0.590	ppb
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Flush180	05-MAY-23	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Initial	05-OCT-16	0.710	ppb
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F07	Outside of Gym Right Fountain	Initial	05-MAY-23	1.000	ug/L
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	05-OCT-16	0.160	ppb
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F01	Pool Left Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F01	Pool Left Fountain	Initial	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F01	Pool Left Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	05-OCT-16	1.000	ppb
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	05-OCT-16	0.170	ppb
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	13-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51677	51677-1-POOL-F02	Pool Right Fountain	Flush180	13-MAR-20	1.000	ug/L
51677	51677-1-POOL-F02	Pool Right Fountain	Initial	05-OCT-16	0.170	ppb
51677	51677-1-POOL-F02	Pool Right Fountain	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F05	Right Fountain East End of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F05	Right Fountain East End of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F05	Right Fountain East End of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F05	Right Fountain East End of hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F05	Right Fountain East End of hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	0.900	ppb
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	0.400	ppb
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	3.500	ppb
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	2.200	ppb
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	1.300	ppb
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	0.420	ppb
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	0.430	ppb
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	05-OCT-16	0.470	ppb
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Flush180	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Flush180	05-MAY-23	1.740	ug/L
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Initial	05-OCT-16	0.490	ppb
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Initial	05-OCT-16	1.700	ppb
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-2-HAL-F02	Right Fountain West End of Hall	Initial	13-MAR-20	1.000	ug/L
51677	51677-3-HAL-F02	Right Fountain West End of Hall	Initial	05-MAY-23	1.430	ug/L