



**Sep 10, 2024**

**KENWOOD HS**

**5015 S BLACKSTONE AVE, Chicago IL 60615.**

Dear **KENWOOD HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**KENWOOD HS**

**5015 S BLACKSTONE AVE, Chicago IL 60615.**

Estimadas familias de **KENWOOD HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	25-OCT-16	0.570	ppb
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	25-OCT-16	0.480	ppb
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	25-OCT-16	0.410	ppb
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	25-OCT-16	0.320	ppb
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	22-MAY-19	1.450	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Initial	25-OCT-16	2.100	ppb
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Initial	22-MAY-19	5.900	ug/L
51404	51404-1-S-HAL-F05	East End Hall 2nd Fountain from Right	Initial	29-APR-20	1.490	ug/L
51404	51404-3-S-HAL-F02	East End Hall 2nd From Left	Flush180	25-OCT-16	3.100	ppb
51404	51404-3-S-HAL-F02	East End Hall 2nd From Left	Flush180	25-OCT-16	2.100	ppb
51404	51404-3-S-HAL-F02	East End Hall 2nd From Left	Flush180	25-OCT-16	2.100	ppb
51404	51404-3-S-HAL-F02	East End Hall 2nd From Left	Flush180	25-OCT-16	1.800	ppb
51404	51404-3-S-HAL-F02	East End Hall 2nd From Left	Initial	25-OCT-16	7.000	ppb
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	25-OCT-16	0.730	ppb
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	25-OCT-16	0.710	ppb
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	25-OCT-16	0.840	ppb
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	25-OCT-16	0.960	ppb
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	23-MAY-19	6.430	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	23-MAY-19	6.310	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	23-MAY-19	5.870	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	23-MAY-19	4.780	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Flush180	29-APR-20	1.000	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Initial	25-OCT-16	4.200	ppb
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Initial	23-MAY-19	9.640	ug/L
51404	51404-1-S-HAL-F06	East End Hall 3rd Fountain from Right	Initial	29-APR-20	2.140	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51404	51404-3-S-HAL-F03	East End Hall 3rd From left	Flush180	25-OCT-16	2.300	ppb
51404	51404-3-S-HAL-F03	East End Hall 3rd From left	Flush180	25-OCT-16	4.700	ppb
51404	51404-3-S-HAL-F03	East End Hall 3rd From left	Flush180	25-OCT-16	3.000	ppb
51404	51404-3-S-HAL-F03	East End Hall 3rd From left	Flush180	25-OCT-16	2.100	ppb
51404	51404-3-S-HAL-F03	East End Hall 3rd From left	Initial	25-OCT-16	14.000	ppb
51404	51404-3-S-HAL-F01	East End Hall Left Fountain	Flush180	25-OCT-16	6.700	ppb
51404	51404-3-S-HAL-F01	East End Hall Left Fountain	Flush180	25-OCT-16	6.600	ppb
51404	51404-3-S-HAL-F01	East End Hall Left Fountain	Flush180	25-OCT-16	7.700	ppb
51404	51404-3-S-HAL-F01	East End Hall Left Fountain	Flush180	25-OCT-16	6.300	ppb
51404	51404-3-S-HAL-F01	East End Hall Left Fountain	Initial	25-OCT-16	10.000	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	25-OCT-16	22.000	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	25-OCT-16	2.500	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	25-OCT-16	6.100	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	17-FEB-17	1.900	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	17-FEB-17	1.600	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	17-FEB-17	2.600	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	25-OCT-16	17.000	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Flush180	17-FEB-17	3.300	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Initial	25-OCT-16	7.500	ppb
51404	51404-2-S-HAL-F05	East End Hall Middle Fountain	Initial	17-FEB-17	12.000	ppb
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	25-OCT-16	3.000	ppb
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	25-OCT-16	2.400	ppb
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	25-OCT-16	2.900	ppb
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	25-OCT-16	1.700	ppb
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	22-MAY-19	5.060	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	22-MAY-19	3.470	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	22-MAY-19	2.320	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	22-MAY-19	1.730	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	22-MAY-19	7.190	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	22-MAY-19	3.920	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	22-MAY-19	2.980	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	22-MAY-19	6.740	ug/L
51404	51404-2-S-HAL-F07	East End Hall Right Fountain	Flush180	22-MAY-19	25.300	ug/L
51404	51404-2-S-HAL-F07	East End Hall Right Fountain	Flush180	22-MAY-19	23.300	ug/L
51404	51404-2-S-HAL-F07	East End Hall Right Fountain	Flush180	22-MAY-19	18.500	ug/L
51404	51404-2-S-HAL-F07	East End Hall Right Fountain	Flush180	22-MAY-19	8.410	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	29-APR-20	1.570	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	29-APR-20	2.430	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	29-APR-20	2.350	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	29-APR-20	2.170	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	29-APR-20	11.900	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	29-APR-20	6.630	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	29-APR-20	5.750	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Flush180	29-APR-20	8.220	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Flush180	17-DEC-20	1.000	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Initial	25-OCT-16	6.200	ppb
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Initial	22-MAY-19	8.580	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Initial	22-MAY-19	5.680	ug/L
51404	51404-2-S-HAL-F07	East End Hall Right Fountain	Initial	22-MAY-19	17.700	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Initial	29-APR-20	5.280	ug/L
51404	51404-2-S-HAL-F06	East End Hall Right Fountain	Initial	29-APR-20	8.300	ug/L
51404	51404-1-S-HAL-F04	East End Hall Right Fountain	Initial	17-DEC-20	1.000	ug/L
51404	51404-3-S-HAL-F04	East End Hall Right Fountain next to 340	Flush180	25-OCT-16	1.100	ppb
51404	51404-3-S-HAL-F04	East End Hall Right Fountain next to 340	Flush180	25-OCT-16	0.740	ppb
51404	51404-3-S-HAL-F04	East End Hall Right Fountain next to 340	Flush180	25-OCT-16	0.640	ppb
51404	51404-3-S-HAL-F04	East End Hall Right Fountain next to 340	Flush180	25-OCT-16	0.770	ppb
51404	51404-3-S-HAL-F04	East End Hall Right Fountain next to 340	Initial	25-OCT-16	3.600	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	25-OCT-16	29.000	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	17-FEB-17	1.800	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	17-FEB-17	1.900	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	17-FEB-17	2.600	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	17-FEB-17	3.800	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	25-OCT-16	33.000	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	25-OCT-16	31.000	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Flush180	25-OCT-16	28.000	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Initial	17-FEB-17	10.000	ppb
51404	51404-2-S-HAL-F04	East End of Hall Right Fountain	Initial	25-OCT-16	48.000	ppb
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	25-OCT-16	0.420	ppb
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	25-OCT-16	0.240	ppb
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	25-OCT-16	0.550	ppb
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	25-OCT-16	0.240	ppb
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Flush180	22-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS01					
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Initial	25-OCT-16	1.100	ppb
51404	51404-1-N-KIT-KS01	Kitchen Left Sink	Initial	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	25-OCT-16	0.840	ppb
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Initial	25-OCT-16	0.160	ppb
51404	51404-1-N-KIT-KS02	Kitchen Right Sink	Initial	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F03	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F03	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F03	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F03	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	0.330	ppb
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	0.630	ppb
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	0.380	ppb
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	0.470	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	25-OCT-16	0.520	ppb
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	25-OCT-16	0.360	ppb
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	25-OCT-16	0.430	ppb
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	25-OCT-16	0.810	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-3-S-	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F05					
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F03	West End of Hall Left Fountain	Initial	25-OCT-16	1.000	ppb
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Initial	25-OCT-16	0.600	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Initial	25-OCT-16	0.190	ppb
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Initial	25-OCT-16	0.230	ppb
51404	51404-1-S-HAL-F01	West End of Hall Left Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F01	West End of Hall Left Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F05	West End of Hall Left Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	25-OCT-16	0.170	ppb
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	25-OCT-16	0.270	ppb
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	25-OCT-16	0.190	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	0.210	ppb
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	0.180	ppb
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	25-OCT-16	0.270	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Initial	25-OCT-16	0.290	ppb
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Initial	25-OCT-16	0.600	ppb
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Initial	25-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51404	51404-1-S-HAL-F02	West End of Hall Middle Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F02	West End of Hall Middle Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F06	West End of Hall Middle Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	25-OCT-16	0.860	ppb
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	25-OCT-16	0.340	ppb
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	25-OCT-16	0.570	ppb
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	25-OCT-16	0.730	ppb
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Flush180	25-OCT-16	0.160	ppb
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Flush180	25-OCT-16	0.270	ppb
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Flush180	25-OCT-16	1.000	ppb
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	22-MAY-19	3.390	ug/L
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	22-MAY-19	4.210	ug/L
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	22-MAY-19	1.780	ug/L
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Flush180	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Flush180	17-DEC-20	1.000	ug/L
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Initial	25-OCT-16	0.250	ppb
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Initial	25-OCT-16	1.000	ppb
51404	51404-3-S-HAL-F07	West End of Hall Right Fountain	Initial	22-MAY-19	1.000	ug/L
51404	51404-2-S-HAL-F03	West End of Hall Right Fountain	Initial	17-DEC-20	1.000	ug/L
51586	51586-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-BF01		Initial	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-BF01		Initial	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-BF01		Initial	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT	Handwashing	Flush180	25-OCT-16	2.100	ppb
51586	51586-2-E-KIT	Handwashing	Flush180	25-OCT-16	0.790	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51586	51586-2-E-KIT	Handwashing	Flush180	25-OCT-16	0.300	ppb
51586	51586-2-E-KIT	Handwashing	Flush180	25-OCT-16	0.660	ppb
51586	51586-2-E-KIT	Handwashing	Initial	25-OCT-16	4.500	ppb
51586	51586-2-W-KIT-KS04	Island west wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS04	Island west wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS04	Island west wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS04	Island west wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS04	Island west wall	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	25-OCT-16	0.330	ppb
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	25-OCT-16	0.330	ppb
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	25-OCT-16	0.340	ppb
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	25-OCT-16	0.390	ppb
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Initial	25-OCT-16	0.320	ppb
51586	51586-2-E-KIT-KS05	Kitchen Left Sink on SE Wall	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	25-OCT-16	1.400	ppb
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	25-OCT-16	0.810	ppb
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	25-OCT-16	0.480	ppb
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	25-OCT-16	0.590	ppb
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Initial	25-OCT-16	3.500	ppb
51586	51586-2-W-KIT-KS02	Kitchen Middle Sink on NE Wall	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	25-OCT-16	0.380	ppb
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	25-OCT-16	0.370	ppb
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	25-OCT-16	0.360	ppb
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	25-OCT-16	0.390	ppb
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Initial	25-OCT-16	0.310	ppb
51586	51586-2-E-KIT-KS06	Kitchen Middle sink on SE Wall	Initial	21-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS06					
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	25-OCT-16	0.510	ppb
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	25-OCT-16	0.620	ppb
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	25-OCT-16	0.540	ppb
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	25-OCT-16	0.560	ppb
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Initial	25-OCT-16	0.680	ppb
51586	51586-2-E-KIT-KS07	Kitchen Right Sink on SE Wall	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	25-OCT-16	0.400	ppb
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	25-OCT-16	0.270	ppb
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Initial	25-OCT-16	0.820	ppb
51586	51586-2-W-KIT-KS01	Kitchen right sink on NE Wall	Initial	21-MAY-19	1.000	ug/L
51586	51586-1-106C-S01	Library	Flush180	25-OCT-16	1.100	ppb
51586	51586-1-106C-S01	Library	Flush180	25-OCT-16	1.000	ppb
51586	51586-1-106C-S01	Library	Flush180	25-OCT-16	1.000	ppb
51586	51586-1-106C-S01	Library	Flush180	25-OCT-16	1.100	ppb
51586	51586-1-106C-S01	Library	Initial	25-OCT-16	1.500	ppb
51586	51586-1-MOF-S01	Main Office Kitchenette 101C	Flush180	25-OCT-16	1.100	ppb
51586	51586-1-MOF-S01	Main Office Kitchenette 101C	Flush180	25-OCT-16	1.200	ppb
51586	51586-1-MOF-S01	Main Office Kitchenette 101C	Flush180	25-OCT-16	1.000	ppb
51586	51586-1-MOF-S01	Main Office Kitchenette 101C	Flush180	25-OCT-16	4.300	ppb
51586	51586-1-MOF-S01	Main Office Kitchenette 101C	Initial	25-OCT-16	0.910	ppb
51586	51586-3-W-HAL-F03	North End of Hall Left Fountain by 340	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F03	North End of Hall Left Fountain by 340	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F03	North End of Hall Left Fountain by 340	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F03	North End of Hall Left Fountain by 340	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F03	North End of Hall Left Fountain by 340	Initial	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F04	North End of Hall Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-	North End of Hall Right Fountain	Flush180	21-MAY-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04					
51586	51586-3-W-HAL-F04	North End of Hall Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F04	North End of Hall Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F04	North End of Hall Right Fountain	Initial	21-MAY-19	1.180	ug/L
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Initial	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F01	Outside Kitchen Left Fountain	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	21-MAY-19	1.390	ug/L
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Initial	25-OCT-16	0.210	ppb
51586	51586-2-E-HAL-F02	Outside Kitchen Right Fountain	Initial	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	25-OCT-16	0.260	ppb
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	25-OCT-16	0.250	ppb
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	25-OCT-16	0.350	ppb
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	25-OCT-16	0.600	ppb
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Initial	25-OCT-16	0.820	ppb
51586	51586-1-W-HAL-F03	Outside RM 161 Left Fountain	Initial	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	25-OCT-16	0.310	ppb
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	25-OCT-16	0.320	ppb
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	25-OCT-16	0.300	ppb
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	25-OCT-16	0.520	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Initial	25-OCT-16	0.720	ppb
51586	51586-1-W-HAL-F04	Outside RM 161 Right Fountain	Initial	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	25-OCT-16	1.700	ppb
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	25-OCT-16	2.000	ppb
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	25-OCT-16	1.500	ppb
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	25-OCT-16	1.600	ppb
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	21-MAY-19	5.540	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	21-MAY-19	4.650	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	21-MAY-19	2.780	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	21-MAY-19	1.720	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	29-APR-20	5.590	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	29-APR-20	3.080	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	29-APR-20	2.270	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Flush180	29-APR-20	1.980	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Initial	25-OCT-16	3.600	ppb
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Initial	21-MAY-19	3.660	ug/L
51586	51586-1-W-HAL-F01	Outside RM 165 Janitors Closet Left	Initial	29-APR-20	8.010	ug/L
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	25-OCT-16	4.000	ppb
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	25-OCT-16	11.000	ppb
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	25-OCT-16	3.300	ppb
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	25-OCT-16	6.100	ppb
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	21-MAY-19	1.260	ug/L
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Initial	25-OCT-16	8.000	ppb
51586	51586-1-W-HAL-F02	Outside RM 165 Right Fountain	Initial	21-MAY-19	2.870	ug/L
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	25-OCT-16	0.330	ppb
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	25-OCT-16	0.490	ppb
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	25-OCT-16	0.410	ppb
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	25-OCT-16	0.370	ppb
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	21-MAY-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F05	Outside RM 247	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F05	Outside RM 247	Initial	25-OCT-16	0.340	ppb
51586	51586-2-W-HAL-F05	Outside RM 247	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	25-OCT-16	1.300	ppb
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	25-OCT-16	1.300	ppb
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	25-OCT-16	1.400	ppb
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	25-OCT-16	1.200	ppb
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	21-MAY-19	2.400	ug/L
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	21-MAY-19	2.140	ug/L
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	21-MAY-19	2.400	ug/L
51586	51586-2-W-HAL-F04	Outside RM 248	Flush180	21-MAY-19	1.670	ug/L
51586	51586-2-W-HAL-F04	Outside RM 248	Initial	25-OCT-16	1.200	ppb
51586	51586-2-W-HAL-F04	Outside RM 248	Initial	21-MAY-19	2.250	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	21-MAY-19	2.190	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	21-MAY-19	12.100	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	21-MAY-19	1.560	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	21-MAY-19	1.220	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	29-APR-20	1.430	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	29-APR-20	1.000	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Flush180	29-APR-20	1.000	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Initial	21-MAY-19	1.980	ug/L
51586	51586-2-W-HAL-F03	Outside RM 248, left	Initial	29-APR-20	2.510	ug/L
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	25-OCT-16	0.860	ppb
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	25-OCT-16	0.950	ppb
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	25-OCT-16	0.790	ppb
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	25-OCT-16	0.800	ppb
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	21-MAY-19	2.150	ug/L
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	21-MAY-19	1.400	ug/L
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	21-MAY-19	1.110	ug/L
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Flush180	21-MAY-19	2.650	ug/L
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Initial	25-OCT-16	1.100	ppb
51586	51586-3-W-HAL-F02	Outside RM 344 Right Fountain	Initial	21-MAY-19	3.660	ug/L
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	25-OCT-16	0.830	ppb
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	25-OCT-16	0.880	ppb
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	25-OCT-16	1.100	ppb
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	25-OCT-16	0.940	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01					
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Initial	25-OCT-16	1.600	ppb
51586	51586-3-W-HAL-F01	Outside RM 345 Left Fountain	Initial	21-MAY-19	1.980	ug/L
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	25-OCT-16	0.400	ppb
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	25-OCT-16	0.310	ppb
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	25-OCT-16	0.290	ppb
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	25-OCT-16	0.300	ppb
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Initial	25-OCT-16	0.540	ppb
51586	51586-2-W-HAL-F06	Outside Rm 247 Right Fountain	Initial	21-MAY-19	1.000	ug/L
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	25-OCT-16	1.300	ppb
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	25-OCT-16	1.500	ppb
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	25-OCT-16	1.400	ppb
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	25-OCT-16	1.300	ppb
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-S-113-S01	RM 113 English Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-1-S-113-S01	RM 113 English Office	Initial	25-OCT-16	0.950	ppb
51586	51586-1-S-113-S01	RM 113 English Office	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	25-OCT-16	0.670	ppb
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	25-OCT-16	0.670	ppb
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	25-OCT-16	1.500	ppb
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	25-OCT-16	0.680	ppb
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-S-212-S01	RM 212 Sink	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-S-212-S01	RM 212 Sink	Initial	25-OCT-16	0.550	ppb
51586	51586-2-S-212-S01	RM 212 Sink	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-N-	RM 214 World Language Office	Flush180	25-OCT-16	2.800	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	214-S01					
51586	51586-2-N-214-S01	RM 214 World Language Office	Flush180	25-OCT-16	0.770	ppb
51586	51586-2-N-214-S01	RM 214 World Language Office	Flush180	25-OCT-16	0.700	ppb
51586	51586-2-N-214-S01	RM 214 World Language Office	Flush180	25-OCT-16	0.710	ppb
51586	51586-2-N-214-S01	RM 214 World Language Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-N-214-S01	RM 214 World Language Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-N-214-S01	RM 214 World Language Office	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-N-214-S01	RM 214 World Language Office	Initial	25-OCT-16	0.800	ppb
51586	51586-2-N-214-S01	RM 214 World Language Office	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	25-OCT-16	1.000	ppb
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	25-OCT-16	0.240	ppb
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	25-OCT-16	0.200	ppb
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Flush180	21-MAY-19	1.000	ug/L
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Initial	25-OCT-16	0.380	ppb
51586	51586-2-W-KIT-KS03	Right Sink on NE Wall	Initial	21-MAY-19	1.000	ug/L
51586	51586-2-224-S01	Rm 224	Flush180	25-OCT-16	1.200	ppb
51586	51586-2-224-S01	Rm 224	Flush180	25-OCT-16	1.300	ppb
51586	51586-2-224-S01	Rm 224	Flush180	25-OCT-16	1.300	ppb
51586	51586-2-224-S01	Rm 224	Flush180	25-OCT-16	1.200	ppb
51586	51586-2-224-S01	Rm 224	Initial	25-OCT-16	1.300	ppb
52369	52369-1-E-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-BF01		Initial	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	25-OCT-16	0.880	ppb
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	25-OCT-16	0.680	ppb
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	25-OCT-16	1.100	ppb
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Initial	25-OCT-16	1.900	ppb
52369	52369-1-W-HAL-F01	Outside Band Room Left Fountain	Initial	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Initial	25-OCT-16	0.370	ppb
52369	52369-1-W-HAL-F02	Outside Band Room Right Fountain	Initial	21-MAY-19	1.000	ug/L
52369	52369-2-HAL-F03	Outside Classroom 226 Left Fountain	Flush180	25-OCT-16	1.300	ppb
52369	52369-2-HAL-F03	Outside Classroom 226 Left Fountain	Flush180	25-OCT-16	0.620	ppb
52369	52369-2-HAL-F03	Outside Classroom 226 Left Fountain	Flush180	25-OCT-16	0.970	ppb
52369	52369-2-HAL-F03	Outside Classroom 226 Left Fountain	Flush180	25-OCT-16	0.390	ppb
52369	52369-2-HAL-F03	Outside Classroom 226 Left Fountain	Initial	25-OCT-16	1.100	ppb
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	25-OCT-16	0.160	ppb
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Initial	25-OCT-16	0.190	ppb
52369	52369-1-E-HAL-F03	Outside Little Theater Left Fountain	Initial	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	25-OCT-16	0.910	ppb
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	25-OCT-16	2.200	ppb
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	25-OCT-16	2.600	ppb
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	25-OCT-16	1.100	ppb
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Initial	25-OCT-16	11.000	ppb
52369	52369-1-E-HAL-F04	Outside Little Theater Right Fountain	Initial	21-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52369	52369-2-HAL-F04	Outside RM 226 Right Foun Outside RM 226 Right Foun	Flush180	25-OCT-16	1.200	ppb
52369	52369-2-HAL-F04	Outside RM 226 Right Foun Outside RM 226 Right Foun	Flush180	25-OCT-16	3.600	ppb
52369	52369-2-HAL-F04	Outside RM 226 Right Foun Outside RM 226 Right Foun	Flush180	25-OCT-16	1.200	ppb
52369	52369-2-HAL-F04	Outside RM 226 Right Foun Outside RM 226 Right Foun	Flush180	25-OCT-16	1.700	ppb
52369	52369-2-HAL-F04	Outside RM 226 Right Foun Outside RM 226 Right Foun	Initial	25-OCT-16	2.400	ppb
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	25-OCT-16	0.350	ppb
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	25-OCT-16	0.330	ppb
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	25-OCT-16	0.310	ppb
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	25-OCT-16	0.270	ppb
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Initial	25-OCT-16	0.610	ppb
52369	52369-2-W-HAL-F01	Outside Room 233 Art Room Left Fountain	Initial	21-MAY-19	1.560	ug/L
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	25-OCT-16	0.470	ppb
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	25-OCT-16	0.260	ppb
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	25-OCT-16	0.910	ppb
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	21-MAY-19	1.160	ug/L
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Initial	25-OCT-16	1.000	ppb
52369	52369-2-W-HAL-F02	Outside Room 233 Art Room Right Fountain	Initial	21-MAY-19	1.060	ug/L
52370	52370-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-BF01		Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-BF01		Initial	21-MAY-19	1.000	ug/L
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	0.260	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-2-E-	East Hall Left Fountain	Flush180	25-OCT-16	0.260	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01					
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	21-MAY-19	1.610	ug/L
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	21-MAY-19	1.290	ug/L
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Initial	25-OCT-16	0.510	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Initial	25-OCT-16	0.510	ppb
52370	52370-2-E-HAL-F01	East Hall Left Fountain	Initial	21-MAY-19	1.280	ug/L
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.710	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.610	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.410	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.570	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.410	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.710	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.570	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Flush180	25-OCT-16	0.610	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Initial	25-OCT-16	1.800	ppb
52370	52370-2-HAL-F02	East Hall Right Fountain	Initial	25-OCT-16	1.800	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.610	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.230	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.230	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.230	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.200	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.230	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.200	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	25-OCT-16	0.610	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	21-MAY-19	1.780	ug/L
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	21-MAY-19	2.690	ug/L
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Initial	25-OCT-16	0.610	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Initial	25-OCT-16	0.610	ppb
52370	52370-1-E-HAL-F01	East Hall outside Gym Left Fountain	Initial	21-MAY-19	2.020	ug/L
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.270	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.230	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.230	ppb
52370	52370-1-E-	East Hall outside Gym Right	Flush180	25-OCT-16	0.210	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Fountain				
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.270	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.210	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	21-MAY-19	1.220	ug/L
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Initial	25-OCT-16	0.600	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Initial	25-OCT-16	0.600	ppb
52370	52370-1-E-HAL-F02	East Hall outside Gym Right Fountain	Initial	21-MAY-19	1.810	ug/L
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	0.290	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	0.330	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	0.330	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	25-OCT-16	0.290	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	21-MAY-19	2.540	ug/L
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	21-MAY-19	2.090	ug/L
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	21-MAY-19	1.630	ug/L
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Flush180	21-MAY-19	1.580	ug/L
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Initial	25-OCT-16	0.170	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Initial	25-OCT-16	0.170	ppb
52370	52370-1-W-BL-F02	Men Locker Room Right Fountain	Initial	21-MAY-19	3.800	ug/L
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	0.190	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	0.250	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	0.190	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	25-OCT-16	1.000	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	21-MAY-19	2.630	ug/L
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	21-MAY-19	2.240	ug/L
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	21-MAY-19	1.480	ug/L
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Flush180	21-MAY-19	1.390	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Initial	25-OCT-16	0.300	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Initial	25-OCT-16	0.300	ppb
52370	52370-1-W-BL-F01	Mens Locker Room Left Fountain	Initial	21-MAY-19	3.780	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.100	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.700	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.400	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.100	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.800	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.800	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.700	ppb
52370	52370-1-E-101-F01	Pool	Flush180	25-OCT-16	3.400	ppb
52370	52370-1-E-101-F01	Pool	Flush180	21-MAY-19	5.110	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	21-MAY-19	6.090	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	21-MAY-19	4.990	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	21-MAY-19	5.320	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	29-APR-20	3.160	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	29-APR-20	3.410	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	29-APR-20	3.050	ug/L
52370	52370-1-E-101-F01	Pool	Flush180	29-APR-20	4.040	ug/L
52370	52370-1-E-101-F01	Pool	Initial	25-OCT-16	5.000	ppb
52370	52370-1-E-101-F01	Pool	Initial	25-OCT-16	5.000	ppb
52370	52370-1-E-101-F01	Pool	Initial	21-MAY-19	7.080	ug/L
52370	52370-1-E-101-F01	Pool	Initial	29-APR-20	3.620	ug/L
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.580	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.750	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.500	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.630	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.750	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.500	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.630	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	25-OCT-16	0.580	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Initial	25-OCT-16	0.990	ppb
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Initial	25-OCT-16	0.990	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52370	52370-2-W-HAL-F03	West Hall Left Fountain	Initial	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.300	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.270	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.270	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.300	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.350	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.300	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.300	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	25-OCT-16	0.350	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Initial	25-OCT-16	0.680	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Initial	25-OCT-16	0.680	ppb
52370	52370-1-W-HAL-F03	West Hall Left Fountain next to 185	Initial	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.640	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.750	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.700	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.840	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.750	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.700	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.840	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	25-OCT-16	0.640	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Initial	25-OCT-16	1.200	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Initial	25-OCT-16	1.200	ppb
52370	52370-1-W-HAL-F04	West Hall Right Fountain by185	Initial	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F04	West Hall Right Fountain. By 264	Flush180	21-MAY-19	1.340	ug/L
52370	52370-2-W-HAL-F04	West Hall Right Fountain. By 264	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F04	West Hall Right Fountain. By 264	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F04	West Hall Right Fountain. By 264	Flush180	21-MAY-19	1.000	ug/L
52370	52370-2-W-HAL-F04	West Hall Right Fountain. By 264	Initial	21-MAY-19	2.390	ug/L
52370	52370-1-E-185-F02	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	185-F02					
52370	52370-1-E-185-F02	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F02	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F02	Woman's Locker RM	Initial	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	1.800	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	1.800	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	1.300	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	0.950	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	1.400	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	1.400	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	1.300	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	25-OCT-16	0.950	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F01	Woman's Locker RM	Flush180	21-MAY-19	1.000	ug/L
52370	52370-1-E-185-F01	Woman's Locker RM	Initial	25-OCT-16	2.300	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Initial	25-OCT-16	2.300	ppb
52370	52370-1-E-185-F01	Woman's Locker RM	Initial	21-MAY-19	1.000	ug/L