



Sep 10, 2024

KERSHAW

6450 S LOWE AVE, Chicago IL 60621.

Dear **KERSHAW** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

KERSHAW

6450 S LOWE AVE, Chicago IL 60621.

Estimadas familias de **KERSHAW**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51379	51379-1-GYM-F01	Inside Gym	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-GYM-F01	Inside Gym	Flush180	26-APR-19	1.240	ug/L
51379	51379-1-GYM-F01	Inside Gym	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-GYM-F01	Inside Gym	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-GYM-F01	Inside Gym	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-GYM-F01	Inside Gym	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-GYM-F01	Inside Gym	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-GYM-F01	Inside Gym	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-GYM-F01	Inside Gym	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-GYM-F01	Inside Gym	Initial	26-APR-19	1.110	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Flush180	04-AUG-20	1.640	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Initial	26-APR-19	1.040	ug/L
51379	51379-1-S-HAL-F01	ACROSS FROM LUNCH ROOM LEFT	Initial	04-AUG-20	2.990	ug/L
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F04	Across from 103 Mens Bathroom right fixture	Initial	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	11-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-HAL-F03	Across from 103 left fixture, by Womens Bathroom	Initial	26-APR-19	1.000	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Flush180	26-APR-19	1.250	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Flush180	26-APR-19	1.010	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Flush180	26-APR-19	1.020	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Flush180	04-AUG-20	3.530	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Initial	26-APR-19	1.510	ug/L
51379	51379-2-E-Hal-F03	Across from 203	Initial	04-AUG-20	5.320	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	11-JUL-23	2.830	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	11-JUL-23	3.310	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	11-JUL-23	9.950	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	11-JUL-23	4.310	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	29-SEP-23	1.000	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	01-AUG-23	4.770	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	01-AUG-23	3.610	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	01-AUG-23	12.000	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	29-SEP-23	1.000	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	29-SEP-23	1.000	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	29-SEP-23	1.000	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Flush180	01-AUG-23	3.780	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Initial	11-JUL-23	2.500	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Initial	29-SEP-23	1.000	ug/L
51379	51379-2-E-HAL-RBF01	Across from 203, retrofit Bottle Filler	Initial	01-AUG-23	5.980	ug/L
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-E-HAL-F04	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	26-APR-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-S-HAL-F02	N Girls Bathroom	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-E-HAL-F04	N Girls Bathroom	Initial	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F02	N Girls Bathroom	Initial	26-APR-19	1.000	ug/L
51379	51379-1-S-HAL-F02	N Girls Bathroom	Initial	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-KIT-KS04	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-KIT-KS04	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-KIT-KS04	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-KIT-KS04	NW Kitchen	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS03	NW Kitchen	Initial	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	17-AUG-16	0.486	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	17-AUG-16	0.755	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	17-AUG-16	0.597	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	17-AUG-16	0.556	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	11-JUN-16	87.900	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	11-JUN-16	208.000	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	11-JUN-16	557.000	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	11-JUN-16	59.500	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Flush180	11-JUN-16	46.800	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Initial	17-AUG-16	0.865	ppb
51379	51379-1-W-KIT-KS01	NW Kitchen - Dishwash Sink	Initial	26-APR-19	1.000	ug/L
51379	51379-1-KIT-	NW Kitchen - Pot Filler	Flush180	11-JUN-16	9.550	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS05					
51379	51379-1-KIT-KS05	NW Kitchen - Pot Filler	Flush180	11-JUN-16	24.500	ppb
51379	51379-1-KIT-KS05	NW Kitchen - Pot Filler	Flush180	11-JUN-16	38.900	ppb
51379	51379-1-KIT-KS05	NW Kitchen - Pot Filler	Flush180	11-JUN-16	10.200	ppb
51379	51379-1-KIT-KS05	NW Kitchen - Pot Filler	Flush180	11-JUN-16	20.200	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	15-NOV-16	4.040	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	15-NOV-16	11.600	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	15-NOV-16	7.840	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	15-NOV-16	37.800	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-KIT-KS02	NW Kitchen center	Flush180	15-NOV-16	32.400	ppb
51379	51379-1-W-KIT-KS02	NW Kitchen center	Initial	26-APR-19	1.000	ug/L
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	15-NOV-16	3.610	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	15-NOV-16	1.150	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	15-NOV-16	1.950	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	15-NOV-16	0.847	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	15-NOV-16	1.000	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	26-APR-19	1.000	ug/L
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F02	S Fan Room	Initial	26-APR-19	2.490	ug/L
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	26-APR-19	1.230	ug/L
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	26-APR-19	1.150	ug/L
51379	51379-2-S-	S Fan Room 217	Flush180	26-APR-19	1.130	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01					
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	26-APR-19	1.040	ug/L
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	11-JUN-16	7.090	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	11-JUN-16	11.700	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	11-JUN-16	22.100	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	17-AUG-16	2.440	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	17-AUG-16	1.690	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	17-AUG-16	1.900	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	17-AUG-16	2.290	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	17-AUG-16	2.460	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Flush180	11-JUN-16	1.000	ppb
51379	51379-2-S-HAL-F01	S Fan Room 217	Initial	26-APR-19	2.130	ug/L
51379	51379-1-E-102-F01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-102-F01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-102-F01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-102-F01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-102-F01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-N-102-S01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-N-102-S01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-N-102-S01	S Room 102	Flush180	26-APR-19	1.550	ug/L
51379	51379-1-N-102-S01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-102-S01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-102-S01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-102-F01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-102-F01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-102-F01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-E-102-F01	S Room 102	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-102-S01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-N-102-S01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-N-102-S01	S Room 102	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-E-102-F01	S Room 102	Initial	26-APR-19	1.000	ug/L
51379	51379-1-N-102-S01	S Room 102	Initial	26-APR-19	1.690	ug/L
51379	51379-1-W-100-F01	SE Room 100	Flush180	11-JUN-16	5.120	ppb
51379	51379-1-W-100-F01	SE Room 100	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-100-F01	SE Room 100	Flush180	11-JUN-16	1.000	ppb
51379	51379-1-W-100-F01	SE Room 100	Flush180	11-JUN-16	8.440	ppb
51379	51379-1-W-100-F01	SE Room 100	Flush180	11-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51379	51379-1-W-100-F01	SE Room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-100-F01	SE Room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-100-F01	SE Room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-100-F01	SE Room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-W-100-F01	SE Room 100	Initial	26-APR-19	1.020	ug/L
51379	51379-1-N-100-S01	Sink room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-100-S01	Sink room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-100-S01	Sink room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-100-S01	Sink room 100	Flush180	26-APR-19	1.000	ug/L
51379	51379-1-N-100-S01	Sink room 100	Initial	26-APR-19	1.000	ug/L