



Sep 10, 2024

KINZIE

5625 S MOBILE AVE, Chicago IL 60638.

Dear **KINZIE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

KINZIE

5625 S MOBILE AVE, Chicago IL 60638.

Estimadas familias de **KINZIE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51299	51299-1-HAL-F03	Across Main Office RM 109 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F03	Across Main Office RM 109 Left Fountain	Flush180	07-OCT-16	0.170	ppb
51299	51299-1-HAL-F03	Across Main Office RM 109 Left Fountain	Flush180	07-OCT-16	0.160	ppb
51299	51299-1-HAL-F03	Across Main Office RM 109 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F03	Across Main Office RM 109 Left Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-1-HAL-RBF01	Across Main Office RM 109 Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-RBF01	Across Main Office RM 109 Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-RBF01	Across Main Office RM 109 Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-RBF01	Across Main Office RM 109 Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-RBF01	Across Main Office RM 109 Left Retrofit Bottle Filler	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F04	Across Main Office RM 109 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F04	Across Main Office RM 109 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F04	Across Main Office RM 109 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F04	Across Main Office RM 109 Right Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	07-OCT-16	0.340	ppb
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	07-OCT-16	0.370	ppb
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	07-OCT-16	0.420	ppb
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	07-OCT-16	0.340	ppb
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	19-AUG-20	1.530	ug/L
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Initial	07-OCT-16	0.350	ppb
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Initial	19-AUG-20	1.720	ug/L
51299	51299-1-HAL-F01	Across RM 101 Left Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F02	Across RM 101 Right Fountain	Flush180	07-OCT-16	0.300	ppb
51299	51299-1-HAL-F02	Across RM 101 Right Fountain	Flush180	07-OCT-16	0.320	ppb
51299	51299-1-HAL-F02	Across RM 101 Right Fountain	Flush180	07-OCT-16	0.280	ppb
51299	51299-1-HAL-F02	Across RM 101 Right Fountain	Flush180	07-OCT-16	0.310	ppb
51299	51299-1-HAL-F02	Across RM 101 Right Fountain	Initial	07-OCT-16	0.280	ppb
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-OCT-16	0.490	ppb
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-OCT-16	0.480	ppb
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-OCT-16	1.700	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-OCT-16	0.490	ppb
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-SEP-22	2.660	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-SEP-22	1.030	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-SEP-22	1.210	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	07-SEP-22	1.000	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	19-MAY-22	12.900	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Initial	07-OCT-16	3.000	ppb
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Initial	07-SEP-22	4.030	ug/L
51299	51299-B-HAL-F01	Basement Next to Playroom Left Fountain	Initial	19-MAY-22	2.820	ug/L
51299	51299-B-HAL-F02	Basement Next to Playroom Right Fountain	Flush180	07-OCT-16	2.100	ppb
51299	51299-B-HAL-F02	Basement Next to Playroom Right Fountain	Flush180	07-OCT-16	3.300	ppb
51299	51299-B-HAL-F02	Basement Next to Playroom Right Fountain	Flush180	07-OCT-16	5.200	ppb
51299	51299-B-HAL-F02	Basement Next to Playroom Right Fountain	Flush180	07-OCT-16	2.800	ppb
51299	51299-B-HAL-F02	Basement Next to Playroom Right Fountain	Initial	07-OCT-16	11.000	ppb
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	19-MAY-22	2.830	ug/L
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	19-MAY-22	2.630	ug/L
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	19-MAY-22	2.350	ug/L
51299	51299-1-KIT-KS02	Kitchen Center Sink	Flush180	19-MAY-22	1.650	ug/L
51299	51299-1-KIT-KS02	Kitchen Center Sink	Initial	07-OCT-16	0.600	ppb
51299	51299-1-KIT-KS02	Kitchen Center Sink	Initial	19-MAY-22	1.770	ug/L
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS01	Kitchen Left Sink	Flush180	19-MAY-22	1.350	ug/L
51299	51299-1-KIT-KS01	Kitchen Left Sink	Initial	07-OCT-16	0.890	ppb
51299	51299-1-KIT-KS01	Kitchen Left Sink	Initial	19-MAY-22	2.370	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-OCT-16	0.180	ppb
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	18-AUG-22	4.300	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	18-AUG-22	2.550	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	18-AUG-22	3.390	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	18-AUG-22	1.400	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-SEP-22	1.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-SEP-22	1.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-SEP-22	1.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	07-SEP-22	1.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	19-MAY-22	11.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	19-MAY-22	12.800	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	19-MAY-22	2.590	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Flush180	19-MAY-22	2.810	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Initial	07-OCT-16	1.400	ppb
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Initial	18-AUG-22	40.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Initial	07-SEP-22	1.000	ug/L
51299	51299-1-KIT-KS03	Kitchen Prep Table Sink	Initial	19-MAY-22	80.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	07-OCT-16	9.100	ppb
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Initial	07-OCT-16	0.440	ppb
51299	51299-1-KIT-KS04	Kitchen Right Sink	Initial	18-AUG-22	1.000	ug/L
51299	51299-1-KIT-KS04	Kitchen Right Sink	Initial	19-MAY-22	9.880	ug/L
51299	51299-2-HAL-F01	Near N. Stairwell Left Fountain	Flush180	07-OCT-16	3.500	ppb
51299	51299-2-HAL-F01	Near N. Stairwell Left Fountain	Flush180	07-OCT-16	3.800	ppb
51299	51299-2-HAL-	Near N. Stairwell Left Fountain	Flush180	07-OCT-16	3.300	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51299	51299-2-HAL-F0151299-2-HAL-F01	Near N. Stairwell Left Fountain	Flush180	07-OCT-16	2.500	ppb
51299	51299-2-HAL-F01	Near N. Stairwell Left Fountain	Initial	07-OCT-16	4.400	ppb
51299	51299-2-HAL-RBF01	Near N. Stairwell Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-RBF01	Near N. Stairwell Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-RBF01	Near N. Stairwell Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-RBF01	Near N. Stairwell Left Retrofit Bottle Filler	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-RBF01	Near N. Stairwell Left Retrofit Bottle Filler	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	07-OCT-16	0.190	ppb
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	07-OCT-16	0.390	ppb
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	07-OCT-16	0.400	ppb
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	18-AUG-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Flush180	19-MAY-22	23.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Initial	18-AUG-22	1.000	ug/L
51299	51299-1-HAL-F06	Next to RM 115 Center Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	07-OCT-16	0.540	ppb
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Initial	07-OCT-16	0.470	ppb
51299	51299-1-HAL-F05	Next to RM 115 Left Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	07-OCT-16	0.390	ppb
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	07-OCT-16	0.530	ppb
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	07-OCT-16	0.350	ppb
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	07-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F07	Next to RM 115 Right Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F05	Next to RM 207 Left Fountain	Flush180	07-OCT-16	1.600	ppb
51299	51299-2-HAL-F05	Next to RM 207 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F05	Next to RM 207 Left Fountain	Flush180	07-OCT-16	1.900	ppb
51299	51299-2-HAL-F05	Next to RM 207 Left Fountain	Flush180	07-OCT-16	2.600	ppb
51299	51299-2-HAL-F05	Next to RM 207 Left Fountain	Initial	07-OCT-16	3.900	ppb
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	07-OCT-16	0.570	ppb
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	07-OCT-16	0.570	ppb
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	07-OCT-16	0.470	ppb
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	07-OCT-16	0.540	ppb
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	19-MAY-22	1.450	ug/L
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	19-MAY-22	1.240	ug/L
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	19-MAY-22	1.640	ug/L
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Flush180	19-MAY-22	1.150	ug/L
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Initial	07-OCT-16	2.700	ppb
51299	51299-2-HAL-F06	Next to RM 207 Right Fountain	Initial	19-MAY-22	3.690	ug/L
51299	51299-2-HAL-F03	Next to RM 209 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F03	Next to RM 209 Left Fountain	Flush180	07-OCT-16	0.210	ppb
51299	51299-2-HAL-F03	Next to RM 209 Left Fountain	Flush180	07-OCT-16	0.180	ppb
51299	51299-2-HAL-F03	Next to RM 209 Left Fountain	Flush180	07-OCT-16	0.190	ppb
51299	51299-2-HAL-F03	Next to RM 209 Left Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F04	Next to RM 209 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F04	Next to RM 209 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F04	Next to RM 209 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F04	Next to RM 209 Right Fountain	Initial	07-OCT-16	0.170	ppb
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	07-OCT-16	0.220	ppb
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	19-AUG-20	2.070	ug/L
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-	Next to RM 219 Left Fountain	Flush180	19-MAY-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07					
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Initial	19-AUG-20	2.080	ug/L
51299	51299-2-HAL-F07	Next to RM 219 Left Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Initial	07-OCT-16	1.000	ppb
51299	51299-2-HAL-F08	Next to RM 219 Right Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	07-OCT-16	0.200	ppb
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	07-OCT-16	0.170	ppb
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Initial	07-OCT-16	0.160	ppb
51299	51299-1-HAL-F08	Next to RMS 123 and 125 Left Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Initial	07-OCT-16	0.190	ppb
51299	51299-1-HAL-F09	Next to RMS 123 and 125 Right Fountain	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	07-OCT-16	0.170	ppb
51299	51299-1-106-	Nurses Office RM 106	Flush180	07-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	07-OCT-16	0.470	ppb
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	07-OCT-16	0.610	ppb
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-106-S01	Nurses Office RM 106	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-106-S01	Nurses Office RM 106	Initial	07-OCT-16	0.490	ppb
51299	51299-1-106-S01	Nurses Office RM 106	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-118-S01	Room 118	Flush180	07-OCT-16	2.000	ppb
51299	51299-1-118-S01	Room 118	Flush180	07-OCT-16	0.340	ppb
51299	51299-1-118-S01	Room 118	Flush180	07-OCT-16	0.460	ppb
51299	51299-1-118-S01	Room 118	Flush180	07-OCT-16	0.840	ppb
51299	51299-1-118-S01	Room 118	Flush180	19-MAY-22	2.180	ug/L
51299	51299-1-118-S01	Room 118	Flush180	19-MAY-22	3.100	ug/L
51299	51299-1-118-S01	Room 118	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-118-S01	Room 118	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-118-S01	Room 118	Initial	07-OCT-16	2.900	ppb
51299	51299-1-118-S01	Room 118	Initial	19-MAY-22	1.560	ug/L
51299	51299-1-119-S01	Room 119	Flush180	07-OCT-16	0.920	ppb
51299	51299-1-119-S01	Room 119	Flush180	07-OCT-16	0.970	ppb
51299	51299-1-119-S01	Room 119	Flush180	07-OCT-16	0.240	ppb
51299	51299-1-119-S01	Room 119	Flush180	07-OCT-16	0.250	ppb
51299	51299-1-119-S01	Room 119	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-119-S01	Room 119	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-119-S01	Room 119	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-119-S01	Room 119	Initial	07-OCT-16	0.830	ppb
51299	51299-1-119-S01	Room 119	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-120-S01	Room 120	Flush180	07-OCT-16	0.230	ppb
51299	51299-1-120-S01	Room 120	Flush180	07-OCT-16	0.360	ppb
51299	51299-1-120-S01	Room 120	Flush180	07-OCT-16	0.440	ppb
51299	51299-1-120-S01	Room 120	Flush180	07-OCT-16	1.000	ppb
51299	51299-1-120-S01	Room 120	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-120-S01	Room 120	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-120-S01	Room 120	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-120-S01	Room 120	Flush180	19-MAY-22	1.000	ug/L
51299	51299-1-120-S01	Room 120	Initial	07-OCT-16	0.450	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51299	51299-1-120-S01	Room 120	Initial	19-MAY-22	1.000	ug/L
51299	51299-1-122-S01	Room 122	Flush180	07-OCT-16	1.100	ppb
51299	51299-1-122-S01	Room 122	Flush180	07-OCT-16	1.300	ppb
51299	51299-1-122-S01	Room 122	Flush180	07-OCT-16	0.630	ppb
51299	51299-1-122-S01	Room 122	Flush180	07-OCT-16	0.660	ppb
51299	51299-1-122-S01	Room 122	Flush180	19-MAY-22	2.540	ug/L
51299	51299-1-122-S01	Room 122	Flush180	19-MAY-22	1.690	ug/L
51299	51299-1-122-S01	Room 122	Flush180	19-MAY-22	1.340	ug/L
51299	51299-1-122-S01	Room 122	Flush180	19-MAY-22	1.060	ug/L
51299	51299-1-122-S01	Room 122	Initial	07-OCT-16	1.700	ppb
51299	51299-1-122-S01	Room 122	Initial	19-MAY-22	2.430	ug/L