



Sep 10, 2024

LAKE VIEW HS

4015 N ASHLAND AVE, Chicago IL 60613.

Dear **LAKE VIEW HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LAKE VIEW HS

4015 N ASHLAND AVE, Chicago IL 60613.

Estimadas familias de **LAKE VIEW HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51533	51533-1-HAL-BF02	BF (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	2.380	ug/L
51533	51533-1-HAL-BF02	BF (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	2.370	ug/L
51533	51533-1-HAL-BF02	BF (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	2.240	ug/L
51533	51533-1-HAL-BF02	BF (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	2.230	ug/L
51533	51533-1-HAL-BF02	BF (Right) S. Wall Next to Room 102	Initial	21-MAY-2024	2.200	ug/L
51533	51533-4-HAL-BF01	Bottle Filler (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-BF01	Bottle Filler (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-BF01	Bottle Filler (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-BF01	Bottle Filler (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-BF01	Bottle Filler (Left) Across from Rm. 426	Initial	06-APR-22	1.000	ug/L
51533	51533-2-HAL-BF01	Bottle Filler Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-BF01	Bottle Filler Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-BF01	Bottle Filler Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-BF01	Bottle Filler Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-BF01	Bottle Filler Across from Rm. 220	Initial	06-APR-22	1.000	ug/L
51533	51533-3-HAL-BF01	Bottle Filler Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-BF01	Bottle Filler Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-BF01	Bottle Filler Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-BF01	Bottle Filler Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-BF01	Bottle Filler Outside Rm. 320	Initial	06-APR-22	1.000	ug/L
51533	51533-1-HAL-BF01	Bottle Filler S. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-BF01	Bottle Filler S. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-BF01	Bottle Filler S. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-BF01	Bottle Filler S. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-BF01	Bottle Filler S. Wall Across from Rm. 124	Initial	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F03	Fountain (Left) Across from Rm. 220	Initial	06-APR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	19-OCT-16	1.000	ppb
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	19-OCT-16	1.000	ppb
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	19-OCT-16	1.000	ppb
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	19-OCT-16	1.000	ppb
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Flush180	06-APR-22	1.000	ug/L
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Initial	19-OCT-16	1.000	ppb
51533	51533-4-HAL-F01	Fountain (Left) Across from Rm. 426	Initial	06-APR-22	1.000	ug/L
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Initial	19-OCT-16	2.900	ppb
51533	51533-B-POL-F16	Fountain (Left) N. Wall Swimming Pool	Initial	06-APR-22	1.000	ug/L
51533	51533-B-HAL-F14	Fountain (Left) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F14	Fountain (Left) Next to Room 17	Flush180	19-OCT-16	2.200	ppb
51533	51533-B-HAL-F14	Fountain (Left) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F14	Fountain (Left) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F14	Fountain (Left) Next to Room 17	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F06	Fountain (Left) Outside Rm. 209	Initial	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F08	Fountain (Left) Outside Rm. 304	Flush180	19-OCT-16	6.600	ppb
51533	51533-3-HAL-F08	Fountain (Left) Outside Rm. 304	Flush180	19-OCT-16	4.500	ppb

Water Quality Assessment Lake View High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51533	51533-3-HAL-F08	Fountain (Left) Outside Rm. 304	Flush180	19-OCT-16	4.100	ppb
51533	51533-3-HAL-F08	Fountain (Left) Outside Rm. 304	Flush180	19-OCT-16	4.400	ppb
51533	51533-3-HAL-F08	Fountain (Left) Outside Rm. 304	Initial	19-OCT-16	5.100	ppb
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	06-APR-22	1.510	ug/L
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	06-APR-22	1.240	ug/L
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	06-APR-22	1.100	ug/L
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Flush180	06-APR-22	1.370	ug/L
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Initial	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F07	Fountain (Left) Outside Rm. 305	Initial	06-APR-22	1.300	ug/L
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	19-OCT-16	3.700	ppb
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	19-OCT-16	2.600	ppb
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	19-OCT-16	2.800	ppb
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Initial	19-OCT-16	2.700	ppb
51533	51533-3-HAL-F04	Fountain (Left) Outside Rm. 320	Initial	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F01	Fountain (Left) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F01	Fountain (Left) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F01	Fountain (Left) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F01	Fountain (Left) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F01	Fountain (Left) Outside Rm. 336	Initial	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F05	Fountain (Left) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F05	Fountain (Left) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F05	Fountain (Left) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F05	Fountain (Left) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F05	Fountain (Left) S. Wall Across from Rm. 120	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F04	Fountain (Right) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F04	Fountain (Right) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F04	Fountain (Right) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F04	Fountain (Right) Across from Rm. 220	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F04	Fountain (Right) Across from Rm. 220	Initial	19-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	220				
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Initial	19-OCT-16	1.000	ppb
51533	51533-B-POL-F15	Fountain (Right) N. Wall Swimming Pool	Initial	06-APR-22	1.000	ug/L
51533	51533-B-HAL-F13	Fountain (Right) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F13	Fountain (Right) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F13	Fountain (Right) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F13	Fountain (Right) Next to Room 17	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-HAL-F13	Fountain (Right) Next to Room 17	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F05	Fountain (Right) Outside Rm. 209	Initial	06-APR-22	1.580	ug/L
51533	51533-3-HAL-F09	Fountain (Right) Outside Rm. 304	Flush180	19-OCT-16	3.400	ppb
51533	51533-3-HAL-F09	Fountain (Right) Outside Rm. 304	Flush180	19-OCT-16	3.700	ppb
51533	51533-3-HAL-F09	Fountain (Right) Outside Rm. 304	Flush180	19-OCT-16	3.500	ppb
51533	51533-3-HAL-F09	Fountain (Right) Outside Rm. 304	Flush180	19-OCT-16	3.500	ppb
51533	51533-3-HAL-F09	Fountain (Right) Outside Rm. 304	Initial	19-OCT-16	3.300	ppb
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	19-OCT-16	2.300	ppb
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	06-APR-22	1.170	ug/L
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	06-APR-22	1.080	ug/L
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	06-APR-22	1.000	ug/L

Water Quality Assessment Lake View High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06					
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Flush180	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Initial	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F06	Fountain (Right) Outside Rm. 305	Initial	06-APR-22	1.000	ug/L
51533	51533-3-HAL-F05	Fountain (Right) Outside Rm. 320	Flush180	19-OCT-16	2.600	ppb
51533	51533-3-HAL-F05	Fountain (Right) Outside Rm. 320	Flush180	19-OCT-16	2.600	ppb
51533	51533-3-HAL-F05	Fountain (Right) Outside Rm. 320	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F05	Fountain (Right) Outside Rm. 320	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F05-51533-3-HAL-F05	Fountain (Right) Outside Rm. 320	Initial	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	06-APR-22	2.230	ug/L
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	06-APR-22	2.040	ug/L
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	06-APR-22	2.490	ug/L
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Flush180	06-APR-22	2.680	ug/L
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Initial	19-OCT-16	1.000	ppb
51533	51533-3-HAL-F02	Fountain (Right) Outside Rm. 336	Initial	06-APR-22	2.170	ug/L
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Initial	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F06	Fountain (Right) S. Wall Across from Rm. 120	Initial	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	1.000	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	1.000	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	1.000	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush	21-MAY-2024	1.000	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	19-OCT-16	3.600	ppb
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	19-OCT-16	2.100	ppb
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	19-OCT-16	2.500	ppb
51533	51533-1-HAL-	Fountain (Right) S. Wall Next to	Flush180	06-APR-22	4.590	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Room 102				
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	06-APR-22	3.230	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	06-APR-22	4.300	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	06-APR-22	3.850	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	29-APR-22	5.740	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	29-APR-22	5.490	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	29-APR-22	9.220	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Flush180	29-APR-22	2.220	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Initial	19-OCT-16	2.600	ppb
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Initial	06-APR-22	6.960	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Initial	29-APR-22	9.550	ug/L
51533	51533-1-HAL-F01	Fountain (Right) S. Wall Next to Room 102	Initial	21-MAY-2024	1.260	ug/L
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	19-OCT-16	1.000	ppb
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	19-OCT-16	2.300	ppb
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Flush180	06-APR-22	1.000	ug/L
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Initial	19-OCT-16	3.400	ppb
51533	51533-1-HAL-F08	Fountain E. Wall Across from Rm. 124	Initial	06-APR-22	1.720	ug/L
51533	51533-3-HAL-F03	Fountain Next to Rm. 329	Flush180	19-OCT-16	2.200	ppb
51533	51533-3-HAL-F03	Fountain Next to Rm. 329	Flush180	19-OCT-16	2.400	ppb
51533	51533-3-HAL-F03	Fountain Next to Rm. 329	Flush180	19-OCT-16	2.700	ppb
51533	51533-3-HAL-F03	Fountain Next to Rm. 329	Flush180	19-OCT-16	2.300	ppb
51533	51533-3-HAL-F03	Fountain Next to Rm. 329	Initial	19-OCT-16	3.600	ppb
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	19-OCT-16	2.700	ppb
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Flush180	06-APR-22	1.000	ug/L
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Initial	19-OCT-16	1.000	ppb
51533	51533-2-HAL-F01	Fountain W. Wall Across from Rm. 229	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-	Kitchen Center Island Sink	Flush180	19-OCT-16	1.000	ppb

Water Quality Assessment Lake View High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS10					
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Flush180	19-OCT-16	2.400	ppb
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Flush180	19-OCT-16	2.100	ppb
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Initial	19-OCT-16	3.700	ppb
51533	51533-B-KIT-KS10	Kitchen Center Island Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	19-OCT-16	2.200	ppb
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	06-APR-22	1.870	ug/L
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Initial	19-OCT-16	3.500	ppb
51533	51533-B-KIT-KS01	Kitchen E. Wall Left Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Initial	19-OCT-16	2.400	ppb
51533	51533-B-KIT-KS02	Kitchen E. Wall Right Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	19-OCT-16	2.900	ppb
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	19-OCT-16	2.700	ppb
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Initial	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS08	Kitchen N. Wall Center Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Initial	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS07	Kitchen N. Wall Left Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Initial	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS09	Kitchen N. Wall Right Sink	Initial	06-APR-22	1.760	ug/L
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	19-OCT-16	2.100	ppb
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Initial	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS05	Kitchen S. Wall Center Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	19-OCT-16	2.200	ppb
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	06-APR-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Initial	19-OCT-16	2.300	ppb
51533	51533-B-KIT-KS03	Kitchen S. Wall Kettle	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Initial	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS04	Kitchen S. Wall Left Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Flush180	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Initial	19-OCT-16	1.000	ppb
51533	51533-B-KIT-KS06	Kitchen S. Wall Right Sink	Initial	06-APR-22	1.000	ug/L
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	27.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	27.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	11.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	5.200	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	11.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	27.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	27.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	01-DEC-16	5.200	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	19-OCT-16	18.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	19-OCT-16	6.300	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	19-OCT-16	3.300	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	19-OCT-16	11.000	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	06-APR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F11					
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Flush180	06-APR-22	1.000	ug/L
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Initial	01-DEC-16	6.100	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Initial	19-OCT-16	5.500	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Initial	01-DEC-16	6.100	ppb
51533	51533-B-CAF-F11	Lunch Rm. S. Wall Fountain (Left)	Initial	06-APR-22	1.000	ug/L