



**Sep 10, 2024**

**LARA**

**4619 S WOLCOTT AVE, Chicago IL 60609.**

Dear **LARA** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**LARA**

**4619 S WOLCOTT AVE, Chicago IL 60609.**

Estimadas familias de **LARA**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	23-SEP-16	5.160	ppb
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	23-SEP-16	4.670	ppb
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	23-SEP-16	5.140	ppb
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	23-SEP-16	4.920	ppb
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Initial	23-SEP-16	1.760	ppb
51327	51327-2-HAL-F03	Main- Across From Library, Left Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	23-SEP-16	4.500	ppb
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	23-SEP-16	4.740	ppb
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	23-SEP-16	4.480	ppb
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	23-SEP-16	4.670	ppb
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Initial	23-SEP-16	4.000	ppb
51327	51327-2-HAL-F04	Main- Across From Library, Right Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F07	Main- Across From Offices, Left Fountain	Flush180	23-SEP-16	0.235	ppb
51327	51327-1-HAL-F07	Main- Across From Offices, Left Fountain	Flush180	23-SEP-16	0.259	ppb
51327	51327-1-HAL-F07	Main- Across From Offices, Left Fountain	Flush180	23-SEP-16	0.196	ppb
51327	51327-1-HAL-F07	Main- Across From Offices, Left Fountain	Flush180	23-SEP-16	0.286	ppb
51327	51327-1-HAL-F07	Main- Across From Offices, Left Fountain	Initial	23-SEP-16	0.199	ppb
51327	51327-1-HAL-RBF01	Main- Across From Offices, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-RBF01	Main- Across From Offices, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-RBF01	Main- Across From Offices, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-RBF01	Main- Across From Offices, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-RBF01	Main- Across From Offices, Retrofitted bottle Filler (Left)	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	23-SEP-16	0.267	ppb
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	23-SEP-16	0.313	ppb
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	23-SEP-16	0.271	ppb
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	23-SEP-16	0.272	ppb
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	04-FEB-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Initial	23-SEP-16	0.317	ppb
51327	51327-1-HAL-F08	Main- Across From Offices, Right Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-F01	Main- Across From Room 206, Left Fountain	Flush180	23-SEP-16	0.764	ppb
51327	51327-2-HAL-F01	Main- Across From Room 206, Left Fountain	Flush180	23-SEP-16	0.311	ppb
51327	51327-2-HAL-F01	Main- Across From Room 206, Left Fountain	Flush180	23-SEP-16	0.547	ppb
51327	51327-2-HAL-F01	Main- Across From Room 206, Left Fountain	Flush180	23-SEP-16	2.390	ppb
51327	51327-2-HAL-F01	Main- Across From Room 206, Left Fountain	Initial	23-SEP-16	0.213	ppb
51327	51327-2-HAL-RBF01	Main- Across From Room 206, retrofitted bottle filler (right)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-RBF01	Main- Across From Room 206, retrofitted bottle filler (right)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-RBF01	Main- Across From Room 206, retrofitted bottle filler (right)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-RBF01	Main- Across From Room 206, retrofitted bottle filler (right)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-2-HAL-RBF01	Main- Across From Room 206, retrofitted bottle filler (right)	Initial	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	23-SEP-16	1.280	ppb
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	23-SEP-16	2.670	ppb
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	23-SEP-16	2.970	ppb
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	23-SEP-16	2.100	ppb
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Initial	23-SEP-16	0.774	ppb
51327	51327-3-HAL-F03	Main- Across From Room 300, Left Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	23-SEP-16	1.700	ppb
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	23-SEP-16	6.340	ppb
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	23-SEP-16	1.140	ppb
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	23-SEP-16	2.130	ppb
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Initial	23-SEP-16	0.333	ppb
51327	51327-3-HAL-F04	Main- Across From Room 300, Right Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Flush180	23-SEP-16	0.188	ppb
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Flush180	23-SEP-16	0.210	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Flush180	23-SEP-16	0.194	ppb
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Flush180	23-SEP-16	0.229	ppb
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Flush180	04-AUG-20	1.000	ug/L
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Initial	23-SEP-16	0.160	ppb
51327	51327-3-HAL-F01	Main- Across From Room 306, Left Fountain	Initial	04-AUG-20	1.000	ug/L
51327	51327-3-HAL-RBF01	Main- Across From Room 306, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-RBF01	Main- Across From Room 306, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-RBF01	Main- Across From Room 306, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-RBF01	Main- Across From Room 306, Retrofitted bottle Filler (Left)	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-RBF01	Main- Across From Room 306, Retrofitted bottle Filler (Left)	Initial	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	23-SEP-16	0.932	ppb
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	23-SEP-16	0.424	ppb
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	23-SEP-16	1.390	ppb
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	23-SEP-16	1.810	ppb
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Initial	23-SEP-16	0.214	ppb
51327	51327-3-HAL-F02	Main- Across From Room 306, Right Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F05	Main- Gym, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F05	Main- Gym, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F05	Main- Gym, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F05	Main- Gym, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F05	Main- Gym, Left Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	23-SEP-16	0.272	ppb
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	23-SEP-16	0.207	ppb
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	23-SEP-16	0.309	ppb
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	23-SEP-16	0.203	ppb
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	04-AUG-20	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Initial	23-SEP-16	0.269	ppb
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Initial	04-AUG-20	1.000	ug/L
51327	51327-1-GYM-F06	Main- Gym, Right Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-102-	Main- Inside Room 102, East Wall	Flush180	23-SEP-16	4.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S09	Sink				
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	23-SEP-16	4.360	ppb
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	23-SEP-16	4.040	ppb
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	23-SEP-16	4.070	ppb
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Initial	23-SEP-16	3.310	ppb
51327	51327-1-102-S09	Main- Inside Room 102, East Wall Sink	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-102-F01	Main- Inside Room 102, East Wall fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-F01	Main- Inside Room 102, East Wall fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-F01	Main- Inside Room 102, East Wall fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-F01	Main- Inside Room 102, East Wall fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-F01	Main- Inside Room 102, East Wall fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	23-SEP-16	1.040	ppb
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	23-SEP-16	0.810	ppb
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	23-SEP-16	0.983	ppb
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	23-SEP-16	0.868	ppb
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Initial	23-SEP-16	1.170	ppb
51327	51327-1-102-S10	Main- Inside Room 102, North Wall Sink	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	23-SEP-16	4.900	ppb
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	23-SEP-16	1.840	ppb
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	23-SEP-16	1.410	ppb
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	23-SEP-16	4.970	ppb
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	04-FEB-22	1.580	ug/L
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Flush180	04-FEB-22	1.340	ug/L
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Initial	23-SEP-16	8.460	ppb
51327	51327-1-103-S11	Main- Inside Room 103, East Wall Sink	Initial	04-FEB-22	3.850	ug/L
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	23-SEP-16	3.650	ppb
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	23-SEP-16	1.620	ppb
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	23-SEP-16	3.410	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S12	Wall Sink				
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	23-SEP-16	3.810	ppb
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Initial	23-SEP-16	2.170	ppb
51327	51327-1-103-S12	Main- Inside Room 103, South Wall Sink	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	23-SEP-16	0.460	ppb
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	23-SEP-16	3.380	ppb
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	23-SEP-16	1.510	ppb
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	23-SEP-16	0.507	ppb
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Initial	23-SEP-16	3.820	ppb
51327	51327-1-106-S15	Main- Inside Room 106, South Wall, Left Sink	Initial	03-MAR-22	1.360	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	23-SEP-16	0.425	ppb
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	23-SEP-16	0.903	ppb
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	23-SEP-16	0.653	ppb
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	23-SEP-16	0.410	ppb
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	03-MAR-22	4.860	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	03-MAR-22	13.500	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	03-MAR-22	2.710	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	03-MAR-22	1.530	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	04-FEB-22	36.800	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	04-FEB-22	33.200	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	04-FEB-22	22.200	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	04-FEB-22	61.400	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	25-MAR-22	1.000	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	25-MAR-22	1.000	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	25-MAR-22	1.000	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Flush180	25-MAR-22	1.000	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Initial	23-SEP-16	1.580	ppb
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Initial	03-MAR-22	4.600	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Initial	04-FEB-22	1900.000	ug/L
51327	51327-1-108-S18	Main- Inside Room 108, Left Sink	Initial	25-MAR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	23-SEP-16	1.180	ppb
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	23-SEP-16	1.200	ppb
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	23-SEP-16	0.580	ppb
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	23-SEP-16	0.266	ppb
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	04-FEB-22	2.120	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	04-FEB-22	2.260	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	04-FEB-22	2.870	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	04-FEB-22	3.990	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Flush180	03-MAR-22	1.000	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Initial	23-SEP-16	2.920	ppb
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Initial	04-FEB-22	5.650	ug/L
51327	51327-1-108-S17	Main- Inside Room 108, Right Sink	Initial	03-MAR-22	4.450	ug/L
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	23-SEP-16	0.960	ppb
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	23-SEP-16	0.819	ppb
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	23-SEP-16	0.828	ppb
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	23-SEP-16	0.732	ppb
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Initial	23-SEP-16	1.230	ppb
51327	51327-1-KIT-KS02	Main- Kitchen, Center Prep Sink	Initial	04-FEB-22	1.060	ug/L
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	23-SEP-16	0.830	ppb
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	23-SEP-16	0.807	ppb
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	23-SEP-16	0.515	ppb
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	23-SEP-16	0.949	ppb
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Initial	23-SEP-16	1.870	ppb
51327	51327-1-KIT-KS01	Main- Kitchen, East Wall Sink	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	23-SEP-16	0.985	ppb
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	23-SEP-16	0.809	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	23-SEP-16	2.370	ppb
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	23-SEP-16	0.934	ppb
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Initial	23-SEP-16	6.810	ppb
51327	51327-1-KIT-KS03	Main- Kitchen, West Wall, Left Sink	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	23-SEP-16	0.725	ppb
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	23-SEP-16	0.724	ppb
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	23-SEP-16	0.639	ppb
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	23-SEP-16	0.798	ppb
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	04-FEB-22	1.340	ug/L
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Initial	23-SEP-16	0.609	ppb
51327	51327-1-KIT-KS04	Main- Kitchen, West Wall, Right Sink	Initial	04-FEB-22	4.570	ug/L
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	23-SEP-16	0.234	ppb
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	23-SEP-16	0.357	ppb
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	23-SEP-16	0.346	ppb
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	23-SEP-16	0.266	ppb
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Initial	23-SEP-16	0.321	ppb
51327	51327-1-HAL-F13	Main- Outside Room 106, Left Fountain	Initial	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	23-SEP-16	0.533	ppb
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	23-SEP-16	0.430	ppb
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	23-SEP-16	0.425	ppb
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	23-SEP-16	0.576	ppb
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Flush180	04-FEB-22	1.000	ug/L
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Initial	23-SEP-16	0.500	ppb
51327	51327-1-HAL-F14	Main- Outside Room 106, Right Fountain	Initial	04-FEB-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F14	Fountain				