



Sep 10, 2024

LASALLE

1734 N ORLEANS ST, Chicago IL 60614.

Dear **LASALLE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LASALLE

1734 N ORLEANS ST, Chicago IL 60614.

Estimadas familias de **LASALLE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52615	52615-1-EXT-F02	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F02	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F02	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F02	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F03	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F03	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F03	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F03	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F02	1st Floor, Exterior	Initial	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F03	1st Floor, Exterior	Initial	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F01	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F01	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F01	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F01	1st Floor, Exterior	Flush180	27-SEP-19	1.000	ug/L
52615	52615-1-EXT-F01	1st Floor, Exterior	Initial	27-SEP-19	1.000	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Flush180	25-AUG-20	3.510	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F01	Main- 2nd Floor Outside Restrooms, North Fountain	Initial	25-AUG-20	1.460	ug/L
52615	52615-2-W-HAL-F02	Main- 2nd Floor Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F02	Main- 2nd Floor Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F02	Main- 2nd Floor Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F02	Main- 2nd Floor Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-2-W-HAL-F02	Main- 2nd Floor Outside Restrooms, South Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-MAR-19	2.240	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-MAR-19	2.490	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-MAR-19	3.980	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-MAR-19	4.260	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-APR-20	33.700	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-APR-20	9.140	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-APR-20	23.700	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	14-MAY-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	14-MAY-20	1.000	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	14-MAY-20	1.120	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	14-MAY-20	1.000	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Flush180	21-APR-20	3.590	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Initial	21-MAR-19	6.870	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Initial	21-APR-20	21.700	ug/L
52615	52615-1-E-100-S01	Main- Inside Room 100, Sink	Initial	14-MAY-20	3.060	ug/L
52615	52615-1-102-F11	Main- Inside Room 102, Fountain	Flush180	21-SEP-16	3.000	ppb
52615	52615-1-102-F11	Main- Inside Room 102, Fountain	Flush180	21-SEP-16	2.700	ppb
52615	52615-1-102-F11	Main- Inside Room 102, Fountain	Flush180	21-SEP-16	2.200	ppb
52615	52615-1-102-F11	Main- Inside Room 102, Fountain	Flush180	21-SEP-16	2.100	ppb
52615	52615-1-102-F11	Main- Inside Room 102, Fountain	Initial	21-SEP-16	8.800	ppb
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-MAR-19	11.500	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-MAR-19	5.420	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-MAR-19	5.630	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-MAR-19	6.360	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	14-MAY-20	1.610	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	14-MAY-20	1.410	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	14-MAY-20	1.000	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-APR-20	6.350	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-APR-20	3.820	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-APR-20	6.060	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	21-APR-20	9.560	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Flush180	14-MAY-20	1.000	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Initial	21-MAR-19	4.220	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Initial	14-MAY-20	4.450	ug/L
52615	52615-1-E-102-S01	Main- Inside Room 102, Sink	Initial	21-APR-20	7.750	ug/L
52615	52615-1-E-KIT-KS02	Main- Kitchen, Center Sink	Flush180	21-MAR-19	1.180	ug/L
52615	52615-1-E-KIT-KS02	Main- Kitchen, Center Sink	Flush180	21-MAR-19	1.030	ug/L
52615	52615-1-E-KIT-KS02	Main- Kitchen, Center Sink	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-E-KIT-KS02	Main- Kitchen, Center Sink	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-E-KIT-KS02	Main- Kitchen, Center Sink	Initial	21-MAR-19	1.080	ug/L
52615	52615-1-E-KIT-KS01	Main- Kitchen, North Sink	Flush180	21-MAR-19	2.140	ug/L
52615	52615-1-E-KIT-KS01	Main- Kitchen, North Sink	Flush180	21-MAR-19	2.220	ug/L
52615	52615-1-E-KIT-KS01	Main- Kitchen, North Sink	Flush180	21-MAR-19	2.200	ug/L
52615	52615-1-E-KIT-KS01	Main- Kitchen, North Sink	Flush180	21-MAR-19	1.720	ug/L
52615	52615-1-E-KIT-KS01	Main- Kitchen, North Sink	Initial	21-MAR-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52615	52615-1-E-KIT-KS03	Main- Kitchen, South Sink	Flush180	21-MAR-19	1.850	ug/L
52615	52615-1-E-KIT-KS03	Main- Kitchen, South Sink	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-E-KIT-KS03	Main- Kitchen, South Sink	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-E-KIT-KS03	Main- Kitchen, South Sink	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-E-KIT-KS03	Main- Kitchen, South Sink	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Flush180	25-AUG-20	1.970	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F01	Main- Outside Girls Toilets, East Fountain	Initial	25-AUG-20	1.000	ug/L
52615	52615-1-S-HAL-F02	Main- Outside Girls Toilets, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F02	Main- Outside Girls Toilets, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F02	Main- Outside Girls Toilets, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F02	Main- Outside Girls Toilets, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-S-HAL-F02	Main- Outside Girls Toilets, West Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F03	Main- Outside Lunchroom, East Fountain	Flush180	21-MAR-19	1.340	ug/L
52615	52615-1-N-HAL-F03	Main- Outside Lunchroom, East Fountain	Flush180	21-MAR-19	1.040	ug/L
52615	52615-1-N-HAL-F03	Main- Outside Lunchroom, East Fountain	Flush180	21-MAR-19	1.090	ug/L
52615	52615-1-N-HAL-F03	Main- Outside Lunchroom, East Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F03	Main- Outside Lunchroom, East Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F04	Main- Outside Lunchroom, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F04	Main- Outside Lunchroom, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F04	Main- Outside Lunchroom, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F04	Main- Outside Lunchroom, West Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F04	Main- Outside Lunchroom, West Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F05	Main- Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F05	Main- Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F05	Main- Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F05	Main- Outside Restrooms, North Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F05	Main- Outside Restrooms, North Fountain	Initial	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F06	Main- Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F06	Main- Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F06	Main- Outside Restrooms, South Fountain	Flush180	21-MAR-19	1.000	ug/L
52615	52615-1-N-HAL-F06	Main- Outside Restrooms, South Fountain	Initial	21-MAR-19	1.000	ug/L

