



**Sep 10, 2024**

**LAWNDALE**

**3500 W DOUGLAS BLVD, Chicago IL 60623.**

Dear **LAWNDALE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**LAWNDALE**

**3500 W DOUGLAS BLVD, Chicago IL 60623.**

Estimadas familias de **LAWNDALE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51209	51209-4-HAL-F01	Fourth floor fountain	Flush180	05-AUG-20	1.460	ug/L
51209	51209-4-HAL-F01	Fourth floor fountain	Flush180	10-MAY-22	4.500	ug/L
51209	51209-4-HAL-F01	Fourth floor fountain	Flush180	10-MAY-22	4.260	ug/L
51209	51209-4-HAL-F01	Fourth floor fountain	Flush180	10-MAY-22	4.350	ug/L
51209	51209-4-HAL-F01	Fourth floor fountain	Flush180	10-MAY-22	3.470	ug/L
51209	51209-4-HAL-F01	Fourth floor fountain	Initial	05-AUG-20	2.220	ug/L
51209	51209-4-HAL-F01	Fourth floor fountain	Initial	10-MAY-22	2.780	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	04-JUN-16	2.630	ppb
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	04-JUN-16	3.110	ppb
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	04-JUN-16	1.740	ppb
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	04-JUN-16	2.020	ppb
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	05-AUG-20	1.550	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.770	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.630	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Initial	04-JUN-16	2.680	ppb
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Initial	05-AUG-20	1.600	ug/L
51209	51209-1-HAL-F02	Main- 1st floor Outside Girls Restroom, Fountain	Initial	10-MAY-22	1.880	ug/L
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	04-JUN-16	0.529	ppb
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	04-JUN-16	0.747	ppb
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	04-JUN-16	0.436	ppb
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	04-JUN-16	0.363	ppb
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Initial	04-JUN-16	1.300	ppb
51209	51209-1-HAL-F01	Main- 1st floor Outside Gym, Fountain	Initial	10-MAY-22	1.000	ug/L
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	22-JUN-16	0.568	ppb
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	22-JUN-16	0.557	ppb
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	22-JUN-16	0.561	ppb
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	22-JUN-16	0.657	ppb
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	10-MAY-22	1.310	ug/L
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	10-MAY-22	1.320	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	10-MAY-22	1.320	ug/L
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Flush180	10-MAY-22	1.370	ug/L
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Initial	22-JUN-16	0.944	ppb
51209	51209-1-GYM-F01	Main- 1st floor, Inside Gym, Fountain	Initial	10-MAY-22	1.420	ug/L
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	04-JUN-16	2.100	ppb
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	04-JUN-16	3.120	ppb
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	04-JUN-16	1.440	ppb
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	04-JUN-16	4.230	ppb
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	10-MAY-22	3.080	ug/L
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	10-MAY-22	2.310	ug/L
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	10-MAY-22	1.940	ug/L
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Flush180	10-MAY-22	1.900	ug/L
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Initial	04-JUN-16	7.960	ppb
51209	51209-2-HAL-F04	Main- 2nd floor Outside Room 223, Right Fountain 2	Initial	10-MAY-22	2.220	ug/L
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	04-JUN-16	3.760	ppb
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	04-JUN-16	2.060	ppb
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	04-JUN-16	2.990	ppb
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	04-JUN-16	5.170	ppb
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	10-MAY-22	3.520	ug/L
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	10-MAY-22	4.350	ug/L
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	10-MAY-22	3.080	ug/L
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Flush180	10-MAY-22	2.050	ug/L
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Initial	04-JUN-16	5.130	ppb
51209	51209-2-HAL-F03	Main- 2nd floor Outside Room 223, left Fountain 1	Initial	10-MAY-22	2.970	ug/L
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	04-JUN-16	0.758	ppb
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	04-JUN-16	0.730	ppb
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	04-JUN-16	1.210	ppb
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	04-JUN-16	0.705	ppb
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	10-MAY-22	3.160	ug/L
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	10-MAY-22	1.700	ug/L
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	10-MAY-22	1.460	ug/L
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Flush180	10-MAY-22	1.260	ug/L
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Initial	04-JUN-16	1.960	ppb
51209	51209-2-HAL-F01	Main- 2nd floor Outside Room 225, Left Fountain	Initial	10-MAY-22	4.830	ug/L
51209	51209-2-HAL-F02	Main- 2nd floor Outside Room 225, Right Fountain	Flush180	10-MAY-22	1.600	ug/L
51209	51209-2-HAL-F02	Main- 2nd floor Outside Room 225, Right Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-2-HAL-F02	Main- 2nd floor Outside Room 225, Right Fountain	Flush180	10-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51209	51209-2-HAL-F02	Main- 2nd floor Outside Room 225, Right Fountain	Flush180	10-MAY-22	1.000	ug/L
51209	51209-2-HAL-F02	Main- 2nd floor Outside Room 225, Right Fountain	Initial	10-MAY-22	3.510	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	04-JUN-16	0.546	ppb
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	04-JUN-16	0.383	ppb
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	04-JUN-16	0.334	ppb
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	04-JUN-16	0.409	ppb
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	12-JUL-22	3.290	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	12-JUL-22	3.320	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	12-JUL-22	3.730	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	12-JUL-22	3.780	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-JUN-22	2.940	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-JUN-22	2.970	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-JUN-22	3.030	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-JUN-22	2.250	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-MAY-22	16.300	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-MAY-22	15.600	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-MAY-22	11.200	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Flush180	10-MAY-22	9.850	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Initial	04-JUN-16	0.745	ppb
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Initial	12-JUL-22	1.000	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Initial	10-JUN-22	10.500	ug/L
51209	51209-3-HAL-F04	Main- 3rd floor, Outside Room 323, Right Fountain	Initial	10-MAY-22	29.600	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-JUN-22	1.890	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-JUN-22	2.660	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-JUN-22	3.150	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-JUN-22	4.480	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-MAY-22	7.870	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-MAY-22	6.660	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-MAY-22	5.420	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Flush180	10-MAY-22	4.460	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Initial	10-JUN-22	2.430	ug/L
51209	51209-3-HAL-F03	Main- 3rd floor, Outside Room 323, left Fountain	Initial	10-MAY-22	10.200	ug/L
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	04-JUN-16	1.360	ppb
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	04-JUN-16	1.850	ppb
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	04-JUN-16	1.460	ppb
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	04-JUN-16	0.744	ppb
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	10-MAY-22	3.030	ug/L
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	10-MAY-22	2.850	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	325, Right Fountain				
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	10-MAY-22	2.620	ug/L
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Flush180	10-MAY-22	2.380	ug/L
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Initial	04-JUN-16	0.284	ppb
51209	51209-3-HAL-F02	Main- 3rd floor, Outside Room 325, Right Fountain	Initial	10-MAY-22	4.600	ug/L
54718	54718-1-112-F01	Annex - 1st floor, Inside Room 112, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-F01	Annex - 1st floor, Inside Room 112, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-F01	Annex - 1st floor, Inside Room 112, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-F01	Annex - 1st floor, Inside Room 112, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-F01	Annex - 1st floor, Inside Room 112, Fountain	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	04-JUN-16	1.150	ppb
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	04-JUN-16	0.928	ppb
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	04-JUN-16	0.919	ppb
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	04-JUN-16	0.763	ppb
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Initial	04-JUN-16	0.840	ppb
54718	54718-1-112-S03	Annex - 1st floor, Inside Room 112, Sink	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	04-JUN-16	0.580	ppb
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	04-JUN-16	0.570	ppb
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	04-JUN-16	0.546	ppb
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	04-JUN-16	0.549	ppb
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	10-MAY-22	1.320	ug/L
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Initial	04-JUN-16	0.584	ppb
54718	54718-1-117-F05	Annex - 1st floor, Inside Room 117, Fountain	Initial	10-MAY-22	2.820	ug/L
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	04-JUN-16	0.596	ppb
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	04-JUN-16	0.624	ppb
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	04-JUN-16	0.544	ppb
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	04-JUN-16	0.981	ppb
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Flush180	10-MAY-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S04	117, Sink				
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Initial	04-JUN-16	0.964	ppb
54718	54718-1-117-S04	Annex - 1st floor, Inside Room 117, Sink	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS02	Annex - 1st floor, Kitchen, CENTER Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS02	Annex - 1st floor, Kitchen, CENTER Sink	Flush180	10-MAY-22	1.090	ug/L
54718	54718-1-KIT-KS02	Annex - 1st floor, Kitchen, CENTER Sink	Flush180	10-MAY-22	1.150	ug/L
54718	54718-1-KIT-KS02	Annex - 1st floor, Kitchen, CENTER Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS02	Annex - 1st floor, Kitchen, CENTER Sink	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS01	Annex - 1st floor, Kitchen, LEFT Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS01	Annex - 1st floor, Kitchen, LEFT Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS01	Annex - 1st floor, Kitchen, LEFT Sink	Flush180	10-MAY-22	3.240	ug/L
54718	54718-1-KIT-KS01	Annex - 1st floor, Kitchen, LEFT Sink	Flush180	10-MAY-22	3.460	ug/L
54718	54718-1-KIT-KS01	Annex - 1st floor, Kitchen, LEFT Sink	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	04-JUN-16	1.140	ppb
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	04-JUN-16	0.977	ppb
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	04-JUN-16	1.160	ppb
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	04-JUN-16	1.110	ppb
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	10-MAY-22	1.310	ug/L
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	10-MAY-22	1.140	ug/L
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Initial	04-JUN-16	1.810	ppb
54718	54718-1-KIT-KS03	Annex - 1st floor, Kitchen, RIGHT Sink	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Flush180	04-JUN-16	0.646	ppb
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Flush180	04-JUN-16	0.718	ppb
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Flush180	04-JUN-16	0.839	ppb
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Flush180	04-JUN-16	0.804	ppb
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Flush180	05-AUG-20	1.000	ug/L
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Initial	04-JUN-16	0.688	ppb
54718	54718-1-HAL-F02	Annex - 1st floor, Outside Boys Restroom, Fountain	Initial	05-AUG-20	1.000	ug/L
54718	54718-1-HAL-RBF01	Annex - 1st floor, Outside Boys Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-RBF01	Annex - 1st floor, Outside Boys Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-RBF01	Annex - 1st floor, Outside Boys Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-RBF01	Annex - 1st floor, Outside Boys Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-RBF01	Annex - 1st floor, Outside Boys Restroom, Retrofit Bottle filler	Initial	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	04-JUN-16	1.210	ppb
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	04-JUN-16	1.050	ppb
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	04-JUN-16	1.580	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	04-JUN-16	1.490	ppb
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.330	ug/L
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.300	ug/L
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Flush180	10-MAY-22	1.000	ug/L
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Initial	04-JUN-16	1.540	ppb
54718	54718-1-HAL-F01	Annex - 1st floor, Outside Girls Restroom, Fountain	Initial	10-MAY-22	1.340	ug/L
54718	54718-2-HAL-RBF01	Annex - 2nd floor, Outside Girls Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-2-HAL-RBF01	Annex - 2nd floor, Outside Girls Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-2-HAL-RBF01	Annex - 2nd floor, Outside Girls Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-2-HAL-RBF01	Annex - 2nd floor, Outside Girls Restroom, Retrofit Bottle filler	Flush180	10-MAY-22	1.000	ug/L
54718	54718-2-HAL-RBF01	Annex - 2nd floor, Outside Girls Restroom, Retrofit Bottle filler	Initial	10-MAY-22	1.000	ug/L
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	04-JUN-16	1.130	ppb
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	04-JUN-16	0.685	ppb
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	04-JUN-16	1.250	ppb
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	04-JUN-16	0.886	ppb
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	10-MAY-22	1.800	ug/L
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	10-MAY-22	1.390	ug/L
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	10-MAY-22	1.430	ug/L
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Flush180	10-MAY-22	1.280	ug/L
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Initial	04-JUN-16	1.010	ppb
54718	54718-2-HAL-F01	Annex - 2nd floor, Outside boys Restroom, Fountain	Initial	10-MAY-22	1.950	ug/L
54718	54718-3-HAL-RBF01	Annex, Third Floor Retrofit Bottle filler by Boys Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-RBF01	Annex, Third Floor Retrofit Bottle filler by Boys Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-RBF01	Annex, Third Floor Retrofit Bottle filler by Boys Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-RBF01	Annex, Third Floor Retrofit Bottle filler by Boys Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-RBF01	Annex, Third Floor Retrofit Bottle filler by Boys Restroom	Initial	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Flush180	05-AUG-20	2.210	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Flush180	10-MAY-22	1.030	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Flush180	10-MAY-22	1.000	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Initial	05-AUG-20	1.860	ug/L
54718	54718-3-HAL-F01	Annex, Third Floor fountain by Girls Restroom	Initial	10-MAY-22	1.190	ug/L





**Water Quality Assessment**  
**Lawndale Elementary Community Academy**

Page 9 of 9  
Date Printed 9/10/2024

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
-------------	--------------	------------------	-----------	--------------	--------	-----