



Sep 10, 2024

LELAND

512 S LAVERGNE AVE, Chicago IL 60644.

Dear **LELAND** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LELAND

512 S LAVERGNE AVE, Chicago IL 60644.

Estimadas familias de **LELAND**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	08-SEP-23	4.400	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	08-SEP-23	1.340	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-1-111-F01	Inside room 111, Fountain	Initial	24-NOV-21	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-1-113-F01	Inside room 113, Fountain	Initial	24-NOV-21	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Flush180	24-NOV-21	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-1-115-F01	Inside room 115, Fountain	Initial	24-NOV-21	1.000	ug/L
51098	51098-1-115-S01	Inside room 115, Left Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S01	Inside room 115, Left Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S01	Inside room 115, Left Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S01	Inside room 115, Left Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S01	Inside room 115, Left Sink	Initial	08-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51098	51098-1-115-S02	Inside room 115, Right Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S02	Inside room 115, Right Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S02	Inside room 115, Right Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S02	Inside room 115, Right Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-115-S02	Inside room 115, Right Sink	Initial	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	08-JUN-16	0.215	ppb
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	08-JUN-16	0.235	ppb
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	08-JUN-16	0.279	ppb
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	08-JUN-16	0.220	ppb
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Flush180	19-AUG-20	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Initial	08-JUN-16	0.346	ppb
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F01	Main- Across From Office, North Fountain	Initial	19-AUG-20	1.000	ug/L
51098	51098-1-HAL-RBF01	Main- Across From Office, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-RBF01	Main- Across From Office, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-RBF01	Main- Across From Office, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-RBF01	Main- Across From Office, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-RBF01	Main- Across From Office, North Retrofit BF	Initial	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-JUN-16	1.000	ppb
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-JUN-16	1.000	ppb
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-JUN-16	1.000	ppb
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	08-JUN-16	1.000	ppb
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Initial	08-JUN-16	1.000	ppb
51098	51098-1-HAL-F02	Main- Across From Office,Center Fountain	Initial	27-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-JUN-16	0.144	ppb
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-JUN-16	0.140	ppb
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-JUN-16	0.145	ppb
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	08-JUN-16	0.160	ppb
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Initial	08-JUN-16	0.234	ppb
51098	51098-2-HAL-F02	Main- Across From Room 203, Center Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	08-JUN-16	0.169	ppb
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	08-JUN-16	0.348	ppb
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	08-JUN-16	0.143	ppb
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	08-JUN-16	0.137	ppb
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Initial	08-JUN-16	0.685	ppb
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F01	Main- Across From Room 203, North Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-RBF01	Main- Across From Room 203, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-RBF01	Main- Across From Room 203, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-RBF01	Main- Across From Room 203, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-RBF01	Main- Across From Room 203, North Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-RBF01	Main- Across From Room 203, North Retrofit BF	Initial	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-	Main- Across From Room 203,	Flush180	08-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	South Fountain				
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-JUN-16	0.128	ppb
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-JUN-16	0.123	ppb
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-JUN-16	0.132	ppb
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	08-JUN-16	0.134	ppb
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	27-SEP-19	2.450	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Initial	08-JUN-16	0.153	ppb
51098	51098-2-HAL-F03	Main- Across From Room 203, South Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-JUN-16	1.040	ppb
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-JUN-16	0.735	ppb
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-JUN-16	0.683	ppb
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	08-JUN-16	0.803	ppb
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Flush180	19-AUG-20	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Initial	08-JUN-16	0.625	ppb
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F02	Main- Across From Room 303, Center Fountain	Initial	19-AUG-20	1.000	ug/L
51098	51098-3-HAL-RBF01	Main- Across From Room 303, Left Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-RBF01	Main- Across From Room 303, Left Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-	Main- Across From Room 303,	Flush180	08-SEP-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01	Left Retrofit BF				
51098	51098-3-HAL-RBF01	Main- Across From Room 303, Left Retrofit BF	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-RBF01	Main- Across From Room 303, Left Retrofit BF	Initial	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-JUN-16	0.608	ppb
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-JUN-16	0.561	ppb
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	08-JUN-16	0.652	ppb
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Flush180	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Initial	08-SEP-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Initial	08-JUN-16	0.547	ppb
51098	51098-3-HAL-F03	Main- Across From Room 303, South Fountain	Initial	27-SEP-19	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 308, Fountain 1	Flush180	08-JUN-16	0.512	ppb
51098	51098-3-HAL-F03	Main- Across From Room 308, Fountain 1	Flush180	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 308, Fountain 1	Flush180	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 308, Fountain 1	Flush180	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F03	Main- Across From Room 308, Fountain 1	Initial	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F04	Main- Across From Room 308, Fountain 2	Flush180	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F04	Main- Across From Room 308, Fountain 2	Flush180	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F04	Main- Across From Room 308, Fountain 2	Flush180	08-FEB-23	1.000	ug/L
51098	51098-3-HAL-F04	Main- Across From Room 308, Fountain 2	Initial	08-FEB-23	1.000	ug/L
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	08-JUN-16	1.350	ppb
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	08-JUN-16	1.330	ppb
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	08-JUN-16	1.210	ppb
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	08-JUN-16	1.160	ppb
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Initial	08-JUN-16	1.470	ppb
51098	51098-B-KIT-KS02	Main- Kitchen, North Center Sink	Initial	27-SEP-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	08-JUN-16	3.080	ppb
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	08-JUN-16	4.980	ppb
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	08-JUN-16	8.050	ppb
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	08-JUN-16	5.050	ppb
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Initial	08-JUN-16	14.700	ppb
51098	51098-B-KIT-KS01	Main- Kitchen, North Sink	Initial	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS06	Main- Kitchen, Pot filler	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS06	Main- Kitchen, Pot filler	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS06	Main- Kitchen, Pot filler	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS06	Main- Kitchen, Pot filler	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS06	Main- Kitchen, Pot filler	Initial	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS05	Main- Kitchen, Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS05	Main- Kitchen, Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS05	Main- Kitchen, Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS05	Main- Kitchen, Sink	Flush180	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS05	Main- Kitchen, Sink	Initial	08-SEP-23	1.000	ug/L
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	08-JUN-16	1.400	ppb
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	08-JUN-16	1.280	ppb
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	08-JUN-16	1.260	ppb
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	08-JUN-16	1.310	ppb
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Initial	08-JUN-16	2.070	ppb
51098	51098-B-KIT-KS03	Main- Kitchen, South Center Sink	Initial	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	08-JUN-16	7.950	ppb
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	08-JUN-16	2.190	ppb
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	08-JUN-16	9.590	ppb
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	08-JUN-16	5.810	ppb
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	27-SEP-19	1.000	ug/L
51098	51098-B-KIT-KS04	Main- Kitchen, South Sink	Flush180	27-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	West Fountain				
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-JUN-16	0.153	ppb
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-JUN-16	0.122	ppb
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-JUN-16	0.134	ppb
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	08-JUN-16	0.184	ppb
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Flush180	19-AUG-20	1.000	ug/L
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Initial	08-SEP-23	1.660	ug/L
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Initial	08-JUN-16	0.359	ppb
52502	52502-2-HAL-F01	Annex- Across from Room 211, East Fountain	Initial	19-AUG-20	1.000	ug/L
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-JUN-16	0.257	ppb
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-JUN-16	0.162	ppb
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-JUN-16	0.173	ppb
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Flush180	08-JUN-16	0.201	ppb
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Initial	08-SEP-23	1.550	ug/L
52502	52502-2-HAL-F02	Annex- Across from Room 211, West Fountain	Initial	08-JUN-16	0.881	ppb
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-SEP-23	2.030	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-JUN-16	0.466	ppb
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-JUN-16	0.150	ppb
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-JUN-16	0.234	ppb
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	08-JUN-16	0.166	ppb
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	27-SEP-19	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	27-SEP-19	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	27-SEP-19	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Flush180	27-SEP-19	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Initial	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Initial	08-JUN-16	0.771	ppb
52502	52502-3-HAL-F01	Annex- Across from Room 311, East Fountain	Initial	27-SEP-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-SEP-23	1.000	ug/L
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-JUN-16	1.140	ppb
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-JUN-16	5.340	ppb
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-JUN-16	4.080	ppb
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Flush180	08-JUN-16	1.700	ppb
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Initial	08-SEP-23	1.070	ug/L
52502	52502-3-HAL-F02	Annex- Across from Room 311, West Fountain	Initial	08-JUN-16	7.270	ppb
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	08-JUN-16	0.429	ppb
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	08-JUN-16	0.264	ppb
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	08-JUN-16	0.468	ppb
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	08-JUN-16	0.277	ppb
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	27-SEP-19	2.120	ug/L
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	27-SEP-19	1.950	ug/L
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	27-SEP-19	1.720	ug/L
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Flush180	27-SEP-19	1.690	ug/L
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Initial	08-JUN-16	1.610	ppb
52502	52502-1-KIT-KS06	Annex- Kitchen Sink	Initial	27-SEP-19	2.900	ug/L
52502	52502-1-KIT-KS08	Annex- Kitchen, 3-basin Sink, Center	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS08	Annex- Kitchen, 3-basin Sink, Center	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS08	Annex- Kitchen, 3-basin Sink, Center	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS08	Annex- Kitchen, 3-basin Sink, Center	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS08	Annex- Kitchen, 3-basin Sink, Center	Initial	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS07	Annex- Kitchen, 3-basin Sink, Left	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS07	Annex- Kitchen, 3-basin Sink, Left	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS07	Annex- Kitchen, 3-basin Sink, Left	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS07	Annex- Kitchen, 3-basin Sink, Left	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS07	Annex- Kitchen, 3-basin Sink, Left	Initial	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS09	Annex- Kitchen, 3-basin Sink, Right	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS09	Annex- Kitchen, 3-basin Sink, Right	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS09	Annex- Kitchen, 3-basin Sink, Right	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-KIT-KS09	Annex- Kitchen, 3-basin Sink, Right	Initial	08-SEP-23	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-SEP-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-JUN-16	0.378	ppb
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-JUN-16	0.455	ppb
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-JUN-16	0.753	ppb
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	08-JUN-16	0.431	ppb
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Initial	08-SEP-23	1.000	ug/L
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Initial	08-JUN-16	0.542	ppb
52502	52502-1-111-S04	Annex- Room 111, Left Sink	Initial	27-SEP-19	1.000	ug/L
52502	52502-1-111-S05	Annex- Room 111, Right Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S05	Annex- Room 111, Right Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S05	Annex- Room 111, Right Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S05	Annex- Room 111, Right Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-111-S05	Annex- Room 111, Right Sink	Initial	08-SEP-23	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-SEP-23	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-JUN-16	0.213	ppb
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-JUN-16	0.166	ppb
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-JUN-16	0.162	ppb
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	08-JUN-16	0.173	ppb
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Flush180	27-SEP-19	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Initial	08-SEP-23	1.000	ug/L
52502	52502-1-113-S05	Annex- Room 113, Sink	Initial	08-JUN-16	1.040	ppb
52502	52502-1-113-S05	Annex- Room 113, Sink	Initial	27-SEP-19	1.000	ug/L