



Sep 10, 2024

LINDBLOM HS

6130 S WOLCOTT AVE, Chicago IL 60636.

Dear **LINDBLOM HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LINDBLOM HS

6130 S WOLCOTT AVE, Chicago IL 60636.

Estimadas familias de **LINDBLOM HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anejo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52292	52292-4-KIT-KS01	3-Basin Sink Left	Flush180	27-OCT-16	0.620	ppb
52292	52292-4-KIT-KS01	3-Basin Sink Left	Flush180	27-OCT-16	0.470	ppb
52292	52292-4-KIT-KS01	3-Basin Sink Left	Flush180	27-OCT-16	0.470	ppb
52292	52292-4-KIT-KS01	3-Basin Sink Left	Flush180	27-OCT-16	0.800	ppb
52292	52292-4-KIT-KS01	3-Basin Sink Left	Initial	27-OCT-16	4.400	ppb
52292	52292-4-KIT-KS02	3-Basin Sink Middle	Flush180	27-OCT-16	0.220	ppb
52292	52292-4-KIT-KS02	3-Basin Sink Middle	Flush180	27-OCT-16	0.170	ppb
52292	52292-4-KIT-KS02	3-Basin Sink Middle	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS02	3-Basin Sink Middle	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS02	3-Basin Sink Middle	Initial	27-OCT-16	1.700	ppb
52292	52292-4-KIT-KS03	3-Basin Sink Right	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS03	3-Basin Sink Right	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS03	3-Basin Sink Right	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS03	3-Basin Sink Right	Flush180	27-OCT-16	0.190	ppb
52292	52292-4-KIT-KS03	3-Basin Sink Right	Initial	27-OCT-16	0.170	ppb
52292	52292-2-HAL-F01	Across 224 RM Left Fountain	Flush180	27-OCT-16	2.800	ppb
52292	52292-2-HAL-F01	Across 224 RM Left Fountain	Flush180	27-OCT-16	3.600	ppb
52292	52292-2-HAL-F01	Across 224 RM Left Fountain	Flush180	27-OCT-16	3.200	ppb
52292	52292-2-HAL-F01	Across 224 RM Left Fountain	Flush180	27-OCT-16	2.500	ppb
52292	52292-2-HAL-F01	Across 224 RM Left Fountain	Initial	27-OCT-16	3.200	ppb
52292	52292-1-HAL-BF02	Across Main Office Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF02	Across Main Office Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF02	Across Main Office Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF02	Across Main Office Bottle Filler	Initial	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush180	27-OCT-16	0.260	ppb
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush180	27-OCT-16	0.270	ppb
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush180	27-OCT-16	0.280	ppb
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Flush180	27-OCT-16	0.250	ppb
52292	52292-2-HAL-F07	Across Main Office Left Fountain	Flush180	27-OCT-16	0.470	ppb
52292	52292-2-HAL-F07	Across Main Office Left Fountain	Flush180	27-OCT-16	0.500	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52292	52292-2-HAL-F07	Across Main Office Left Fountain	Flush180	27-OCT-16	0.420	ppb
52292	52292-2-HAL-F07	Across Main Office Left Fountain	Flush180	27-OCT-16	0.440	ppb
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Initial	27-OCT-16	0.180	ppb
52292	52292-2-HAL-F07	Across Main Office Left Fountain	Initial	27-OCT-16	0.420	ppb
52292	52292-1-HAL-F01	Across Main Office Left Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush	23-JAN-2024	1.050	ug/L
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush	23-JAN-2024	1.050	ug/L
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush180	27-OCT-16	0.200	ppb
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush180	27-OCT-16	0.190	ppb
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush180	27-OCT-16	0.180	ppb
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Flush180	27-OCT-16	0.180	ppb
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Initial	27-OCT-16	1.000	ppb
52292	52292-1-HAL-F02	Across Main Office Right Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F05	Across RM 100 Left Fountain	Flush180	27-OCT-16	1.900	ppb
52292	52292-1-HAL-F05	Across RM 100 Left Fountain	Flush180	27-OCT-16	2.400	ppb
52292	52292-1-HAL-F05	Across RM 100 Left Fountain	Flush180	27-OCT-16	3.100	ppb
52292	52292-1-HAL-F05	Across RM 100 Left Fountain	Flush180	27-OCT-16	2.800	ppb
52292	52292-1-HAL-F05	Across RM 100 Left Fountain	Initial	27-OCT-16	1.400	ppb
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush	23-JAN-2024	2.230	ug/L
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush	23-JAN-2024	3.400	ug/L
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush	23-JAN-2024	3.350	ug/L
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush	23-JAN-2024	3.620	ug/L
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush180	27-OCT-16	2.000	ppb
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush180	27-OCT-16	2.100	ppb
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush180	27-OCT-16	1.600	ppb
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Flush180	27-OCT-16	1.800	ppb
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Initial	27-OCT-16	3.500	ppb
52292	52292-1-HAL-F06	Across RM 100 Right Fountain	Initial	23-JAN-2024	1.480	ug/L
52292	52292-1-HAL-F03	Across RM 124 Left Fountain	Flush180	27-OCT-16	0.680	ppb
52292	52292-1-HAL-F03	Across RM 124 Left Fountain	Flush180	27-OCT-16	0.580	ppb
52292	52292-1-HAL-F03	Across RM 124 Left Fountain	Flush180	27-OCT-16	0.650	ppb
52292	52292-1-HAL-F03	Across RM 124 Left Fountain	Flush180	27-OCT-16	0.590	ppb
52292	52292-1-HAL-F03	Across RM 124 Left Fountain	Initial	27-OCT-16	0.270	ppb
52292	52292-1-HAL-F04	Across RM 124 Right Fountain	Flush180	27-OCT-16	0.480	ppb
52292	52292-1-HAL-F04	Across RM 124 Right Fountain	Flush180	27-OCT-16	0.590	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52292	52292-1-HAL-F04	Across RM 124 Right Fountain	Flush180	27-OCT-16	0.500	ppb
52292	52292-1-HAL-F04	Across RM 124 Right Fountain	Flush180	27-OCT-16	0.620	ppb
52292	52292-1-HAL-F04	Across RM 124 Right Fountain	Initial	27-OCT-16	0.310	ppb
52292	52292-2-HAL-F09	Across RM 213 Left Fountain	Flush180	27-OCT-16	0.560	ppb
52292	52292-2-HAL-F09	Across RM 213 Left Fountain	Flush180	27-OCT-16	0.540	ppb
52292	52292-2-HAL-F09	Across RM 213 Left Fountain	Flush180	27-OCT-16	0.600	ppb
52292	52292-2-HAL-F09	Across RM 213 Left Fountain	Flush180	27-OCT-16	0.560	ppb
52292	52292-2-HAL-F09	Across RM 213 Left Fountain	Initial	27-OCT-16	0.460	ppb
52292	52292-2-HAL-F10	Across RM 213 Right Fountain	Flush180	27-OCT-16	0.810	ppb
52292	52292-2-HAL-F10	Across RM 213 Right Fountain	Flush180	27-OCT-16	0.820	ppb
52292	52292-2-HAL-F10	Across RM 213 Right Fountain	Flush180	27-OCT-16	1.100	ppb
52292	52292-2-HAL-F10	Across RM 213 Right Fountain	Flush180	27-OCT-16	0.570	ppb
52292	52292-2-HAL-F10	Across RM 213 Right Fountain	Initial	27-OCT-16	0.460	ppb
52292	52292-3-HAL-F03	Across RM 319 Left Fountain	Flush180	27-OCT-16	0.330	ppb
52292	52292-3-HAL-F03	Across RM 319 Left Fountain	Flush180	27-OCT-16	0.400	ppb
52292	52292-3-HAL-F03	Across RM 319 Left Fountain	Flush180	27-OCT-16	0.380	ppb
52292	52292-3-HAL-F03	Across RM 319 Left Fountain	Flush180	27-OCT-16	0.390	ppb
52292	52292-3-HAL-F03	Across RM 319 Left Fountain	Initial	27-OCT-16	0.290	ppb
52292	52292-3-HAL-F04	Across RM 319 Right Fountain	Flush180	27-OCT-16	0.420	ppb
52292	52292-3-HAL-F04	Across RM 319 Right Fountain	Flush180	27-OCT-16	0.390	ppb
52292	52292-3-HAL-F04	Across RM 319 Right Fountain	Flush180	27-OCT-16	0.370	ppb
52292	52292-3-HAL-F04	Across RM 319 Right Fountain	Flush180	27-OCT-16	0.360	ppb
52292	52292-3-HAL-F04	Across RM 319 Right Fountain	Initial	27-OCT-16	0.370	ppb
52292	52292-3-HAL-F01	Across RM 324 Left Fountain	Flush180	27-OCT-16	0.490	ppb
52292	52292-3-HAL-F01	Across RM 324 Left Fountain	Flush180	27-OCT-16	0.470	ppb
52292	52292-3-HAL-F01	Across RM 324 Left Fountain	Flush180	27-OCT-16	0.400	ppb
52292	52292-3-HAL-F01	Across RM 324 Left Fountain	Flush180	27-OCT-16	0.380	ppb
52292	52292-3-HAL-F01	Across RM 324 Left Fountain	Initial	27-OCT-16	0.310	ppb
52292	52292-3-HAL-F02	Across RM 324 Right Fountain	Flush180	27-OCT-16	0.460	ppb
52292	52292-3-HAL-F02	Across RM 324 Right Fountain	Flush180	27-OCT-16	0.480	ppb
52292	52292-3-HAL-F02	Across RM 324 Right Fountain	Flush180	27-OCT-16	0.470	ppb
52292	52292-3-HAL-F02	Across RM 324 Right Fountain	Flush180	27-OCT-16	0.450	ppb
52292	52292-3-HAL-F02	Across RM 324 Right Fountain	Initial	27-OCT-16	0.370	ppb
52292	52292-1-HAL-F03	Across Rm 124 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F03	Across Rm 124 Left Fountain	Flush	23-JAN-2024	1.020	ug/L
52292	52292-1-HAL-F03	Across Rm 124 Left Fountain	Flush	23-JAN-2024	1.740	ug/L
52292	52292-1-HAL-F03	Across Rm 124 Left Fountain	Flush	23-JAN-2024	1.320	ug/L
52292	52292-1-HAL-F03	Across Rm 124 Left Fountain	Initial	23-JAN-2024	1.270	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
52292	52292-1-HAL-F04	Across Rm 124 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F04	Across Rm 124 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F04	Across Rm 124 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F04	Across Rm 124 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-F04	Across Rm 124 Right Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-1-HAL-BF01	Across Social RM Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF01	Across Social RM Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF01	Across Social RM Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF01	Across Social RM Bottle Filler	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-BF01	Across Social RM Bottle Filler	Initial	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush180	27-OCT-16	0.360	ppb
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush180	27-OCT-16	0.410	ppb
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush180	27-OCT-16	0.340	ppb
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush180	27-OCT-16	0.320	ppb
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Flush180	18-DEC-20	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Initial	27-OCT-16	0.220	ppb
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Initial	18-DEC-20	1.000	ug/L
52292	52292-1-HAL-F07	Across Social RM Left Fountain	Initial	12-OCT-2023	1.000	ug/L
52292	52292-1-HAL-F08	Across Social RM Right Fountain	Flush180	27-OCT-16	0.810	ppb
52292	52292-1-HAL-F08	Across Social RM Right Fountain	Flush180	27-OCT-16	0.980	ppb
52292	52292-1-HAL-F08	Across Social RM Right Fountain	Flush180	27-OCT-16	1.100	ppb
52292	52292-1-HAL-F08	Across Social RM Right Fountain	Flush180	27-OCT-16	1.200	ppb
52292	52292-1-HAL-F08	Across Social RM Right Fountain	Initial	27-OCT-16	1.200	ppb
52292	52292-3-HAL-F09	Across from Rm 313 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F09	Across from Rm 313 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F09	Across from Rm 313 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F09	Across from Rm 313 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F09	Across from Rm 313 Left Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	01-MAY-2024	7.830	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	01-MAY-2024	8.910	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	01-MAY-2024	8.550	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	01-MAY-2024	8.330	ug/L
52292	52292-3-HAL-	Across from Rm 319 Left Fountain	Flush	23-JAN-2024	5.770	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	23-JAN-2024	11.300	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	23-JAN-2024	8.980	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Flush	23-JAN-2024	7.310	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Initial	01-MAY-2024	7.070	ug/L
52292	52292-3-HAL-F03	Across from Rm 319 Left Fountain	Initial	23-JAN-2024	6.760	ug/L
52292	52292-3-HAL-F04	Across from Rm 319 Right Fountain	Flush	23-JAN-2024	1.130	ug/L
52292	52292-3-HAL-F04	Across from Rm 319 Right Fountain	Flush	23-JAN-2024	1.280	ug/L
52292	52292-3-HAL-F04	Across from Rm 319 Right Fountain	Flush	23-JAN-2024	1.290	ug/L
52292	52292-3-HAL-F04	Across from Rm 319 Right Fountain	Flush	23-JAN-2024	1.300	ug/L
52292	52292-3-HAL-F04	Across from Rm 319 Right Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F02	Across from Rm 324 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F02	Across from Rm 324 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F02	Across from Rm 324 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F02	Across from Rm 324 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-3-HAL-F02	Across from Rm 324 Right Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F09	Across room 213 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F09	Across room 213 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F09	Across room 213 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F09	Across room 213 Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F09	Across room 213 Left Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-RBF01	Across room 213 Retro Bottle filler	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-RBF01	Across room 213 Retro Bottle filler	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-RBF01	Across room 213 Retro Bottle filler	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-RBF01	Across room 213 Retro Bottle filler	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-RBF01	Across room 213 Retro Bottle filler	Initial	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F10	Across room 213 Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F10	Across room 213 Right Fountain	Flush	23-JAN-2024	1.080	ug/L
52292	52292-2-HAL-F10	Across room 213 Right Fountain	Flush	23-JAN-2024	1.300	ug/L
52292	52292-2-HAL-F10	Across room 213 Right Fountain	Flush	23-JAN-2024	1.400	ug/L
52292	52292-2-HAL-F10	Across room 213 Right Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	1.900	ppb
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	1.700	ppb
52292	52292-3-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	14.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52292	52292-3-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	3.100	ppb
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	1.600	ppb
52292	52292-3-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	13.000	ppb
52292	52292-3-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	7.700	ppb
52292	52292-2-HAL-F05	By Elevator Left Fountain	Flush180	27-OCT-16	1.600	ppb
52292	52292-3-HAL-F05	By Elevator Left Fountain	Initial	27-OCT-16	2.000	ppb
52292	52292-2-HAL-F05	By Elevator Left Fountain	Initial	27-OCT-16	1.000	ppb
52292	52292-2-HAL-F05	By Elevator Left Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	3.000	ppb
52292	52292-2-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	2.800	ppb
52292	52292-2-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	3.100	ppb
52292	52292-3-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	9.800	ppb
52292	52292-3-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	10.000	ppb
52292	52292-3-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	9.500	ppb
52292	52292-2-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	3.100	ppb
52292	52292-3-HAL-F06	By Elevator Right Fountain	Flush180	27-OCT-16	5.600	ppb
52292	52292-3-HAL-F06	By Elevator Right Fountain	Initial	27-OCT-16	1.300	ppb
52292	52292-2-HAL-F06	By Elevator Right Fountain	Initial	27-OCT-16	2.600	ppb
52292	52292-3-HAL-F07	By RM 302 Left Fountain	Flush180	27-OCT-16	0.390	ppb
52292	52292-3-HAL-F07	By RM 302 Left Fountain	Flush180	27-OCT-16	0.260	ppb
52292	52292-3-HAL-F07	By RM 302 Left Fountain	Flush180	27-OCT-16	0.310	ppb
52292	52292-3-HAL-F07	By RM 302 Left Fountain	Flush180	27-OCT-16	0.350	ppb
52292	52292-3-HAL-F07	By RM 302 Left Fountain	Initial	27-OCT-16	0.250	ppb
52292	52292-3-HAL-F08	By RM 302 Right Fountain	Flush180	27-OCT-16	0.240	ppb
52292	52292-3-HAL-F08	By RM 302 Right Fountain	Flush180	27-OCT-16	0.170	ppb
52292	52292-3-HAL-F08	By RM 302 Right Fountain	Flush180	27-OCT-16	0.210	ppb
52292	52292-3-HAL-F08	By RM 302 Right Fountain	Flush180	27-OCT-16	0.280	ppb
52292	52292-3-HAL-F08	By RM 302 Right Fountain	Initial	27-OCT-16	0.280	ppb
52292	52292-3-HAL-F09	By RM 313 Left Fountain	Flush180	27-OCT-16	0.400	ppb
52292	52292-3-HAL-F09	By RM 313 Left Fountain	Flush180	27-OCT-16	0.440	ppb
52292	52292-3-HAL-F09	By RM 313 Left Fountain	Flush180	27-OCT-16	0.380	ppb
52292	52292-3-HAL-F09	By RM 313 Left Fountain	Flush180	27-OCT-16	0.400	ppb
52292	52292-3-HAL-F09	By RM 313 Left Fountain	Initial	27-OCT-16	1.000	ppb
52292	52292-3-HAL-F10	By RM 313 Right Fountain	Flush180	27-OCT-16	1.000	ppb
52292	52292-3-HAL-F10	By RM 313 Right Fountain	Flush180	27-OCT-16	1.000	ppb
52292	52292-3-HAL-F10	By RM 313 Right Fountain	Flush180	27-OCT-16	1.000	ppb
52292	52292-3-HAL-F10	By RM 313 Right Fountain	Flush180	27-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52292	52292-3-HAL-F10	By RM 313 Right Fountain	Initial	27-OCT-16	1.000	ppb
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush180	27-OCT-16	1.000	ppb
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush180	27-OCT-16	0.230	ppb
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush180	27-OCT-16	1.000	ppb
52292	52292-1-NUR-S01	Health Services Nurse Room	Flush180	27-OCT-16	1.000	ppb
52292	52292-1-NUR-S01	Health Services Nurse Room	Initial	27-OCT-16	0.210	ppb
52292	52292-1-NUR-S01	Health Services Nurse Room	Initial	12-OCT-2023	1.000	ug/L
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	27-OCT-16	0.390	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	27-OCT-16	1.000	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	27-OCT-16	1.400	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	27-OCT-16	0.390	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	18-NOV-16	1.000	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	18-NOV-16	1.000	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	18-NOV-16	0.310	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Flush180	18-NOV-16	0.340	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Initial	27-OCT-16	22.000	ppb
52292	52292-1-140-S02	In RM 140 Special EDS Rm Right sink	Initial	18-NOV-16	0.390	ppb
52292	52292-1-140-S01	In RM 140 Special Eds RM Left Sink	Flush180	27-OCT-16	0.280	ppb
52292	52292-1-140-S01	In RM 140 Special Eds RM Left Sink	Flush180	27-OCT-16	0.310	ppb
52292	52292-1-140-S01	In RM 140 Special Eds RM Left Sink	Flush180	27-OCT-16	0.310	ppb
52292	52292-1-140-S01	In RM 140 Special Eds RM Left Sink	Flush180	27-OCT-16	0.170	ppb
52292	52292-1-140-S01	In RM 140 Special Eds RM Left Sink	Initial	27-OCT-16	1.500	ppb
52292	52292-1-141-F01	In ROTC RM	Flush180	27-OCT-16	2.800	ppb
52292	52292-1-141-F01	In ROTC RM	Flush180	27-OCT-16	2.200	ppb
52292	52292-1-141-F01	In ROTC RM	Flush180	27-OCT-16	2.400	ppb
52292	52292-1-141-F01	In ROTC RM	Flush180	27-OCT-16	2.700	ppb
52292	52292-1-141-F01	In ROTC RM	Initial	27-OCT-16	4.400	ppb
52292	52292-1-SR-S01	In Social RM Pantry	Flush180	27-OCT-16	2.600	ppb
52292	52292-1-SR-S01	In Social RM Pantry	Flush180	27-OCT-16	1.500	ppb
52292	52292-1-SR-S01	In Social RM Pantry	Flush180	27-OCT-16	3.100	ppb
52292	52292-1-SR-S01	In Social RM Pantry	Flush180	27-OCT-16	2.500	ppb
52292	52292-1-SR-S01	In Social RM Pantry	Initial	27-OCT-16	2.000	ppb
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-CAF-	Next to Serving Station Left	Flush180	27-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush180	27-OCT-16	0.370	ppb
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush180	18-DEC-20	1.000	ug/L
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Initial	27-OCT-16	1.000	ppb
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Initial	18-DEC-20	1.000	ug/L
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F01	Next to Serving Station Left Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush180	27-OCT-16	0.240	ppb
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush180	27-OCT-16	0.270	ppb
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush180	27-OCT-16	0.270	ppb
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Flush180	27-OCT-16	0.290	ppb
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Initial	27-OCT-16	0.210	ppb
52292	52292-4-CAF-F02	Next to Serving Station Right Fountain	Initial	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F03	Outside Boy's Bathroom Left Fountain	Flush	23-JAN-2024	1.000	ug/L
52292	52292-2-HAL-F03	Outside Boy's Bathroom Left Fountain	Flush	23-JAN-2024	1.180	ug/L
52292	52292-2-HAL-F03	Outside Boy's Bathroom Left Fountain	Flush	23-JAN-2024	1.120	ug/L
52292	52292-2-HAL-F03	Outside Boy's Bathroom Left Fountain	Flush	23-JAN-2024	1.230	ug/L
52292	52292-2-HAL-F03	Outside Boy's Bathroom Left Fountain	Initial	23-JAN-2024	2.140	ug/L
52292	52292-2-HAL-F03	Outside Boys Bathroom Left Fountain	Flush180	27-OCT-16	0.530	ppb
52292	52292-2-HAL-F03	Outside Boys Bathroom Left Fountain	Flush180	27-OCT-16	0.480	ppb
52292	52292-2-HAL-F03	Outside Boys Bathroom Left Fountain	Flush180	27-OCT-16	0.480	ppb
52292	52292-2-HAL-F03	Outside Boys Bathroom Left Fountain	Flush180	27-OCT-16	0.530	ppb
52292	52292-2-HAL-F03	Outside Boys Bathroom Left Fountain	Initial	27-OCT-16	0.410	ppb
52292	52292-2-HAL-F04	Outside Boys Bathroom Right Fountain	Flush180	27-OCT-16	0.260	ppb
52292	52292-2-HAL-F04	Outside Boys Bathroom Right Fountain	Flush180	27-OCT-16	0.290	ppb
52292	52292-2-HAL-F04	Outside Boys Bathroom Right Fountain	Flush180	27-OCT-16	1.000	ppb
52292	52292-2-HAL-F04	Outside Boys Bathroom Right Fountain	Flush180	27-OCT-16	0.200	ppb
52292	52292-2-HAL-F04	Outside Boys Bathroom Right Fountain	Initial	27-OCT-16	1.000	ppb
52292	52292-2-HAL-202	Outside Room 202 Left Fountain	Flush	23-JAN-2024	2.290	ug/L
52292	52292-2-HAL-	Outside Room 202 Left Fountain	Flush	23-JAN-2024	2.080	ug/L

Water Quality Assessment Robert Lindblom Math & Science Academy HS

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	202					
52292	52292-2-HAL-202	Outside Room 202 Left Fountain	Flush	23-JAN-2024	1.850	ug/L
52292	52292-2-HAL-202	Outside Room 202 Left Fountain	Flush	23-JAN-2024	1.700	ug/L
52292	52292-2-HAL-202	Outside Room 202 Left Fountain	Initial	23-JAN-2024	1.690	ug/L
52292	52292-1-POOL-F01	Pool Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F01	Pool Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F01	Pool Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F01	Pool Left Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F01	Pool Left Fountain	Flush180	27-OCT-16	0.590	ppb
52292	52292-1-POOL-F01	Pool Left Fountain	Flush180	27-OCT-16	0.350	ppb
52292	52292-1-POOL-F01	Pool Left Fountain	Flush180	27-OCT-16	0.760	ppb
52292	52292-1-POOL-F01	Pool Left Fountain	Flush180	27-OCT-16	0.710	ppb
52292	52292-1-POOL-F01	Pool Left Fountain	Initial	27-OCT-16	1.500	ppb
52292	52292-1-POOL-F01	Pool Left Fountain	Initial	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F02	Pool Right Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F02	Pool Right Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F02	Pool Right Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F02	Pool Right Fountain	Flush	12-OCT-2023	1.000	ug/L
52292	52292-1-POOL-F02	Pool Right Fountain	Initial	12-OCT-2023	1.000	ug/L
52292	52292-4-KIT-KS05	Prep Sink Across Dishwashing Station	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS05	Prep Sink Across Dishwashing Station	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS05	Prep Sink Across Dishwashing Station	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS05	Prep Sink Across Dishwashing Station	Flush180	27-OCT-16	1.000	ppb
52292	52292-4-KIT-KS05	Prep Sink Across Dishwashing Station	Initial	27-OCT-16	0.510	ppb
52292	52292-4-KIT-KS04	Prep Sink Across Pot Filler	Flush180	27-OCT-16	0.280	ppb
52292	52292-4-KIT-KS04	Prep Sink Across Pot Filler	Flush180	27-OCT-16	0.880	ppb
52292	52292-4-KIT-KS04	Prep Sink Across Pot Filler	Flush180	27-OCT-16	0.180	ppb
52292	52292-4-KIT-KS04	Prep Sink Across Pot Filler	Flush180	27-OCT-16	0.350	ppb
52292	52292-4-KIT-KS04	Prep Sink Across Pot Filler	Initial	27-OCT-16	0.760	ppb