



Sep 10, 2024

LITTLE VILLAGE

2620 S LAWNSDALE AVE, Chicago IL 60623.

Dear **LITTLE VILLAGE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LITTLE VILLAGE

2620 S LAWDALE AVE, Chicago IL 60623.

Estimadas familias de **LITTLE VILLAGE:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Initial	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-F02	Main- Across From Room 204, Bottle Filler	Initial	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Initial	23-SEP-16	1.000	ppb
51264	51264-2-W-HAL-WC01	Main- Across From Room 204, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Initial	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-F02	Main- Across From Room 302, Bottle Filler	Initial	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	20-SEP-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Flush180	30-JUL-20	1.000	ug/L
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Initial	23-SEP-16	1.000	ppb
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-3-W-HAL-WC01	Main- Across From Room 302, Fountain	Initial	30-JUL-20	1.000	ug/L
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Initial	23-SEP-16	1.000	ppb
51264	51264-1-W-HAL-F03	Main- Across Room 105, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	23-SEP-16	0.265	ppb
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	23-SEP-16	0.254	ppb
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	23-SEP-16	0.291	ppb
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	23-SEP-16	0.599	ppb
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Initial	23-SEP-16	1.240	ppb
51264	51264-1-E-101-S17	Main- Inside Room 101 Center, Sink	Initial	20-SEP-19	1.260	ug/L
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Initial	23-SEP-16	1.000	ppb
51264	51264-1-E-101-F16	Main- Inside Room 101 Left, Fountain	Initial	20-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	23-SEP-16	0.202	ppb
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	23-SEP-16	0.186	ppb
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	23-SEP-16	0.256	ppb
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	23-SEP-16	0.237	ppb
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Initial	23-SEP-16	0.481	ppb
51264	51264-1-E-101-S18	Main- Inside Room 101 Left, Sink	Initial	20-SEP-19	1.110	ug/L
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	23-SEP-16	0.284	ppb
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	23-SEP-16	1.900	ppb
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	23-SEP-16	0.414	ppb
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	23-SEP-16	1.050	ppb
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Initial	23-SEP-16	1.290	ppb
51264	51264-1-W-102-S14	Main- Inside Room 102 Center, Sink	Initial	20-SEP-19	1.320	ug/L
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	23-SEP-16	0.220	ppb
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	23-SEP-16	0.643	ppb
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	23-SEP-16	0.327	ppb
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	23-SEP-16	0.448	ppb
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Initial	23-SEP-16	0.454	ppb
51264	51264-1-W-102-S13	Main- Inside Room 102 Left, Sink	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	23-SEP-16	0.389	ppb
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	23-SEP-16	0.930	ppb
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	23-SEP-16	5.030	ppb
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	23-SEP-16	1.710	ppb
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	102-F15	Fountain				
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Initial	23-SEP-16	0.164	ppb
51264	51264-1-W-102-F15	Main- Inside Room 102 Right, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	23-SEP-16	1.030	ppb
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	23-SEP-16	0.461	ppb
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	23-SEP-16	0.632	ppb
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	23-SEP-16	0.607	ppb
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	20-SEP-19	1.140	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	07-JAN-20	5.850	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	07-JAN-20	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	07-JAN-20	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	07-JAN-20	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	08-NOV-19	17.900	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	08-NOV-19	33.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	08-NOV-19	35.100	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	08-NOV-19	5.970	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	14-FEB-20	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	14-FEB-20	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	14-FEB-20	1.080	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Flush180	14-FEB-20	1.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Initial	23-SEP-16	3.610	ppb
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Initial	20-SEP-19	5.120	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Initial	07-JAN-20	1.740	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Initial	08-NOV-19	62.000	ug/L
51264	51264-1-E-103-S11	Main- Inside Room 103 Center, Sink	Initial	14-FEB-20	1.000	ug/L
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	23-SEP-16	0.463	ppb
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	23-SEP-16	0.409	ppb
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	23-SEP-16	0.401	ppb
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	23-SEP-16	0.313	ppb
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Flush180	30-JUL-20	1.000	ug/L
51264	51264-1-E-	Main- Inside Room 103 Left,	Initial	23-SEP-16	1.090	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	103-F10	Fountain				
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-E-103-F10	Main- Inside Room 103 Left, Fountain	Initial	30-JUL-20	1.000	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	2.900	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	23-SEP-16	0.974	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	23-SEP-16	6.430	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	23-SEP-16	6.720	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	23-SEP-16	4.300	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	2.900	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	2.100	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	2.100	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	4.200	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	4.200	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	2.800	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	07-DEC-16	2.800	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	20-SEP-19	2.360	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	20-SEP-19	5.640	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	20-SEP-19	3.930	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	20-SEP-19	2.360	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	08-NOV-19	1.780	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	08-NOV-19	1.710	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	08-NOV-19	1.600	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Flush180	08-NOV-19	1.500	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Initial	23-SEP-16	15.300	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Initial	07-DEC-16	1.000	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Initial	07-DEC-16	1.000	ppb
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Initial	20-SEP-19	15.900	ug/L
51264	51264-1-E-103-S12	Main- Inside Room 103 Right, Sink	Initial	08-NOV-19	3.050	ug/L
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	23-SEP-16	1.160	ppb
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	23-SEP-16	0.934	ppb
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	23-SEP-16	2.080	ppb
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	23-SEP-16	1.880	ppb
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Initial	23-SEP-16	4.510	ppb
51264	51264-1-W-104-S08	Main- Inside Room 104 Center, Sink	Initial	20-SEP-19	1.520	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	23-SEP-16	0.799	ppb
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	23-SEP-16	1.010	ppb
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	23-SEP-16	0.788	ppb
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	23-SEP-16	0.728	ppb
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	20-SEP-19	1.040	ug/L
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Initial	23-SEP-16	4.410	ppb
51264	51264-1-W-104-S07	Main- Inside Room 104 Left, Sink	Initial	20-SEP-19	3.030	ug/L
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	23-SEP-16	0.202	ppb
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	23-SEP-16	0.167	ppb
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	23-SEP-16	0.131	ppb
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Initial	23-SEP-16	0.176	ppb
51264	51264-1-W-104-F09	Main- Inside Room 104 Right, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	23-SEP-16	0.910	ppb
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	23-SEP-16	0.930	ppb
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	23-SEP-16	0.894	ppb
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	23-SEP-16	0.817	ppb
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Initial	23-SEP-16	2.420	ppb
51264	51264-1-N-105-S05	Main- Inside Room 105 Center, Sink	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	23-SEP-16	1.190	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	23-SEP-16	1.930	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	23-SEP-16	0.716	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	23-SEP-16	0.934	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Initial	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Initial	23-SEP-16	19.700	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Initial	07-DEC-16	1.000	ppb
51264	51264-1-N-105-F04	Main- Inside Room 105 Left, Fountain	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	23-SEP-16	1.000	ppb
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Initial	23-SEP-16	1.000	ppb
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS01	Main- Kitchen Center, Sink	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	23-SEP-16	0.205	ppb
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	23-SEP-16	0.199	ppb
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	23-SEP-16	0.192	ppb
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	23-SEP-16	0.200	ppb
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Initial	23-SEP-16	0.722	ppb
51264	51264-1-W-TL-S19	Main- Teachers Lounge, Sink	Initial	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	23-SEP-16	0.957	ppb
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	23-SEP-16	0.563	ppb
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	23-SEP-16	0.190	ppb
51264	51264-1-W-	Main-Kitchen West Wall, Sink	Flush180	23-SEP-16	0.382	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS02					
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Flush180	20-SEP-19	1.000	ug/L
51264	51264-1-W-KIT-KS02	Main-Kitchen West Wall, Sink	Initial	23-SEP-16	0.901	ppb
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Flush180	30-JUL-20	1.000	ug/L
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Initial	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F02	Modular- Next to Room 104 Left, Fountain	Initial	30-JUL-20	1.000	ug/L
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Flush180	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Flush180	30-JUL-20	1.000	ug/L
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Initial	23-SEP-16	1.000	ppb
54621	54621-1-HAL-F01	Modular- Next to Room 104 Right, Fountain	Initial	30-JUL-20	1.000	ug/L